

SYMBOL SCHEDULE	
---	FIRE PARTITION - 2HR. RATED
---	SMOKE BARRIER PARTITION - 2HR. RATED
☐	FIRE ALARM SYSTEM PULL STATION
⊙	FIRE ALARM SYSTEM SMOKE DETECTOR
⊖	FIRE ALARM SYSTEM DUCT DETECTOR
⊠	FIRE ALARM SYSTEM HORN
☐	DOOR HOLDER
FACP	FIRE ALARM CONTROL PANEL
REMOTE FACP	REMOTE FIRE ALARM CONTROL PANEL
⊠	SPRINKLER FLOW SWITCH & TAMPER SWITCH
⊖	DOOR TAG
⊠	CEILING MOUNTED HORN/STROBE


DOOR SCHEDULE				
OPENING NUMBER	DOORS		FRAMES	LABEL
	MATERIAL	SIZE	MATERIAL	
223	H.M.	3'-6" x 6'-8" x 1-3/4"	METAL	???
224	H.M.	3'-6" x 6'-8" x 1-3/4"	METAL	???
225	H.M.	3'-6" x 6'-8" x 2"	METAL	20 MIN.
226	H.M.	3'-6" x 6'-8" x 2"	METAL	60 MIN.
227	H.M.	3'-0" x 6'-8" x 1-3/4"	METAL	60 MIN.
228	H.M.	3'-6" x 6'-8" x 1-3/4"	METAL	NONE
229	H.M.	3'-6" x 6'-8" x 1-3/4"	METAL	???
230	H.M.	3'-6" x 6'-8" x 1-3/4"	METAL	NONE
231	H.M.	3'-6" x 6'-8" x 1-3/4"	METAL	NONE
232	-	-	-	-
233	H.M.	3'-0" x 6'-8" x 1-3/4"	METAL	NONE
234	H.M.	3'-6" x 6'-8" x 1-3/4"	METAL	NONE
235	H.M.	3'-0" x 6'-8" x 1-3/4"	METAL	NONE
236	H.M.	3'-6" x 6'-8" x 2"	METAL	20 MIN.
237	H.M.	3'-6" x 6'-8" x 2"	METAL	20 MIN.
238	-	-	-	-
239	H.M.	3'-6" x 6'-8" x 1-3/4"	METAL	??
240	H.M.	3'-0" x 6'-8" x 1-3/4"	METAL	3.0 HR.
241	H.M.	3'-0" x 6'-8" x 1-3/4"	METAL	1.5 HR.
242	H.M.	6'-0" x 6'-8" x 1-3/4"	METAL	20 MIN.
243	H.M.	3'-0" x 6'-8" x 1-3/4"	METAL	60 MIN.
244	H.M.	3'-6" x 6'-8" x 2"	METAL	60 MIN.

**OAKCREST HOUSE**  
**SECOND FLOOR - EAST**  
 SCALE: 3/32" = 1'-0"

No.	Date	Description
1	05-15-2017	EDITED SYMBOL SCHEDULE

**Daniel T. Calongne**  
 and  
 Associates  
7911 Winwood Blvd., Suite D  
 Jackson, Louisiana 70221  
 voice (225) 922-3223 fax (225) 922-2414

**EASTERN LOUISIANA MENTAL HEALTH SYSTEM**  
 JACKSON, LOUISIANA  
  
**LIFE SAFETY CODE DRAWINGS**  
 FOR VARIOUS BUILDINGS



**DRAWING TITLE**  
**LIFE SAFETY PLAN**  
**OAKCREST HOUSE**  
**SECOND FLOOR**  
 Drawn: SNA  
 Checked: DTC  
 Date: 2-24-12  
 Project No.: 11-077  
 Sheet