

FUEL TANK	DIESEL/GAS	BRAND/KW	BUILDING	SERIEL #	MODEL #	CONSUMPTION	HRS. RUN TIME	96 HOUR CONSUMPTION	7 DAY CONSUMPTION
16 GAL	GAS	GROUP HOME 165	GENERAC/17500KW			1.6 GPH	10	153.6G	268.8G
16 GAL	GAS	GROUP HOME 99	GENERAC/17500KW			1.6 GPH	10	153.6G	268.8G
3.5 GAL	DIESEL	GROUP HOME 98	TITAN/7500W			.4 GPH	9	38.4G	67.2G
3.5 GAL	DIESEL	FRONT GATE	TITAN/7500W			.4 GPH	9	38.4G	67.2G

UG=Underground Tank

We have two 100 gallon tanks on mobile trucks along with two 300 gallon tanks, one 250 gallon tank above ground, and one 2,000 gallon above ground tank. There are a total of 3,050 gallons of Diesel to resupply the generator tanks.

In the event that we will run on generator power for 7 days, we will need an additional 5,529 gallons of fuel