



**State of Louisiana**  
Louisiana Department of Health  
Office of Public Health

October 21, 2020

Ms. Carey Laviolette  
Superintendent of Schools  
Iberia Parish School Board  
1500 Jane Street  
New Iberia, LA 70563

RE: Results of School Drinking Water Testing  
Delcambre Elementary School (SCH023030)  
706 Martin Luther King Drive, LA 70528

Dear Ms. Laviolette,

Act 632 of the 2018 Regular Session required the Louisiana Department of Health (LDH) to establish a pilot program for drinking water testing at 12 public elementary schools that were constructed prior to 1986 or which may otherwise be susceptible to drinking water contamination. Thank you for your participation and cooperation in this pilot program.

On October 20, 2020 a total of 28 water samples were collected from the above referenced school in accordance with guidance provided in the Environmental Protection Agency's (EPA's) - 3Ts for Reducing Lead in Drinking Water in Schools Manual. Attached are the lead and copper sample results. Please note that the sample result for sample point ID "TCR-005" is for a sample collected from the water system.

All sample results were evaluated against the state recommended action level of 0.015 mg/L for Lead and 1.3 mg/L for Copper for drinking water. All sample results are below the state recommended action level of 0.015 mg/L for Lead for drinking water. However, there were five (5) "first draw" sample results that were 0.005 mg/L or greater for Lead. For those sample locations (fixtures), LDH advises the school to perform a daily flush at those fixtures prior to use to reduce levels of lead in the drinking water.

LDH recommends that all schools follow the guidance provided in the EPA-3Ts manual to safeguard against lead in the drinking water. The EPA-3Ts manual was developed to assist schools with lead in drinking water prevention programs. This guidance is intended for use by school officials responsible for the maintenance and/or safety of school's drinking water. This document along with other helpful information is available for on EPA's website at: <https://www.epa.gov/dwreginfo/3ts-reducing-lead-drinking-water-schools-and-child-care-facilities>.

October 21, 2020

Page 2

RE: Results of School Drinking Water Testing  
Delcambre Elementary School (SCH023030)

Please notify this office of any control or remediation measures taken by the school. LDH will perform follow up sampling to confirm the corrective actions were effective.

Please feel free to contact me or Caryn Benjamin regarding any of the enclosed information.

Sincerely,

Amanda Ames, P.E.  
Chief Engineer and Safe Drinking Water Administrator, LDH

Attachment

cc: Mrs. Jodi Romero, Principal, Delcambre Elementary School

Sample Results Summary

Delcambre Elementary School (SCH023030)		Lead (AL = 0.015 mg/L)		Copper (AL = 1.3 mg/L)	
Sample Point Description and ID		First Draw Sample	After Flush Sample	First Draw Sample	After Flush Sample
TANK FOUNTAIN, FRONT ENT, OFFICE, LEFT	DF01	ND	ND	0.3 mg/L	0.5 mg/L
TANK FOUNTAIN, RM 306	DF03	0.001 mg/L	0.001 mg/L	0.8 mg/L	0.5 mg/L
TANK FOUNTAIN, RM 404	DF04	0.001 mg/L	ND	0.5 mg/L	0.4 mg/L
TANK FOUNTAIN, RM 702	DF05	0.002 mg/L	ND	0.9 mg/L	0.4 mg/L
TRI-BUBBLER, OUTSIDE CAFETERIA	DF06	0.008 mg/L	0.002 mg/L	0.4 mg/L	0.3 mg/L
TANK FOUNTAIN, NRR, RM 110	DF07	ND	ND	1.1 mg/L	0.2 mg/L
TRI-BUBBLER, OUTSIDE, PLAYGROUND	DF08	0.008 mg/L	0.001 mg/L	0.2 mg/L	0.2 mg/L
TANK FOUNTAIN, GIRLS RR, RIGHTSIDE	DF09	ND	ND	0.3 mg/L	0.6 mg/L
TANK FOUNTAIN, BOYS RR, RIGHTSIDE	DF11	ND	0.001 mg/L	0.3 mg/L	0.8 mg/L
POT FILLER, RIGHTSIDE	PF01	0.009 mg/L	ND	0.2 mg/L	0.2 mg/L
POT FILLER, LEFTSIDE	PF02	0.012 mg/L	ND	0.2 mg/L	0.2 mg/L
POT FILLER, KETTLE	PF03	0.005 mg/L	ND	0.2 mg/L	0.3 mg/L
2C SINK, KITCHEN, LEFTSIDE	SK01	0.002 mg/L	ND	0.3 mg/L	0.2 mg/L
3C SINK, KITCHEN, RIGHTSIDE	SK02	ND	ND	0.2 mg/L	0.3 mg/L

"ND" - None Detect - contaminant level is below the Laboratory Reporting limit (<0.001 mg/L for Lead)

"AL" - Action Level - state recommended action level



State of Louisiana  
Louisiana Department of Health  
Public Health Laboratories  
1209 Leesville Avenue  
Baton Rouge, LA 70802  
225-219-5200  
<http://www.dhh.la.gov/lab>



**Amended**

October 21, 2020

The following analytical results have been obtained for the indicated sample(s) which was submitted to this laboratory:

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, FRONT ENT, OFFICE, LEFT	<b>Sample ID:</b>	B2005459-001
<b>Sample Pt ID:</b>	DF01	<b>Sample Type:</b>	Special
<b>PWS ID:</b>	LA1113004	<b>Sample Collector:</b>	Hungerford
<b>Water System Name:</b>	TOWN OF DELCAMBRE WATER SYSTEM	<b>Collection date:</b>	10/20/2020 5:27:00AM
<b>Facility ID:</b>	SCH023030	<b>Lab Submittal date:</b>	10/20/2020 1:00:00PM
<b>Collection Address:</b>	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.3	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	TANK FOUNTAIN,, RM 306	<b>Sample ID:</b>	B2005459-002
<b>Sample Pt ID:</b>	DF03	<b>Sample Type:</b>	Special
<b>PWS ID:</b>	LA1113004	<b>Sample Collector:</b>	Hungerford
<b>Water System Name:</b>	TOWN OF DELCAMBRE WATER SYSTEM	<b>Collection date:</b>	10/20/2020 5:30:00AM
<b>Facility ID:</b>	SCH023030	<b>Lab Submittal date:</b>	10/20/2020 1:00:00PM
<b>Collection Address:</b>	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.001	mg/L	0.001	0.015	
Copper	0.8	mg/L	0.1	1.3	> 1/2 MCL

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, RM 404	<b>Sample ID:</b>	B2005459-003
<b>Sample Pt ID:</b>	DF04	<b>Sample Type:</b>	Special
<b>PWS ID:</b>	LA1113004	<b>Sample Collector:</b>	Hungerford
<b>Water System Name:</b>	TOWN OF DELCAMBRE WATER SYSTEM	<b>Collection date:</b>	10/20/2020 5:34:00AM
<b>Facility ID:</b>	SCH023030	<b>Lab Submittal date:</b>	10/20/2020 1:00:00PM
<b>Collection Address:</b>	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.001	mg/L	0.001	0.015	
Copper	0.5	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, RM 702	Sample ID:	B2005459-004
<b>Sample Pt ID:</b>	DF05	Sample Type:	Special
PWS ID:	LA1113004	Sample Collector:	Hungerford
Water System Name:	TOWN OF DELCAMBRE WATER SYSTEM	Collection date:	10/20/2020 5:34:00AM
Facility ID:	SCH023030	Lab Submittal date:	10/20/2020 1:00:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.002	mg/L	0.001	0.015	
Copper	0.9	mg/L	0.1	1.3	> 1/2 MCL

<b>Sample Pt. Description:</b>	TRI-BUBBLER, OUTSIDE CAFETERIA	Sample ID:	B2005459-005
<b>Sample Pt ID:</b>	DF06	Sample Type:	Special
PWS ID:	LA1113004	Sample Collector:	Hungerford
Water System Name:	TOWN OF DELCAMBRE WATER SYSTEM	Collection date:	10/20/2020 5:35:00AM
Facility ID:	SCH023030	Lab Submittal date:	10/20/2020 1:00:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.008	mg/L	0.001	0.015	> 1/2 MCL
Copper	0.4	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, NRR, RM 110	Sample ID:	B2005459-006
<b>Sample Pt ID:</b>	DF07	Sample Type:	Special
PWS ID:	LA1113004	Sample Collector:	Hungerford
Water System Name:	TOWN OF DELCAMBRE WATER SYSTEM	Collection date:	10/20/2020 5:35:00AM
Facility ID:	SCH023030	Lab Submittal date:	10/20/2020 1:00:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	1.1	mg/L	0.1	1.3	> 1/2 MCL

<b>Sample Pt. Description:</b>	TRI-BUBBLER, OUTSIDE, PLAYGROUND	Sample ID:	B2005459-007
<b>Sample Pt ID:</b>	DF08	Sample Type:	Special
PWS ID:	LA1113004	Sample Collector:	Hungerford
Water System Name:	TOWN OF DELCAMBRE WATER SYSTEM	Collection date:	10/20/2020 5:36:00AM
Facility ID:	SCH023030	Lab Submittal date:	10/20/2020 1:00:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.008	mg/L	0.001	0.015	> 1/2 MCL
Copper	0.2	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, GIRLS RR, RIGHTSIDE	Sample ID:	B2005459-008
<b>Sample Pt ID:</b>	DF09	Sample Type:	Special
PWS ID:	LA1113004	Sample Collector:	Hungerford
Water System Name:	TOWN OF DELCAMBRE WATER SYSTEM	Collection date:	10/20/2020 5:33:00AM
Facility ID:	SCH023030	Lab Submittal date:	10/20/2020 1:00:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.3	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, BOYS RR, RIGHTSIDE	Sample ID:	B2005459-009
<b>Sample Pt ID:</b>	DF11	Sample Type:	Special
PWS ID:	LA1113004	Sample Collector:	Hungerford
Water System Name:	TOWN OF DELCAMBRE WATER SYSTEM	Collection date:	10/20/2020 5:35:00AM
Facility ID:	SCH023030	Lab Submittal date:	10/20/2020 1:00:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.3	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	POT FILLER, RIGHTSIDE	Sample ID:	B2005459-010
<b>Sample Pt ID:</b>	PF01	Sample Type:	Special
PWS ID:	LA1113004	Sample Collector:	Hungerford
Water System Name:	TOWN OF DELCAMBRE WATER SYSTEM	Collection date:	10/20/2020 5:30:00AM
Facility ID:	SCH023030	Lab Submittal date:	10/20/2020 1:00:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.009	mg/L	0.001	0.015	> 1/2 MCL
Copper	0.2	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	POT FILLER, LEFTSIDE	Sample ID:	B2005459-011
<b>Sample Pt ID:</b>	PF02	Sample Type:	Special
PWS ID:	LA1113004	Sample Collector:	Hungerford
Water System Name:	TOWN OF DELCAMBRE WATER SYSTEM	Collection date:	10/20/2020 5:31:00AM
Facility ID:	SCH023030	Lab Submittal date:	10/20/2020 1:00:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.012	mg/L	0.001	0.015	> 1/2 MCL
Copper	0.2	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	POT FILLER, KETTLE	Sample ID:	B2005459-012
<b>Sample Pt ID:</b>	PF03	Sample Type:	Special
PWS ID:	LA1113004	Sample Collector:	Hungerford
Water System Name:	TOWN OF DELCAMBRE WATER SYSTEM	Collection date:	10/20/2020 5:32:00AM
Facility ID:	SCH023030	Lab Submittal date:	10/20/2020 1:00:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.005	mg/L	0.001	0.015	
Copper	0.2	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	2C SINK, KITCHEN, LEFTSIDE	Sample ID:	B2005459-013
<b>Sample Pt ID:</b>	SK01	Sample Type:	Special
PWS ID:	LA1113004	Sample Collector:	Hungerford
Water System Name:	TOWN OF DELCAMBRE WATER SYSTEM	Collection date:	10/20/2020 5:32:00AM
Facility ID:	SCH023030	Lab Submittal date:	10/20/2020 1:00:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.002	mg/L	0.001	0.015	
Copper	0.3	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	3C SINK, KITCHEN, RIGHTSIDE	Sample ID:	B2005459-014
<b>Sample Pt ID:</b>	SK02	Sample Type:	Special
PWS ID:	LA1113004	Sample Collector:	Hungerford
Water System Name:	TOWN OF DELCAMBRE WATER SYSTEM	Collection date:	10/20/2020 5:33:00AM
Facility ID:	SCH023030	Lab Submittal date:	10/20/2020 1:00:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.2	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, FRONT ENT, OFFICE, LEFT	Sample ID:	B2005459-015
<b>Sample Pt ID:</b>	DF01	Sample Type:	Special
PWS ID:	LA1113004	Sample Collector:	Hungerford
Water System Name:	TOWN OF DELCAMBRE WATER SYSTEM	Collection date:	10/20/2020 5:56:00AM
Facility ID:	SCH023030	Lab Submittal date:	10/20/2020 1:00:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.5	mg/L	0.1	1.3	

**Sample Pt. Description:** TANK FOUNTAIN,, RM 306      Sample ID: B2005459-016  
**Sample Pt ID:** DF03      Sample Type: Special  
PWS ID: LA1113004      Sample Collector: Hungerford  
Water System Name: TOWN OF DELCAMBRE WATER SYSTEM      Collection date: 10/20/2020 6:12:00AM  
Facility ID: SCH023030      Lab Submittal date: 10/20/2020 1:00:00PM  
Collection Address: After Flush

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.001	mg/L	0.001	0.015	
Copper	0.5	mg/L	0.1	1.3	

**Sample Pt. Description:** TANK FOUNTAIN, RM 404      Sample ID: B2005459-017  
**Sample Pt ID:** DF04      Sample Type: Special  
PWS ID: LA1113004      Sample Collector: Hungerford  
Water System Name: TOWN OF DELCAMBRE WATER SYSTEM      Collection date: 10/20/2020 5:50:00AM  
Facility ID: SCH023030      Lab Submittal date: 10/20/2020 1:00:00PM  
Collection Address: After Flush

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.4	mg/L	0.1	1.3	

**Sample Pt. Description:** TANK FOUNTAIN, RM 702      Sample ID: B2005459-018  
**Sample Pt ID:** DF05      Sample Type: Special  
PWS ID: LA1113004      Sample Collector: Hungerford  
Water System Name: TOWN OF DELCAMBRE WATER SYSTEM      Collection date: 10/20/2020 5:49:00AM  
Facility ID: SCH023030      Lab Submittal date: 10/20/2020 1:00:00PM  
Collection Address: After Flush

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.4	mg/L	0.1	1.3	

**Sample Pt. Description:** TRI-BUBBLER, OUTSIDE CAFETERIA      Sample ID: B2005459-019  
**Sample Pt ID:** DF06      Sample Type: Special  
PWS ID: LA1113004      Sample Collector: Hungerford  
Water System Name: TOWN OF DELCAMBRE WATER SYSTEM      Collection date: 10/20/2020 5:46:00AM  
Facility ID: SCH023030      Lab Submittal date: 10/20/2020 1:00:00PM  
Collection Address: After Flush

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.002	mg/L	0.001	0.015	
Copper	0.3	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, NRR, RM 110	Sample ID:	B2005459-020
<b>Sample Pt ID:</b>	DF07	Sample Type:	Special
PWS ID:	LA1113004	Sample Collector:	Hungerford
Water System Name:	TOWN OF DELCAMBRE WATER SYSTEM	Collection date:	10/20/2020 6:07:00AM
Facility ID:	SCH023030	Lab Submittal date:	10/20/2020 1:00:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.2	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	TRI-BUBBLER, OUTSIDE, PLAYGROUND	Sample ID:	B2005459-021
<b>Sample Pt ID:</b>	DF08	Sample Type:	Special
PWS ID:	LA1113004	Sample Collector:	Hungerford
Water System Name:	TOWN OF DELCAMBRE WATER SYSTEM	Collection date:	10/20/2020 5:48:00AM
Facility ID:	SCH023030	Lab Submittal date:	10/20/2020 1:00:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.001	mg/L	0.001	0.015	
Copper	0.2	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, GIRLS RR, RIGHTSIDE	Sample ID:	B2005459-022
<b>Sample Pt ID:</b>	DF09	Sample Type:	Special
PWS ID:	LA1113004	Sample Collector:	Hungerford
Water System Name:	TOWN OF DELCAMBRE WATER SYSTEM	Collection date:	10/20/2020 5:54:00AM
Facility ID:	SCH023030	Lab Submittal date:	10/20/2020 1:00:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.6	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, BOYS RR, RIGHTSIDE	Sample ID:	B2005459-023
<b>Sample Pt ID:</b>	DF11	Sample Type:	Special
PWS ID:	LA1113004	Sample Collector:	Hungerford
Water System Name:	TOWN OF DELCAMBRE WATER SYSTEM	Collection date:	10/20/2020 6:10:00AM
Facility ID:	SCH023030	Lab Submittal date:	10/20/2020 1:00:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.001	mg/L	0.001	0.015	
Copper	0.8	mg/L	0.1	1.3	> 1/2 MCL



**Sample Pt. Description:** POT FILLER, RIGHTSIDE  
**Sample Pt ID:** PF01  
 PWS ID: LA1113004  
 Water System Name: TOWN OF DELCAMBRE WATER SYSTEM  
 Facility ID: SCH023030  
 Collection Address: After Flush

Sample ID: B2005459-024  
 Sample Type: Special  
 Sample Collector: Hungerford  
 Collection date: 10/20/2020 5:37:00AM  
 Lab Submittal date: 10/20/2020 1:00:00PM

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.2	mg/L	0.1	1.3	

**Sample Pt. Description:** POT FILLER, LEFTSIDE  
**Sample Pt ID:** PF02  
 PWS ID: LA1113004  
 Water System Name: TOWN OF DELCAMBRE WATER SYSTEM  
 Facility ID: SCH023030  
 Collection Address: After Flush

Sample ID: B2005459-025  
 Sample Type: Special  
 Sample Collector: Hungerford  
 Collection date: 10/20/2020 5:38:00AM  
 Lab Submittal date: 10/20/2020 1:00:00PM

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.2	mg/L	0.1	1.3	

**Sample Pt. Description:** POT FILLER, KETTLE  
**Sample Pt ID:** PF03  
 PWS ID: LA1113004  
 Water System Name: TOWN OF DELCAMBRE WATER SYSTEM  
 Facility ID: SCH023030  
 Collection Address: After Flush

Sample ID: B2005459-026  
 Sample Type: Special  
 Sample Collector: Hungerford  
 Collection date: 10/20/2020 5:40:00AM  
 Lab Submittal date: 10/20/2020 1:00:00PM

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.3	mg/L	0.1	1.3	

**Sample Pt. Description:** 2C SINK, KITCHEN, LEFTSIDE  
**Sample Pt ID:** SK01  
 PWS ID: LA1113004  
 Water System Name: TOWN OF DELCAMBRE WATER SYSTEM  
 Facility ID: SCH023030  
 Collection Address: After Flush

Sample ID: B2005459-027  
 Sample Type: Special  
 Sample Collector: Hungerford  
 Collection date: 10/20/2020 5:42:00AM  
 Lab Submittal date: 10/20/2020 1:00:00PM

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.2	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	3C SINK, KITCHEN, RIGHTSIDE	Sample ID:	B2005459-028
<b>Sample Pt ID:</b>	SK02	Sample Type:	Special
PWS ID:	LA1113004	Sample Collector:	Hungerford
Water System Name:	TOWN OF DELCAMBRE WATER SYSTEM	Collection date:	10/20/2020 4:54:00AM
Facility ID:	SCH023030	Lab Submittal date:	10/20/2020 1:00:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.3	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	610 MARTIN LUTHER KING DR	Sample ID:	B2005459-029
<b>Sample Pt ID:</b>	TCR-005	Sample Type:	Special
PWS ID:	LA1113004	Sample Collector:	Hungerford
Water System Name:	TOWN OF DELCAMBRE WATER SYSTEM	Collection date:	10/20/2020 6:28:00AM
Facility ID:	DS0950	Lab Submittal date:	10/20/2020 1:00:00PM
Collection Address:	Distribution		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

**Qualifier Key**

Qualifier	Description
> 1/2 MCL	Final Result > 1/2 MCL but < MCL

Reviewed by: Aaron Hawkins