



**State of Louisiana**  
Louisiana Department of Health  
Office of Public Health

September 30, 2019

Mr. Whest Shirley  
Superintendent of Schools  
Concordia Parish School Board  
4358 Hwy 84 West  
Vidalia, LA 71373

RE: Results of School Drinking Water Testing  
Ferriday Lower Elementary School (SCH015004)  
110 Bateman Drive, Ferriday, LA 71334

Dear Mr. Shirley,

Act 632 of the 2018 Regular Session required the Louisiana Department of Health (LDH) to establish a pilot program for drinking water testing at 12 public elementary schools that were constructed prior to 1986 or which may otherwise be susceptible to drinking water contamination. Thank you for your participation and cooperation in this pilot program.

On September 26, 2019 a total of 34 water samples were collected from the above referenced school in accordance with guidance provided in the Environmental Protection Agency's (EPA's) - 3Ts for Reducing Lead in Drinking Water in Schools Manual. Attached are the lead and copper sample results. Please note that the sample result for sample point ID "TCR-001" is for a sample collected from the water system.

The "first draw" sample result for drinking fountains, DF01, DF02, DF03, DF04 and DF15 exceeded the state recommended action level of 0.015 mg/L for Lead. The "flush" sample result for said drinking fountains were below the lead action level. LDH advised the school to remove said fountains from service until remediation and resampling is performed. LDH also advised the school to perform routine flushing at other fixtures that had elevated lead results (DF09, PF01) and/or exceeded the copper action level (DF06-DF09 and SK01-SK02). The remainder of sample results are below the state recommended action level of 0.015 mg/L for lead and 1.3 mg/L for copper for drinking water.

LDH recommends that all schools follow the guidance provided in the EPA-3Ts manual to safeguard against lead in the drinking water. The EPA-3Ts manual was developed to assist schools with lead in drinking water prevention programs. This guidance is intended for use by school officials responsible for the maintenance and/or safety of school's drinking water and contains lead reduction and remediation measures. This document along with other helpful information is available for on EPA's website at: <https://www.epa.gov/dwreginfo/3ts-reducing-lead-drinking-water-schools-and-child-care-facilities>.

September 30, 2019


Page 2

RE: Results of School Drinking Water Testing  
Ferriday Lower Elementary School

Please notify this office of any control or remediation measures taken by the school. LDH will perform follow up sampling to confirm that the corrective actions were effective.

Please feel free to contact me regarding any of the enclosed information.

Sincerely,



Amanda Ames, P.E.

Chief Engineer and Safe Drinking Water Administrator, LDH

Attachment

cc: Ms. Sandra Burton, Principal, Ferriday Lower Elementary School



**State of Louisiana**  
 Louisiana Department of Health  
 Public Health Laboratories  
 1209 Leesville Avenue  
 Baton Rouge, LA 70802  
 225-219-5200  
<http://www.dhh.la.gov/lab>



September 30, 2019

The following analytical results have been obtained for the indicated sample(s) which was submitted to this laboratory:

|                                |                               |                     |                     |
|--------------------------------|-------------------------------|---------------------|---------------------|
| <b>Sample Pt. Description:</b> | POT FILLER, KITCHEN           | Sample ID:          | B1904336-001        |
| <b>Sample Pt ID:</b>           | PF01                          | Sample Type:        | Special             |
| PWS ID:                        | LA1029005                     | Sample Collector:   | Bruce               |
| Water System Name:             | TOWN OF FERRIDAY WATER SYSTEM | Collection date:    | 9/26/2019 5:55:00AM |
| Facility ID:                   | SCH015004                     | Lab Submittal date: | 9/27/2019 9:40:00AM |
| Collection Address:            | First Draw                    |                     |                     |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | 0.011   | mg/L  | 0.001      | 0.015 | > 1/2 MCL  |
| Copper                         | 1.0     | mg/L  | 0.1        | 1.3   | > 1/2 MCL  |

|                                |                               |                     |                     |
|--------------------------------|-------------------------------|---------------------|---------------------|
| <b>Sample Pt. Description:</b> | 4C-SINK, LEFT FAUCET, KITCHEN | Sample ID:          | B1904336-002        |
| <b>Sample Pt ID:</b>           | SK01                          | Sample Type:        | Special             |
| PWS ID:                        | LA1029005                     | Sample Collector:   | Bruce               |
| Water System Name:             | TOWN OF FERRIDAY WATER SYSTEM | Collection date:    | 9/26/2019 5:57:00AM |
| Facility ID:                   | SCH015004                     | Lab Submittal date: | 9/27/2019 9:40:00AM |
| Collection Address:            | First Draw                    |                     |                     |

| Component Name                 | Results    | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|------------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |            |       |            |       |            |
| Lead                           | 0.006      | mg/L  | 0.001      | 0.015 |            |
| Copper                         | <b>2.2</b> | mg/L  | 0.1        | 1.3   | > MCL      |

|                                |                                |                     |                     |
|--------------------------------|--------------------------------|---------------------|---------------------|
| <b>Sample Pt. Description:</b> | 4C-SINK, RIGHT FAUCET, KITCHEN | Sample ID:          | B1904336-003        |
| <b>Sample Pt ID:</b>           | SK02                           | Sample Type:        | Special             |
| PWS ID:                        | LA1029005                      | Sample Collector:   | Bruce               |
| Water System Name:             | TOWN OF FERRIDAY WATER SYSTEM  | Collection date:    | 9/26/2019 5:58:00AM |
| Facility ID:                   | SCH015004                      | Lab Submittal date: | 9/27/2019 9:40:00AM |
| Collection Address:            | First Draw                     |                     |                     |

| Component Name                 | Results    | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|------------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |            |       |            |       |            |
| Lead                           | 0.007      | mg/L  | 0.001      | 0.015 |            |
| Copper                         | <b>1.6</b> | mg/L  | 0.1        | 1.3   | > MCL      |

|                                |                                  |                     |                     |
|--------------------------------|----------------------------------|---------------------|---------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, LOW, RT CAFETERIA | Sample ID:          | B1904336-004        |
| <b>Sample Pt ID:</b>           | DF01                             | Sample Type:        | Special             |
| PWS ID:                        | LA1029005                        | Sample Collector:   | Bruce               |
| Water System Name:             | TOWN OF FERRIDAY WATER SYSTEM    | Collection date:    | 9/26/2019 5:52:00AM |
| Facility ID:                   | SCH015004                        | Lab Submittal date: | 9/27/2019 9:40:00AM |
| Collection Address:            | First Draw                       |                     |                     |

| Component Name                 | Results      | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|--------------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |              |       |            |       |            |
| <b>Lead</b>                    | <b>0.020</b> | mg/L  | 0.001      | 0.015 | > MCL      |
| Copper                         | 0.2          | mg/L  | 0.1        | 1.3   |            |

|                                |                                   |                     |                     |
|--------------------------------|-----------------------------------|---------------------|---------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, HIGH, RT CAFETERIA | Sample ID:          | B1904336-005        |
| <b>Sample Pt ID:</b>           | DF02                              | Sample Type:        | Special             |
| PWS ID:                        | LA1029005                         | Sample Collector:   | Bruce               |
| Water System Name:             | TOWN OF FERRIDAY WATER SYSTEM     | Collection date:    | 9/26/2019 5:53:00AM |
| Facility ID:                   | SCH015004                         | Lab Submittal date: | 9/27/2019 9:40:00AM |
| Collection Address:            | First Draw                        |                     |                     |

| Component Name                 | Results      | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|--------------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |              |       |            |       |            |
| <b>Lead</b>                    | <b>0.021</b> | mg/L  | 0.001      | 0.015 | > MCL      |
| Copper                         | 0.2          | mg/L  | 0.1        | 1.3   |            |

|                                |                                  |                     |                     |
|--------------------------------|----------------------------------|---------------------|---------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, LOW, LT CAFETERIA | Sample ID:          | B1904336-006        |
| <b>Sample Pt ID:</b>           | DF03                             | Sample Type:        | Special             |
| PWS ID:                        | LA1029005                        | Sample Collector:   | Bruce               |
| Water System Name:             | TOWN OF FERRIDAY WATER SYSTEM    | Collection date:    | 9/26/2019 5:53:00AM |
| Facility ID:                   | SCH015004                        | Lab Submittal date: | 9/27/2019 9:40:00AM |
| Collection Address:            | First Draw                       |                     |                     |

| Component Name                 | Results      | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|--------------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |              |       |            |       |            |
| <b>Lead</b>                    | <b>0.075</b> | mg/L  | 0.001      | 0.015 | > MCL      |
| Copper                         | 0.9          | mg/L  | 0.1        | 1.3   | > 1/2 MCL  |

|                                |                                    |                     |                     |
|--------------------------------|------------------------------------|---------------------|---------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, HIGH, LLT CAFETERIA | Sample ID:          | B1904336-007        |
| <b>Sample Pt ID:</b>           | DF04                               | Sample Type:        | Special             |
| PWS ID:                        | LA1029005                          | Sample Collector:   | Bruce               |
| Water System Name:             | TOWN OF FERRIDAY WATER SYSTEM      | Collection date:    | 9/26/2019 5:54:00AM |
| Facility ID:                   | SCH015004                          | Lab Submittal date: | 9/27/2019 9:40:00AM |
| Collection Address:            | First Draw                         |                     |                     |

| Component Name                 | Results      | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|--------------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |              |       |            |       |            |
| <b>Lead</b>                    | <b>0.070</b> | mg/L  | 0.001      | 0.015 | > MCL      |
| Copper                         | 1.0          | mg/L  | 0.1        | 1.3   | > 1/2 MCL  |

|                                |                               |                     |                     |
|--------------------------------|-------------------------------|---------------------|---------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, 1ST GR RM2     | Sample ID:          | B1904336-008        |
| <b>Sample Pt ID:</b>           | DF05                          | Sample Type:        | Special             |
| PWS ID:                        | LA1029005                     | Sample Collector:   | Bruce               |
| Water System Name:             | TOWN OF FERRIDAY WATER SYSTEM | Collection date:    | 9/26/2019 6:28:00AM |
| Facility ID:                   | SCH015004                     | Lab Submittal date: | 9/27/2019 9:40:00AM |
| Collection Address:            | First Draw                    |                     |                     |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | 0.004   | mg/L  | 0.001      | 0.015 |            |
| Copper                         | 0.9     | mg/L  | 0.1        | 1.3   | > 1/2 MCL  |

|                                |                               |                     |                     |
|--------------------------------|-------------------------------|---------------------|---------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, 1ST GR RM6     | Sample ID:          | B1904336-009        |
| <b>Sample Pt ID:</b>           | DF06                          | Sample Type:        | Special             |
| PWS ID:                        | LA1029005                     | Sample Collector:   | Bruce               |
| Water System Name:             | TOWN OF FERRIDAY WATER SYSTEM | Collection date:    | 9/26/2019 6:29:00AM |
| Facility ID:                   | SCH015004                     | Lab Submittal date: | 9/27/2019 9:40:00AM |
| Collection Address:            | First Draw                    |                     |                     |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | <0.001  | mg/L  | 0.001      | 0.015 |            |
| Copper                         | 1.5     | mg/L  | 0.1        | 1.3   | > MCL      |

|                                |                               |                     |                     |
|--------------------------------|-------------------------------|---------------------|---------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, 1ST GR RR      | Sample ID:          | B1904336-010        |
| <b>Sample Pt ID:</b>           | DF07                          | Sample Type:        | Special             |
| PWS ID:                        | LA1029005                     | Sample Collector:   | Bruce               |
| Water System Name:             | TOWN OF FERRIDAY WATER SYSTEM | Collection date:    | 9/26/2019 6:31:00AM |
| Facility ID:                   | SCH015004                     | Lab Submittal date: | 9/27/2019 9:40:00AM |
| Collection Address:            | First Draw                    |                     |                     |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | <0.001  | mg/L  | 0.001      | 0.015 |            |
| Copper                         | 1.7     | mg/L  | 0.1        | 1.3   | > MCL      |

|                                |                               |                     |                     |
|--------------------------------|-------------------------------|---------------------|---------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, 1ST GR RM14    | Sample ID:          | B1904336-011        |
| <b>Sample Pt ID:</b>           | DF08                          | Sample Type:        | Special             |
| PWS ID:                        | LA1029005                     | Sample Collector:   | Bruce               |
| Water System Name:             | TOWN OF FERRIDAY WATER SYSTEM | Collection date:    | 9/26/2019 6:33:00AM |
| Facility ID:                   | SCH015004                     | Lab Submittal date: | 9/27/2019 9:40:00AM |
| Collection Address:            | First Draw                    |                     |                     |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | 0.001   | mg/L  | 0.001      | 0.015 |            |
| Copper                         | 1.5     | mg/L  | 0.1        | 1.3   | > MCL      |

|                                |                               |                     |                     |
|--------------------------------|-------------------------------|---------------------|---------------------|
| <b>Sample Pt. Description:</b> | BUBBLER, OUTSIDE MBLDG        | Sample ID:          | B1904336-012        |
| <b>Sample Pt ID:</b>           | DF09                          | Sample Type:        | Special             |
| PWS ID:                        | LA1029005                     | Sample Collector:   | Bruce               |
| Water System Name:             | TOWN OF FERRIDAY WATER SYSTEM | Collection date:    | 9/26/2019 7:13:00AM |
| Facility ID:                   | SCH015004                     | Lab Submittal date: | 9/27/2019 9:40:00AM |
| Collection Address:            | First Draw                    |                     |                     |

| Component Name                 | Results    | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|------------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |            |       |            |       |            |
| Lead                           | 0.014      | mg/L  | 0.001      | 0.015 | > 1/2 MCL  |
| <b>Copper</b>                  | <b>2.2</b> | mg/L  | 0.1        | 1.3   | > MCL      |

|                                |                               |                     |                     |
|--------------------------------|-------------------------------|---------------------|---------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, KINDER, RR     | Sample ID:          | B1904336-013        |
| <b>Sample Pt ID:</b>           | DF15                          | Sample Type:        | Special             |
| PWS ID:                        | LA1029005                     | Sample Collector:   | Bruce               |
| Water System Name:             | TOWN OF FERRIDAY WATER SYSTEM | Collection date:    | 9/26/2019 6:51:00AM |
| Facility ID:                   | SCH015004                     | Lab Submittal date: | 9/27/2019 9:40:00AM |
| Collection Address:            | First Draw                    |                     |                     |

| Component Name                 | Results      | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|--------------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |              |       |            |       |            |
| Lead                           | <b>0.046</b> | mg/L  | 0.001      | 0.015 | > MCL      |
| <b>Copper</b>                  | <b>3.8</b>   | mg/L  | 0.1        | 1.3   | > MCL      |

|                                |                               |                     |                     |
|--------------------------------|-------------------------------|---------------------|---------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, KINDER, RM26   | Sample ID:          | B1904336-014        |
| <b>Sample Pt ID:</b>           | DF16                          | Sample Type:        | Special             |
| PWS ID:                        | LA1029005                     | Sample Collector:   | Bruce               |
| Water System Name:             | TOWN OF FERRIDAY WATER SYSTEM | Collection date:    | 9/26/2019 6:31:00AM |
| Facility ID:                   | SCH015004                     | Lab Submittal date: | 9/27/2019 9:40:00AM |
| Collection Address:            | First Draw                    |                     |                     |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | 0.002   | mg/L  | 0.001      | 0.015 |            |
| Copper                         | 0.9     | mg/L  | 0.1        | 1.3   | > 1/2 MCL  |

|                                |                               |                     |                     |
|--------------------------------|-------------------------------|---------------------|---------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, KINDER, RM23   | Sample ID:          | B1904336-015        |
| <b>Sample Pt ID:</b>           | DF17                          | Sample Type:        | Special             |
| PWS ID:                        | LA1029005                     | Sample Collector:   | Bruce               |
| Water System Name:             | TOWN OF FERRIDAY WATER SYSTEM | Collection date:    | 9/26/2019 6:28:00AM |
| Facility ID:                   | SCH015004                     | Lab Submittal date: | 9/27/2019 9:40:00AM |
| Collection Address:            | First Draw                    |                     |                     |

| Component Name                 | Results    | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|------------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |            |       |            |       |            |
| Lead                           | 0.008      | mg/L  | 0.001      | 0.015 | > 1/2 MCL  |
| <b>Copper</b>                  | <b>3.3</b> | mg/L  | 0.1        | 1.3   | > MCL      |

**Sample Pt. Description:** POT FILLER, KITCHEN  
**Sample Pt ID:** PF01  
 PWS ID: LA1029005  
 Water System Name: TOWN OF FERRIDAY WATER SYSTEM  
 Facility ID: SCH015004  
 Collection Address: After Flush

Sample ID: B1904336-016  
 Sample Type: Special  
 Sample Collector: Bruce  
 Collection date: 9/26/2019 5:56:00AM  
 Lab Submittal date: 9/27/2019 9:40:00AM

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | 0.002   | mg/L  | 0.001      | 0.015 |            |
| Copper                         | 0.2     | mg/L  | 0.1        | 1.3   |            |

**Sample Pt. Description:** 4C-SINK, LEFT FAUCET, KITCHEN  
**Sample Pt ID:** SK01  
 PWS ID: LA1029005  
 Water System Name: TOWN OF FERRIDAY WATER SYSTEM  
 Facility ID: SCH015004  
 Collection Address: After Flush

Sample ID: B1904336-017  
 Sample Type: Special  
 Sample Collector: Bruce  
 Collection date: 9/26/2019 5:59:00AM  
 Lab Submittal date: 9/27/2019 9:40:00AM

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | <0.001  | mg/L  | 0.001      | 0.015 |            |
| Copper                         | 0.1     | mg/L  | 0.1        | 1.3   |            |

**Sample Pt. Description:** 4C-SINK, RIGHT FAUCET, KITCHEN  
**Sample Pt ID:** SK02  
 PWS ID: LA1029005  
 Water System Name: TOWN OF FERRIDAY WATER SYSTEM  
 Facility ID: SCH015004  
 Collection Address: After Flush

Sample ID: B1904336-018  
 Sample Type: Special  
 Sample Collector: Bruce  
 Collection date: 9/26/2019 5:59:00AM  
 Lab Submittal date: 9/27/2019 9:40:00AM

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | <0.001  | mg/L  | 0.001      | 0.015 |            |
| Copper                         | <0.1    | mg/L  | 0.1        | 1.3   |            |

**Sample Pt. Description:** TANK FOUNTAIN, LOW, RT CAFETERIA  
**Sample Pt ID:** DF01  
 PWS ID: LA1029005  
 Water System Name: TOWN OF FERRIDAY WATER SYSTEM  
 Facility ID: SCH015004  
 Collection Address: After Flush

Sample ID: B1904336-019  
 Sample Type: Special  
 Sample Collector: Bruce  
 Collection date: 9/26/2019 6:11:00AM  
 Lab Submittal date: 9/27/2019 9:40:00AM

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | 0.008   | mg/L  | 0.001      | 0.015 | > 1/2 MCL  |
| Copper                         | 0.8     | mg/L  | 0.1        | 1.3   | > 1/2 MCL  |

**Sample Pt. Description:** TANK FOUNTAIN, HIGH, RT CAFETERIA  
**Sample Pt ID:** DF02  
 PWS ID: LA1029005  
 Water System Name: TOWN OF FERRIDAY WATER SYSTEM  
 Facility ID: SCH015004  
 Collection Address: After Flush

Sample ID: B1904336-020  
 Sample Type: Special  
 Sample Collector: Bruce  
 Collection date: 9/26/2019 6:12:00AM  
 Lab Submittal date: 9/27/2019 9:40:00AM

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | 0.007   | mg/L  | 0.001      | 0.015 |            |
| Copper                         | 0.8     | mg/L  | 0.1        | 1.3   | > 1/2 MCL  |

**Sample Pt. Description:** TANK FOUNTAIN, LOW, LT CAFETERIA  
**Sample Pt ID:** DF03  
 PWS ID: LA1029005  
 Water System Name: TOWN OF FERRIDAY WATER SYSTEM  
 Facility ID: SCH015004  
 Collection Address: After Flush

Sample ID: B1904336-021  
 Sample Type: Special  
 Sample Collector: Bruce  
 Collection date: 9/26/2019 6:13:00AM  
 Lab Submittal date: 9/27/2019 9:40:00AM

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | 0.013   | mg/L  | 0.001      | 0.015 | > 1/2 MCL  |
| Copper                         | 0.5     | mg/L  | 0.1        | 1.3   |            |

**Sample Pt. Description:** TANK FOUNTAIN, HIGH, LLT CAFETERIA  
**Sample Pt ID:** DF04  
 PWS ID: LA1029005  
 Water System Name: TOWN OF FERRIDAY WATER SYSTEM  
 Facility ID: SCH015004  
 Collection Address: After Flush

Sample ID: B1904336-022  
 Sample Type: Special  
 Sample Collector: Bruce  
 Collection date: 9/26/2019 6:15:00AM  
 Lab Submittal date: 9/27/2019 9:40:00AM

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | 0.007   | mg/L  | 0.001      | 0.015 |            |
| Copper                         | 0.4     | mg/L  | 0.1        | 1.3   |            |

**Sample Pt. Description:** TANK FOUNTAIN, 1ST GR RM2  
**Sample Pt ID:** DF05  
 PWS ID: LA1029005  
 Water System Name: TOWN OF FERRIDAY WATER SYSTEM  
 Facility ID: SCH015004  
 Collection Address: After Flush

Sample ID: B1904336-023  
 Sample Type: Special  
 Sample Collector: Bruce  
 Collection date: 9/26/2019 6:48:00AM  
 Lab Submittal date: 9/27/2019 9:40:00AM

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | 0.002   | mg/L  | 0.001      | 0.015 |            |
| Copper                         | 0.3     | mg/L  | 0.1        | 1.3   |            |



|                                |                               |                     |                     |
|--------------------------------|-------------------------------|---------------------|---------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, 1ST GR RM6     | Sample ID:          | B1904336-024        |
| <b>Sample Pt ID:</b>           | DF06                          | Sample Type:        | Special             |
| PWS ID:                        | LA1029005                     | Sample Collector:   | Bruce               |
| Water System Name:             | TOWN OF FERRIDAY WATER SYSTEM | Collection date:    | 9/26/2019 7:04:00AM |
| Facility ID:                   | SCH015004                     | Lab Submittal date: | 9/27/2019 9:40:00AM |
| Collection Address:            | After Flush                   |                     |                     |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | <0.001  | mg/L  | 0.001      | 0.015 |            |
| Copper                         | 0.3     | mg/L  | 0.1        | 1.3   |            |

|                                |                               |                     |                     |
|--------------------------------|-------------------------------|---------------------|---------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, 1ST GR RR      | Sample ID:          | B1904336-025        |
| <b>Sample Pt ID:</b>           | DF07                          | Sample Type:        | Special             |
| PWS ID:                        | LA1029005                     | Sample Collector:   | Bruce               |
| Water System Name:             | TOWN OF FERRIDAY WATER SYSTEM | Collection date:    | 9/26/2019 7:07:00AM |
| Facility ID:                   | SCH015004                     | Lab Submittal date: | 9/27/2019 9:40:00AM |
| Collection Address:            | After Flush                   |                     |                     |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | 0.001   | mg/L  | 0.001      | 0.015 |            |
| Copper                         | 0.6     | mg/L  | 0.1        | 1.3   |            |

|                                |                               |                     |                     |
|--------------------------------|-------------------------------|---------------------|---------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, 1ST GR RM14    | Sample ID:          | B1904336-026        |
| <b>Sample Pt ID:</b>           | DF08                          | Sample Type:        | Special             |
| PWS ID:                        | LA1029005                     | Sample Collector:   | Bruce               |
| Water System Name:             | TOWN OF FERRIDAY WATER SYSTEM | Collection date:    | 9/26/2019 6:49:00AM |
| Facility ID:                   | SCH015004                     | Lab Submittal date: | 9/27/2019 9:40:00AM |
| Collection Address:            | After Flush                   |                     |                     |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | 0.001   | mg/L  | 0.001      | 0.015 |            |
| Copper                         | 0.3     | mg/L  | 0.1        | 1.3   |            |

|                                |                               |                     |                     |
|--------------------------------|-------------------------------|---------------------|---------------------|
| <b>Sample Pt. Description:</b> | BUBBLER, OUTSIDE MBLDG        | Sample ID:          | B1904336-027        |
| <b>Sample Pt ID:</b>           | DF09                          | Sample Type:        | Special             |
| PWS ID:                        | LA1029005                     | Sample Collector:   | Bruce               |
| Water System Name:             | TOWN OF FERRIDAY WATER SYSTEM | Collection date:    | 9/26/2019 7:14:00AM |
| Facility ID:                   | SCH015004                     | Lab Submittal date: | 9/27/2019 9:40:00AM |
| Collection Address:            | After Flush                   |                     |                     |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | 0.004   | mg/L  | 0.001      | 0.015 |            |
| Copper                         | 3.1     | mg/L  | 0.1        | 1.3   | > MCL      |

|                                |                               |                     |                     |
|--------------------------------|-------------------------------|---------------------|---------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, KINDER, RR     | Sample ID:          | B1904336-028        |
| <b>Sample Pt ID:</b>           | DF15                          | Sample Type:        | Special             |
| PWS ID:                        | LA1029005                     | Sample Collector:   | Bruce               |
| Water System Name:             | TOWN OF FERRIDAY WATER SYSTEM | Collection date:    | 9/26/2019 7:07:00AM |
| Facility ID:                   | SCH015004                     | Lab Submittal date: | 9/27/2019 9:40:00AM |
| Collection Address:            | After Flush                   |                     |                     |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | 0.002   | mg/L  | 0.001      | 0.015 |            |
| Copper                         | 0.5     | mg/L  | 0.1        | 1.3   |            |

|                                |                               |                     |                     |
|--------------------------------|-------------------------------|---------------------|---------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, KINDER, RM26   | Sample ID:          | B1904336-029        |
| <b>Sample Pt ID:</b>           | DF16                          | Sample Type:        | Special             |
| PWS ID:                        | LA1029005                     | Sample Collector:   | Bruce               |
| Water System Name:             | TOWN OF FERRIDAY WATER SYSTEM | Collection date:    | 9/26/2019 6:53:00AM |
| Facility ID:                   | SCH015004                     | Lab Submittal date: | 9/27/2019 9:40:00AM |
| Collection Address:            | After Flush                   |                     |                     |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | 0.001   | mg/L  | 0.001      | 0.015 |            |
| Copper                         | 0.4     | mg/L  | 0.1        | 1.3   |            |

|                                |                               |                     |                     |
|--------------------------------|-------------------------------|---------------------|---------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, KINDER, RM23   | Sample ID:          | B1904336-030        |
| <b>Sample Pt ID:</b>           | DF17                          | Sample Type:        | Special             |
| PWS ID:                        | LA1029005                     | Sample Collector:   | Bruce               |
| Water System Name:             | TOWN OF FERRIDAY WATER SYSTEM | Collection date:    | 9/26/2019 6:48:00AM |
| Facility ID:                   | SCH015004                     | Lab Submittal date: | 9/27/2019 9:40:00AM |
| Collection Address:            | After Flush                   |                     |                     |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | 0.002   | mg/L  | 0.001      | 0.015 |            |
| Copper                         | 0.4     | mg/L  | 0.1        | 1.3   |            |

|                                |                               |                     |                     |
|--------------------------------|-------------------------------|---------------------|---------------------|
| <b>Sample Pt. Description:</b> | 1101 EE WALLACE BLVD. N.      | Sample ID:          | B1904336-031        |
| <b>Sample Pt ID:</b>           | TCR-001                       | Sample Type:        | Special             |
| PWS ID:                        | LA1029005                     | Sample Collector:   | Bruce               |
| Water System Name:             | TOWN OF FERRIDAY WATER SYSTEM | Collection date:    | 9/27/2019 7:35:00AM |
| Facility ID:                   | DS0950                        | Lab Submittal date: | 9/27/2019 9:40:00AM |
| Collection Address:            | Distribution System           |                     |                     |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | <0.001  | mg/L  | 0.001      | 0.015 |            |
| Copper                         | <0.1    | mg/L  | 0.1        | 1.3   |            |

**Qualifier Key**

| <u>Qualifier</u> | <u>Description</u>               |
|------------------|----------------------------------|
| > 1/2 MCL        | Final Result > 1/2 MCL but < MCL |
| > MCL            | Final Result Above MCL           |

Reviewed by: Aaron Hawkins