



**State of Louisiana**  
Louisiana Department of Health  
Office of Public Health

October 29, 2020

Mr. Joe Murphy  
Superintendent of Schools  
Livingston Parish School Board  
P.O. Box 1130  
Livingston, LA 70754-1130

RE: Results of School Drinking Water Testing  
Frost Elementary School (SCH032011)  
19672 LA Highway 42, Livingston, LA 70754

Dear Mr. Murphy,

Act 632 of the 2018 Regular Session required the Louisiana Department of Health (LDH) to establish a pilot program for drinking water testing at 12 public elementary schools that were constructed prior to 1986 or which may otherwise be susceptible to drinking water contamination. Thank you for your participation and cooperation in this pilot program.

On October 22 and 27, 2020 a total of 22 water samples were collected from the above referenced school in accordance with guidance provided in the Environmental Protection Agency's (EPA's) - 3Ts for Reducing Lead in Drinking Water in Schools Manual. Attached are the lead and copper sample results. Please note that the sample result for sample point ID "TCR-007" is for a sample collected from the water system.

All sample results were evaluated against the state recommended Action Levels for Lead (0.015 mg/L) and Copper (1.3 mg/L) for drinking water. All sample results are below the state recommended Action Levels for Lead and Copper.

Although these results indicate no exceedance of the lead action level (0.015 mg/L) in the school drinking water, LDH recommends that all schools follow the guidance provided in the EPA-3Ts manual to safeguard against lead in the drinking water. The EPA-3Ts manual was developed to assist schools with lead in drinking water prevention programs. This guidance is intended for use by school officials responsible for the maintenance and/or safety of school's drinking water. This document along with other helpful information is available for on EPA's website at: <https://www.epa.gov/dwreginfo/3ts-reducing-lead-drinking-water-schools-and-child-care-facilities>.

October 29, 2020

Page 2

RE: Results of School Drinking Water Testing  
Frost Elementary School (SCH032011)

Please notify this office of any control or remediation measures taken by the school. LDH will perform follow up sampling to confirm the corrective actions were effective.

Please feel free to contact me or Caryn Benjamin regarding any of the enclosed information.

Sincerely,



Amanda Ames, P.E.  
Chief Engineer and Safe Drinking Water Administrator, LDH

Attachments

cc: Ms. Stacey Wise, Principal, Frost Elementary School

Sample Results Summary

| Frost Elementary School (SCH032011)   |      | Lead (mg/L)       |                    | Copper (mg/L)     |                    |
|---|------|-------------------|--------------------|-------------------|--------------------|
|   |      | AL = 0.015 mg/L   |                    | AL = 1.3 mg/L     |                    |
| Sample Point Description and ID   |      | First Draw Sample | After Flush Sample | First Draw Sample | After Flush Sample |
| TANK FOUNTAIN, RM 207 LEFT SIDE, HALSEY TAYLOR  | DF01 | ND                | ND                 | ND                | ND                 |
| TANK FOUNTAIN, GYM ENT, LEFT SIDE, ELKAY  | DF03 | ND                | ND                 | 0.2 mg/L          | ND                 |
| TANK FOUNTAIN, GYM ENT, MIDDLE, OASIS   | DF04 | ND                | ND                 | ND                | ND                 |
| TANK FOUNTAIN, GYM, GIRLS AWAY, ELKAY   | DF09 | ND                | ND                 | 0.1 mg/L          | ND                 |
| TANK FOUNTAIN, GIRLS RR, RM 401, HALSEY TAYLOR  | DF10 | 0.002 mg/L        | ND                 | ND                | ND                 |
| TANK FOUNTAIN, GIRLS RR, RM 304, ELKAY  | DF11 | ND                | ND                 | ND                | ND                 |
| TANK FOUNTAIN, RM 802, OASIS  | DF12 | ND                | ND                 | 0.2 mg/L          | ND                 |
| TANK FOUNTAIN, OUTSIDE RM 805, RIGHT, OASIS   | DF13 | ND                | ND                 | 0.9 mg/L          | ND                 |
| TANK FOUNTAIN, RM 901, ELKAY  | DF15 | 0.002 mg/L        | ND                 | 0.2 mg/L          | ND                 |
| POT FILLER, FLEXIBLE SILVER HOSE  | PF01 | ND                | ND                 | ND                | ND                 |
| 3C SINK, KITCHEN, MAIN WALL   | SK01 | ND                | ND                 | ND                | ND                 |
| "ND" - None Detect - contaminant level is below the Laboratory Reporting Limit (<0.001 mg/L Lead or <0.1 mg/L Copper) |      |                   |                    |                   |                    |
| "AL" - Action Level - state recommended action level  |      |                   |                    |                   |                    |



State of Louisiana  
Louisiana Department of Health  
Public Health Laboratories  
1209 Leesville Avenue  
Baton Rouge, LA 70802  
225-219-5200  
<http://www.dhh.la.gov/lab>



**Amended**

October 26, 2020

The following analytical results have been obtained for the indicated sample(s) which was submitted to this laboratory:

|                                |                                 |                     |                       |
|--------------------------------|---------------------------------|---------------------|-----------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, RM 207 LEFT SIDE | Sample ID:          | B2005521-001          |
| <b>Sample Pt ID:</b>           | DF01                            | Sample Type:        | Special               |
| <b>PWS ID:</b>                 | LA1063003                       | Sample Collector:   | Farlow                |
| <b>Water System Name:</b>      | COLYELL COMMUNITY WATER         | Collection date:    | 10/22/2020 6:05:00AM  |
| <b>Facility ID:</b>            | SCH032011                       | Lab Submittal date: | 10/22/2020 10:15:00AM |
| <b>Collection Address:</b>     | First Draw                      |                     |                       |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | <0.001  | mg/L  | 0.001      | 0.015 |            |
| Copper                         | <0.1    | mg/L  | 0.1        | 1.3   |            |

Folder Comments:

Amended Report Reason:

Engineering requested POCID corrections

|                                |                                   |                     |                       |
|--------------------------------|-----------------------------------|---------------------|-----------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, GYM ENT, LEFT SIDE | Sample ID:          | B2005521-002          |
| <b>Sample Pt ID:</b>           | DF03                              | Sample Type:        | Special               |
| <b>PWS ID:</b>                 | LA1063003                         | Sample Collector:   | Farlow                |
| <b>Water System Name:</b>      | COLYELL COMMUNITY WATER           | Collection date:    | 10/22/2020 6:20:00AM  |
| <b>Facility ID:</b>            | SCH032011                         | Lab Submittal date: | 10/22/2020 10:15:00AM |
| <b>Collection Address:</b>     | First Draw                        |                     |                       |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | <0.001  | mg/L  | 0.001      | 0.015 |            |
| Copper                         | 0.2     | mg/L  | 0.1        | 1.3   |            |

Folder Comments:

Amended Report Reason:

Engineering requested POCID corrections

|                                |                                |                     |                       |
|--------------------------------|--------------------------------|---------------------|-----------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, GYM, GIRLS AWAY | Sample ID:          | B2005521-003          |
| <b>Sample Pt ID:</b>           | DF09                           | Sample Type:        | Special               |
| PWS ID:                        | LA1063003                      | Sample Collector:   | Farlow                |
| Water System Name:             | COLYELL COMMUNITY WATER        | Collection date:    | 10/22/2020 6:09:00AM  |
| Facility ID:                   | SCH032011                      | Lab Submittal date: | 10/22/2020 10:15:00AM |
| Collection Address:            | First Draw                     |                     |                       |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | <0.001  | mg/L  | 0.001      | 0.015 |            |
| Copper                         | 0.1     | mg/L  | 0.1        | 1.3   |            |

Folder Comments:  
Amended Report Reason:  
Engineering requested POCID corrections

|                                |                                 |                     |                       |
|--------------------------------|---------------------------------|---------------------|-----------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, GIRLS RR, RM 401 | Sample ID:          | B2005521-004          |
| <b>Sample Pt ID:</b>           | DF10                            | Sample Type:        | Special               |
| PWS ID:                        | LA1063003                       | Sample Collector:   | Farlow                |
| Water System Name:             | COLYELL COMMUNITY WATER         | Collection date:    | 10/22/2020 6:01:00AM  |
| Facility ID:                   | SCH032011                       | Lab Submittal date: | 10/22/2020 10:15:00AM |
| Collection Address:            | First Draw                      |                     |                       |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | 0.002   | mg/L  | 0.001      | 0.015 |            |
| Copper                         | <0.1    | mg/L  | 0.1        | 1.3   |            |

Folder Comments:  
Amended Report Reason:  
Engineering requested POCID corrections

|                                |                                      |                     |                       |
|--------------------------------|--------------------------------------|---------------------|-----------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, OUTSIDE RM 805, RIGHT | Sample ID:          | B2005521-005          |
| <b>Sample Pt ID:</b>           | DF13                                 | Sample Type:        | Special               |
| PWS ID:                        | LA1063003                            | Sample Collector:   | Farlow                |
| Water System Name:             | COLYELL COMMUNITY WATER              | Collection date:    | 10/22/2020 5:54:00AM  |
| Facility ID:                   | SCH032011                            | Lab Submittal date: | 10/22/2020 10:15:00AM |
| Collection Address:            | First Draw                           |                     |                       |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | <0.001  | mg/L  | 0.001      | 0.015 |            |
| Copper                         | 0.9     | mg/L  | 0.1        | 1.3   | > 1/2 MCL  |

Folder Comments:  
Amended Report Reason:  
Engineering requested POCID corrections

|                                |                                 |                     |                       |
|--------------------------------|---------------------------------|---------------------|-----------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, GIRLS RR, RM 304 | Sample ID:          | B2005521-006          |
| <b>Sample Pt ID:</b>           | DF11                            | Sample Type:        | Special               |
| PWS ID:                        | LA1063003                       | Sample Collector:   | Farlow                |
| Water System Name:             | COLYELL COMMUNITY WATER         | Collection date:    | 10/22/2020 6:14:00AM  |
| Facility ID:                   | SCH032011                       | Lab Submittal date: | 10/22/2020 10:15:00AM |
| Collection Address:            | First Draw                      |                     |                       |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | <0.001  | mg/L  | 0.001      | 0.015 |            |
| Copper                         | <0.1    | mg/L  | 0.1        | 1.3   |            |

Folder Comments:  
Amended Report Reason:  
Engineering requested POCID corrections

|                                |                         |                     |                       |
|--------------------------------|-------------------------|---------------------|-----------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, RM 802   | Sample ID:          | B2005521-007          |
| <b>Sample Pt ID:</b>           | DF12                    | Sample Type:        | Special               |
| PWS ID:                        | LA1063003               | Sample Collector:   | Farlow                |
| Water System Name:             | COLYELL COMMUNITY WATER | Collection date:    | 10/22/2020 6:17:00AM  |
| Facility ID:                   | SCH032011               | Lab Submittal date: | 10/22/2020 10:15:00AM |
| Collection Address:            | First Draw              |                     |                       |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | <0.001  | mg/L  | 0.001      | 0.015 |            |
| Copper                         | 0.2     | mg/L  | 0.1        | 1.3   |            |

Folder Comments:  
Amended Report Reason:  
Engineering requested POCID corrections

|                                |                         |                     |                       |
|--------------------------------|-------------------------|---------------------|-----------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, RM 901   | Sample ID:          | B2005521-008          |
| <b>Sample Pt ID:</b>           | DF15                    | Sample Type:        | Special               |
| PWS ID:                        | LA1063003               | Sample Collector:   | Farlow                |
| Water System Name:             | COLYELL COMMUNITY WATER | Collection date:    | 10/22/2020 6:20:00AM  |
| Facility ID:                   | SCH032011               | Lab Submittal date: | 10/22/2020 10:15:00AM |
| Collection Address:            | First Draw              |                     |                       |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | 0.002   | mg/L  | 0.001      | 0.015 |            |
| Copper                         | 0.2     | mg/L  | 0.1        | 1.3   |            |

Folder Comments:  
Amended Report Reason:  
Engineering requested POCID corrections

|                                |                                  |                     |                       |
|--------------------------------|----------------------------------|---------------------|-----------------------|
| <b>Sample Pt. Description:</b> | POT FILLER, FLEXIBLE SILVER HOSE | Sample ID:          | B2005521-009          |
| <b>Sample Pt ID:</b>           | PF01                             | Sample Type:        | Special               |
| PWS ID:                        | LA1063003                        | Sample Collector:   | Farlow                |
| Water System Name:             | COLYELL COMMUNITY WATER          | Collection date:    | 10/22/2020 5:30:00AM  |
| Facility ID:                   | SCH032011                        | Lab Submittal date: | 10/22/2020 10:15:00AM |
| Collection Address:            | First Draw                       |                     |                       |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | <0.001  | mg/L  | 0.001      | 0.015 |            |
| Copper                         | <0.1    | mg/L  | 0.1        | 1.3   |            |

Folder Comments:  
Amended Report Reason:  
Engineering requested POCID corrections

|                                |                             |                     |                       |
|--------------------------------|-----------------------------|---------------------|-----------------------|
| <b>Sample Pt. Description:</b> | 3C SINK, KITCHEN, MAIN WALL | Sample ID:          | B2005521-010          |
| <b>Sample Pt ID:</b>           | SK01                        | Sample Type:        | Special               |
| PWS ID:                        | LA1063003                   | Sample Collector:   | Farlow                |
| Water System Name:             | COLYELL COMMUNITY WATER     | Collection date:    | 10/22/2020 5:32:00AM  |
| Facility ID:                   | SCH032011                   | Lab Submittal date: | 10/22/2020 10:15:00AM |
| Collection Address:            | First Draw                  |                     |                       |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | <0.001  | mg/L  | 0.001      | 0.015 |            |
| Copper                         | <0.1    | mg/L  | 0.1        | 1.3   |            |

Folder Comments:  
Amended Report Reason:  
Engineering requested POCID corrections

|                                |                                 |                     |                       |
|--------------------------------|---------------------------------|---------------------|-----------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, RM 207 LEFT SIDE | Sample ID:          | B2005521-011          |
| <b>Sample Pt ID:</b>           | DF01                            | Sample Type:        | Special               |
| PWS ID:                        | LA1063003                       | Sample Collector:   | Farlow                |
| Water System Name:             | COLYELL COMMUNITY WATER         | Collection date:    | 10/22/2020 7:11:00AM  |
| Facility ID:                   | SCH032011                       | Lab Submittal date: | 10/22/2020 10:15:00AM |
| Collection Address:            | After Flush                     |                     |                       |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | <0.001  | mg/L  | 0.001      | 0.015 |            |
| Copper                         | <0.1    | mg/L  | 0.1        | 1.3   |            |

Folder Comments:  
Amended Report Reason:  
Engineering requested POCID corrections

|                                |                                   |                     |                       |
|--------------------------------|-----------------------------------|---------------------|-----------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, GYM ENT, LEFT SIDE | Sample ID:          | B2005521-012          |
| <b>Sample Pt ID:</b>           | DF03                              | Sample Type:        | Special               |
| PWS ID:                        | LA1063003                         | Sample Collector:   | Farlow                |
| Water System Name:             | COLYELL COMMUNITY WATER           | Collection date:    | 10/22/2020 6:47:00AM  |
| Facility ID:                   | SCH032011                         | Lab Submittal date: | 10/22/2020 10:15:00AM |
| Collection Address:            | After Flush                       |                     |                       |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | <0.001  | mg/L  | 0.001      | 0.015 |            |
| Copper                         | <0.1    | mg/L  | 0.1        | 1.3   |            |

Folder Comments:  
Amended Report Reason:  
Engineering requested POCID corrections

|                                |                                |                     |                       |
|--------------------------------|--------------------------------|---------------------|-----------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, GYM, GIRLS AWAY | Sample ID:          | B2005521-013          |
| <b>Sample Pt ID:</b>           | DF09                           | Sample Type:        | Special               |
| PWS ID:                        | LA1063003                      | Sample Collector:   | Farlow                |
| Water System Name:             | COLYELL COMMUNITY WATER        | Collection date:    | 10/22/2020 6:52:00AM  |
| Facility ID:                   | SCH032011                      | Lab Submittal date: | 10/22/2020 10:15:00AM |
| Collection Address:            | After Flush                    |                     |                       |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | <0.001  | mg/L  | 0.001      | 0.015 |            |
| Copper                         | <0.1    | mg/L  | 0.1        | 1.3   |            |

Folder Comments:  
Amended Report Reason:  
Engineering requested POCID corrections

|                                |                                 |                     |                       |
|--------------------------------|---------------------------------|---------------------|-----------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, GIRLS RR, RM 401 | Sample ID:          | B2005521-014          |
| <b>Sample Pt ID:</b>           | DF10                            | Sample Type:        | Special               |
| PWS ID:                        | LA1063003                       | Sample Collector:   | Farlow                |
| Water System Name:             | COLYELL COMMUNITY WATER         | Collection date:    | 10/22/2020 6:16:00AM  |
| Facility ID:                   | SCH032011                       | Lab Submittal date: | 10/22/2020 10:15:00AM |
| Collection Address:            | After Flush                     |                     |                       |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | <0.001  | mg/L  | 0.001      | 0.015 |            |
| Copper                         | <0.1    | mg/L  | 0.1        | 1.3   |            |

Folder Comments:  
Amended Report Reason:  
Engineering requested POCID corrections

|                                |                                      |                     |                       |
|--------------------------------|--------------------------------------|---------------------|-----------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, OUTSIDE RM 805, RIGHT | Sample ID:          | B2005521-015          |
| <b>Sample Pt ID:</b>           | DF13                                 | Sample Type:        | Special               |
| PWS ID:                        | LA1063003                            | Sample Collector:   | Farlow                |
| Water System Name:             | COLYELL COMMUNITY WATER              | Collection date:    | 10/22/2020 6:00:00AM  |
| Facility ID:                   | SCH032011                            | Lab Submittal date: | 10/22/2020 10:15:00AM |
| Collection Address:            | After Flush                          |                     |                       |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | <0.001  | mg/L  | 0.001      | 0.015 |            |
| Copper                         | <0.1    | mg/L  | 0.1        | 1.3   |            |

Folder Comments:  
Amended Report Reason:  
Engineering requested POCID corrections

|                                |                                 |                     |                       |
|--------------------------------|---------------------------------|---------------------|-----------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, GIRLS RR, RM 304 | Sample ID:          | B2005521-016          |
| <b>Sample Pt ID:</b>           | DF11                            | Sample Type:        | Special               |
| PWS ID:                        | LA1063003                       | Sample Collector:   | Farlow                |
| Water System Name:             | COLYELL COMMUNITY WATER         | Collection date:    | 10/22/2020 6:29:00AM  |
| Facility ID:                   | SCH032011                       | Lab Submittal date: | 10/22/2020 10:15:00AM |
| Collection Address:            | After Flush                     |                     |                       |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | <0.001  | mg/L  | 0.001      | 0.015 |            |
| Copper                         | <0.1    | mg/L  | 0.1        | 1.3   |            |

Folder Comments:  
Amended Report Reason:  
Engineering requested POCID corrections

|                                |                         |                     |                       |
|--------------------------------|-------------------------|---------------------|-----------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, RM 802   | Sample ID:          | B2005521-017          |
| <b>Sample Pt ID:</b>           | DF12                    | Sample Type:        | Special               |
| PWS ID:                        | LA1063003               | Sample Collector:   | Farlow                |
| Water System Name:             | COLYELL COMMUNITY WATER | Collection date:    | 10/22/2020 6:32:00AM  |
| Facility ID:                   | SCH032011               | Lab Submittal date: | 10/22/2020 10:15:00AM |
| Collection Address:            | After Flush             |                     |                       |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | <0.001  | mg/L  | 0.001      | 0.015 |            |
| Copper                         | <0.1    | mg/L  | 0.1        | 1.3   |            |

Folder Comments:  
Amended Report Reason:  
Engineering requested POCID corrections



|                                |                         |                     |                       |
|--------------------------------|-------------------------|---------------------|-----------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, RM 901   | Sample ID:          | B2005521-018          |
| <b>Sample Pt ID:</b>           | DF15                    | Sample Type:        | Special               |
| PWS ID:                        | LA1063003               | Sample Collector:   | Farlow                |
| Water System Name:             | COLYELL COMMUNITY WATER | Collection date:    | 10/22/2020 7:30:00AM  |
| Facility ID:                   | SCH032011               | Lab Submittal date: | 10/22/2020 10:15:00AM |
| Collection Address:            | After Flush             |                     |                       |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | <0.001  | mg/L  | 0.001      | 0.015 |            |
| Copper                         | <0.1    | mg/L  | 0.1        | 1.3   |            |

Folder Comments:  
Amended Report Reason:  
Engineering requested POCID corrections

|                                |                                  |                     |                       |
|--------------------------------|----------------------------------|---------------------|-----------------------|
| <b>Sample Pt. Description:</b> | POT FILLER, FLEXIBLE SILVER HOSE | Sample ID:          | B2005521-019          |
| <b>Sample Pt ID:</b>           | PF01                             | Sample Type:        | Special               |
| PWS ID:                        | LA1063003                        | Sample Collector:   | Farlow                |
| Water System Name:             | COLYELL COMMUNITY WATER          | Collection date:    | 10/22/2020 5:48:00AM  |
| Facility ID:                   | SCH032011                        | Lab Submittal date: | 10/22/2020 10:15:00AM |
| Collection Address:            | After Flush                      |                     |                       |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | <0.001  | mg/L  | 0.001      | 0.015 |            |
| Copper                         | <0.1    | mg/L  | 0.1        | 1.3   |            |

Folder Comments:  
Amended Report Reason:  
Engineering requested POCID corrections

|                                |                             |                     |                       |
|--------------------------------|-----------------------------|---------------------|-----------------------|
| <b>Sample Pt. Description:</b> | 3C SINK, KITCHEN, MAIN WALL | Sample ID:          | B2005521-020          |
| <b>Sample Pt ID:</b>           | SK01                        | Sample Type:        | Special               |
| PWS ID:                        | LA1063003                   | Sample Collector:   | Farlow                |
| Water System Name:             | COLYELL COMMUNITY WATER     | Collection date:    | 10/22/2020 5:48:00AM  |
| Facility ID:                   | SCH032011                   | Lab Submittal date: | 10/22/2020 10:15:00AM |
| Collection Address:            | After Flush                 |                     |                       |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | <0.001  | mg/L  | 0.001      | 0.015 |            |
| Copper                         | <0.1    | mg/L  | 0.1        | 1.3   |            |

Folder Comments:  
Amended Report Reason:  
Engineering requested POCID corrections

|                                |                         |                     |                       |
|--------------------------------|-------------------------|---------------------|-----------------------|
| <b>Sample Pt. Description:</b> | 19123 LA 42             | Sample ID:          | B2005521-021          |
| <b>Sample Pt ID:</b>           | TCR-007                 | Sample Type:        | Special               |
| PWS ID:                        | LA1063003               | Sample Collector:   | Farlow                |
| Water System Name:             | COLYELL COMMUNITY WATER | Collection date:    | 10/22/2020 7:50:00AM  |
| Facility ID:                   | DS0950                  | Lab Submittal date: | 10/22/2020 10:15:00AM |
| Collection Address:            | Distribution            |                     |                       |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | <0.001  | mg/L  | 0.001      | 0.015 |            |
| Copper                         | <0.1    | mg/L  | 0.1        | 1.3   |            |

Folder Comments:  
Amended Report Reason:  
Engineering requested POCID corrections

**Qualifier Key**

| Qualifier | Description                      |
|-----------|----------------------------------|
| > 1/2 MCL | Final Result > 1/2 MCL but < MCL |

Reviewed by: Aaron Hawkins



State of Louisiana  
Louisiana Department of Health  
Public Health Laboratories  
1209 Leesville Avenue  
Baton Rouge, LA 70802  
225-219-5200  
<http://www.dhh.la.gov/lab>



October 29, 2020

The following analytical results have been obtained for the indicated sample(s) which was submitted to this laboratory:

|                                |                                |                            |                      |
|--------------------------------|--------------------------------|----------------------------|----------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, GYM ENT, MIDDLE | <b>Sample ID:</b>          | B2005649-001         |
| <b>Sample Pt ID:</b>           | DF04                           | <b>Sample Type:</b>        | Special              |
| <b>PWS ID:</b>                 | LA1063003                      | <b>Sample Collector:</b>   | Ramer                |
| <b>Water System Name:</b>      | COLYELL COMMUNITY WATER        | <b>Collection date:</b>    | 10/27/2020 7:46:00AM |
| <b>Facility ID:</b>            | SCH032011                      | <b>Lab Submittal date:</b> | 10/27/2020 8:55:00AM |
| <b>Collection Address:</b>     | First Draw                     |                            |                      |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | <0.001  | mg/L  | 0.001      | 0.015 |            |
| Copper                         | <0.1    | mg/L  | 0.1        | 1.3   |            |

|                                |                                |                            |                      |
|--------------------------------|--------------------------------|----------------------------|----------------------|
| <b>Sample Pt. Description:</b> | TANK FOUNTAIN, GYM ENT, MIDDLE | <b>Sample ID:</b>          | B2005649-002         |
| <b>Sample Pt ID:</b>           | DF04                           | <b>Sample Type:</b>        | Special              |
| <b>PWS ID:</b>                 | LA1063003                      | <b>Sample Collector:</b>   | Ramer                |
| <b>Water System Name:</b>      | COLYELL COMMUNITY WATER        | <b>Collection date:</b>    | 10/27/2020 8:02:00AM |
| <b>Facility ID:</b>            | SCH032011                      | <b>Lab Submittal date:</b> | 10/27/2020 8:55:00AM |
| <b>Collection Address:</b>     | After Flush                    |                            |                      |

| Component Name                 | Results | Units | Rep. Limit | MCL   | Qualifiers |
|--------------------------------|---------|-------|------------|-------|------------|
| <b>Lead and Copper (200.8)</b> |         |       |            |       |            |
| Lead                           | <0.001  | mg/L  | 0.001      | 0.015 |            |
| Copper                         | <0.1    | mg/L  | 0.1        | 1.3   |            |

Reviewed by: Aaron Hawkins