



**State of Louisiana**  
Louisiana Department of Health  
Office of Public Health

October 26, 2020

Mrs. Lynette Hookfin  
Superintendent of Schools  
St. John Parish School Board  
118 West 10<sup>th</sup> Street  
Reserve, LA 70084

RE: Results of School Drinking Water Testing  
John L. Ory Communications Magnet Elementary School (SCH048024)  
182 West Fifth Street, LaPlace, LA 70068

Dear Mrs. Hookfin,

Act 632 of the 2018 Regular Session required the Louisiana Department of Health (LDH) to establish a pilot program for drinking water testing at 12 public elementary schools that were constructed prior to 1986 or which may otherwise be susceptible to drinking water contamination. Thank you for your participation and cooperation in this pilot program.

On October 21, 2020 a total of 23 water samples were collected from the above referenced school in accordance with guidance provided in the Environmental Protection Agency's (EPA's) - 3Ts for Reducing Lead in Drinking Water in Schools Manual. Attached are the lead and copper sample results. Please note that the sample result for sample point ID "TCR-005" is for a sample collected from the water system.

All sample results were evaluated against the state recommended Action Levels for Lead (0.015 mg/L) and Copper (1.3 mg/L) for drinking water. All sample results are below the state recommended Action Levels for Lead and Copper.

Although these results indicate no exceedance of the lead action level (0.015 mg/L) in the school drinking water, LDH recommends that all schools follow the guidance provided in the EPA-3Ts manual to safeguard against lead in the drinking water. The EPA-3Ts manual was developed to assist schools with lead in drinking water prevention programs. This guidance is intended for use by school officials responsible for the maintenance and/or safety of school's drinking water. This document along with other helpful information is available for on EPA's website at: <https://www.epa.gov/dwreginfo/3ts-reducing-lead-drinking-water-schools-and-child-care-facilities>.

Please notify this office of any control or remediation measures taken by the school. LDH will perform follow up sampling to confirm the corrective actions were effective.

October 26, 2020

Page 2

RE: Results of School Drinking Water Testing  
John L. Ory Communications Magnet Elementary School (SCH048024)

Please feel free to contact me or Caryn Benjamin regarding any of the enclosed information.

Sincerely,



Amanda Ames, P.E.  
Chief Engineer and Safe Drinking Water Administrator, LDH

Attachment

cc: Ms. Monica Brown, Principal, John L. Ory Magnet Elementary School

Sample Results Summary

John L. Ory Communications Magnet (SCH048024)		Lead (mg/L)		Copper (mg/L)	
		AL = 0.015 mg/L		AL = 1.3 mg/L	
Sample Point Description and ID		First Draw Sample	After Flush Sample	First Draw Sample	After Flush Sample
TANK FOUNTAIN, 1FL RR, LEFT	DF01	ND	ND	ND	ND
TANK FOUNTAIN, 1FL RR, RIGHT	DF02	ND	ND	ND	ND
TANK FOUNTAIN, 2FL, BSTUDIO, LEFT	DF03	ND	ND	ND	ND
DRINKING SPOUT, RM 106	DF13	0.003	ND	ND	ND
DRINKING SPOUT, RM 107	DF14	0.006	0.001	ND	ND
DRINKING SPOUT, RM 105	DF15	0.002	ND	ND	ND
DRINKING SPOUT, RM 104	DF16	0.001	ND	ND	ND
DRINKING SPOUT, RM 103	DF17	0.001	ND	ND	ND
DRINKING SPOUT, RM 101	DF18	0.003	ND	ND	ND
DRINKING SPOUT, RM 102	DF19	ND	ND	ND	ND
2 HEAD BUBBLER, OUTSIDE RR, RIGHT	DF21	ND	ND	ND	ND
TANK FOUNTAIN, MID HALLWAY, LEFT	DF22	0.004	ND	0.2	ND
TANK FOUNTAIN, MID HALLWAY, 2RIGHT	DF24	0.003	ND	0.3	ND
HANDWASH SINK, LUNCHROOM, RIGHT	HW01	ND	ND	ND	ND
POT FILLER, KITCHEN	PF01	ND	ND	ND	ND
2C, FOOD PREP SINK, KITCHEN	SK01	0.002	ND	ND	ND
CLASSROOM SINK, RM 204	SK05	0.001	ND	ND	ND
CLASSROOM SINK, RM 206	SK06	0.001	ND	ND	ND
CLASSROOM SINK, RM 205	SK07	0.001	ND	ND	ND
CLASSROOM SINK, RM 210	SK10	ND	ND	ND	ND
CLASSROOM SINK, RM 209	SK11	0.003	0.002	ND	ND
CLASSROOM SINK, RM 211	SK12	0.001	ND	ND	ND
SINK, TEACHERS WORKROOM	SK23	ND	ND	ND	ND
"ND" - None Detect - contaminant level is below the Laboratory Reporting limit (<0.001 mg/L Lead or <0.1 Copper)					
"AL" - Action Level - state recommended action level, 0.015 mg/L for Lead and 1.3 mg/L for Copper					



State of Louisiana  
Louisiana Department of Health  
Public Health Laboratories  
1209 Leesville Avenue  
Baton Rouge, LA 70802  
225-219-5200  
<http://www.dhh.la.gov/lab>



October 26, 2020

The following analytical results have been obtained for the indicated sample(s) which was submitted to this laboratory:

<b>Sample Pt. Description:</b>	HANDWASH SINK, LUNCHROOM, RIGHT	Sample ID:	B2005518-001
<b>Sample Pt ID:</b>	HW01	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 5:31:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	2C, FOOD PREP SINK, KITCHEN	Sample ID:	B2005518-002
<b>Sample Pt ID:</b>	SK01	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 5:32:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.002	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	POT FILLER, KITCHEN	Sample ID:	B2005518-003
<b>Sample Pt ID:</b>	PF01	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 5:33:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, 2FL, BSTUDIO, LEFT	Sample ID:	B2005518-004
<b>Sample Pt ID:</b>	DF03	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 5:55:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	CLASSROOM SINK, RM 204	Sample ID:	B2005518-005
<b>Sample Pt ID:</b>	SK05	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 5:44:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	CLASSROOM SINK, RM 206	Sample ID:	B2005518-006
<b>Sample Pt ID:</b>	SK06	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 5:59:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	CLASSROOM SINK, RM 205	Sample ID:	B2005518-007
<b>Sample Pt ID:</b>	SK07	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 6:01:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	CLASSROOM SINK, RM 210	Sample ID:	B2005518-008
<b>Sample Pt ID:</b>	SK10	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 5:50:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	CLASSROOM SINK, RM 209	Sample ID:	B2005518-009
<b>Sample Pt ID:</b>	SK11	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 6:02:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.003	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	CLASSROOM SINK, RM 211	Sample ID:	B2005518-010
<b>Sample Pt ID:</b>	SK12	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 5:52:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	DRINKING SPOUT, RM 106	Sample ID:	B2005518-011
<b>Sample Pt ID:</b>	DF13	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 5:42:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.003	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	DRINKING SPOUT, RM 107	Sample ID:	B2005518-012
<b>Sample Pt ID:</b>	DF14	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 5:45:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.006	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	DRINKING SPOUT, RM 105	Sample ID:	B2005518-013
<b>Sample Pt ID:</b>	DF15	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 5:48:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.002	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	DRINKING SPOUT, RM 104	Sample ID:	B2005518-014
<b>Sample Pt ID:</b>	DF16	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 5:50:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	DRINKING SPOUT, RM 103	Sample ID:	B2005518-015
<b>Sample Pt ID:</b>	DF17	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 6:00:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	DRINKING SPOUT, RM 101	Sample ID:	B2005518-016
<b>Sample Pt ID:</b>	DF18	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 5:57:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.003	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	DRINKING SPOUT, RM 102	Sample ID:	B2005518-017
<b>Sample Pt ID:</b>	DF19	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 5:53:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	2 HEAD BUBBLER, OUTSIDE RR, RIGHT	Sample ID:	B2005518-018
<b>Sample Pt ID:</b>	DF21	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 6:05:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	SINK, TEACHERS WORKROOM	Sample ID:	B2005518-019
<b>Sample Pt ID:</b>	SK23	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 6:14:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, MID HALLWAY, LEFT	Sample ID:	B2005518-020
<b>Sample Pt ID:</b>	DF22	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 6:15:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.004	mg/L	0.001	0.015	
Copper	0.2	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, MID HALLWAY, 2RIGHT	Sample ID:	B2005518-021
<b>Sample Pt ID:</b>	DF24	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 6:17:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.003	mg/L	0.001	0.015	
Copper	0.3	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	HANDWASH SINK, LUNCHROOM, RIGHT	Sample ID:	B2005518-022
<b>Sample Pt ID:</b>	HW01	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 7:21:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	2C, FOOD PREP SINK, KITCHEN	Sample ID:	B2005518-023
<b>Sample Pt ID:</b>	SK01	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 7:23:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	



**Sample Pt. Description:** POT FILLER, KITCHEN  
**Sample Pt ID:** PF01  
 PWS ID: LA1095007  
 Water System Name: ST JOHN WATER DISTRICT 3  
 Facility ID: SCH048024  
 Collection Address: After Flush

Sample ID: B2005518-024  
 Sample Type: Special  
 Sample Collector: Favorth  
 Collection date: 10/22/2020 7:27:00AM  
 Lab Submittal date: 10/22/2020 9:30:00AM

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

**Sample Pt. Description:** TANK FOUNTAIN, 2FL, BSTUDIO, LEFT  
**Sample Pt ID:** DF03  
 PWS ID: LA1095007  
 Water System Name: ST JOHN WATER DISTRICT 3  
 Facility ID: SCH048024  
 Collection Address: After Flush

Sample ID: B2005518-025  
 Sample Type: Special  
 Sample Collector: Favorth  
 Collection date: 10/22/2020 7:06:00AM  
 Lab Submittal date: 10/22/2020 9:30:00AM

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

**Sample Pt. Description:** CLASSROOM SINK, RM 204  
**Sample Pt ID:** SK05  
 PWS ID: LA1095007  
 Water System Name: ST JOHN WATER DISTRICT 3  
 Facility ID: SCH048024  
 Collection Address: After Flush

Sample ID: B2005518-026  
 Sample Type: Special  
 Sample Collector: Favorth  
 Collection date: 10/22/2020 7:25:00AM  
 Lab Submittal date: 10/22/2020 9:30:00AM

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

**Sample Pt. Description:** CLASSROOM SINK, RM 206  
**Sample Pt ID:** SK06  
 PWS ID: LA1095007  
 Water System Name: ST JOHN WATER DISTRICT 3  
 Facility ID: SCH048024  
 Collection Address: After Flush

Sample ID: B2005518-027  
 Sample Type: Special  
 Sample Collector: Favorth  
 Collection date: 10/22/2020 7:23:00AM  
 Lab Submittal date: 10/22/2020 9:30:00AM

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

**Sample Pt. Description:** CLASSROOM SINK, RM 205  
**Sample Pt ID:** SK07  
 PWS ID: LA1095007  
 Water System Name: ST JOHN WATER DISTRICT 3  
 Facility ID: SCH048024  
 Collection Address: After Flush

Sample ID: B2005518-028  
 Sample Type: Special  
 Sample Collector: Favorth  
 Collection date: 10/22/2020 7:20:00AM  
 Lab Submittal date: 10/22/2020 9:30:00AM

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

**Sample Pt. Description:** CLASSROOM SINK, RM 210  
**Sample Pt ID:** SK10  
 PWS ID: LA1095007  
 Water System Name: ST JOHN WATER DISTRICT 3  
 Facility ID: SCH048024  
 Collection Address: After Flush

Sample ID: B2005518-029  
 Sample Type: Special  
 Sample Collector: Favorth  
 Collection date: 10/22/2020 7:19:00AM  
 Lab Submittal date: 10/22/2020 9:30:00AM

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

**Sample Pt. Description:** CLASSROOM SINK, RM 209  
**Sample Pt ID:** SK11  
 PWS ID: LA1095007  
 Water System Name: ST JOHN WATER DISTRICT 3  
 Facility ID: SCH048024  
 Collection Address: After Flush

Sample ID: B2005518-030  
 Sample Type: Special  
 Sample Collector: Favorth  
 Collection date: 10/22/2020 7:16:00AM  
 Lab Submittal date: 10/22/2020 9:30:00AM

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.002	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

**Sample Pt. Description:** CLASSROOM SINK, RM 211  
**Sample Pt ID:** SK12  
 PWS ID: LA1095007  
 Water System Name: ST JOHN WATER DISTRICT 3  
 Facility ID: SCH048024  
 Collection Address: After Flush

Sample ID: B2005518-031  
 Sample Type: Special  
 Sample Collector: Favorth  
 Collection date: 10/22/2020 7:14:00AM  
 Lab Submittal date: 10/22/2020 9:30:00AM

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	DRINKING SPOUT, RM 106	Sample ID:	B2005518-032
<b>Sample Pt ID:</b>	DF13	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 7:00:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	DRINKING SPOUT, RM 107	Sample ID:	B2005518-033
<b>Sample Pt ID:</b>	DF14	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 7:03:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	DRINKING SPOUT, RM 105	Sample ID:	B2005518-034
<b>Sample Pt ID:</b>	DF15	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 7:05:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	DRINKING SPOUT, RM 104	Sample ID:	B2005518-035
<b>Sample Pt ID:</b>	DF16	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 7:06:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	DRINKING SPOUT, RM 103	Sample ID:	B2005518-036
<b>Sample Pt ID:</b>	DF17	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 7:15:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	DRINKING SPOUT, RM 101	Sample ID:	B2005518-037
<b>Sample Pt ID:</b>	DF18	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 7:17:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	DRINKING SPOUT, RM 102	Sample ID:	B2005518-038
<b>Sample Pt ID:</b>	DF19	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 7:16:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	2 HEAD BUBBLER, OUTSIDE RR, RIGHT	Sample ID:	B2005518-039
<b>Sample Pt ID:</b>	DF21	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	Favorth
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/22/2020 6:53:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/22/2020 9:30:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

**Sample Pt. Description:** SINK, TEACHERS WORKROOM  
**Sample Pt ID:** SK23  
 PWS ID: LA1095007  
 Water System Name: ST JOHN WATER DISTRICT 3  
 Facility ID: SCH048024  
 Collection Address: After Flush

Sample ID: B2005518-040  
 Sample Type: Special  
 Sample Collector: Favorth  
 Collection date: 10/22/2020 6:41:00AM  
 Lab Submittal date: 10/22/2020 9:30:00AM

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

**Sample Pt. Description:** TANK FOUNTAIN, MID HALLWAY, LEFT  
**Sample Pt ID:** DF22  
 PWS ID: LA1095007  
 Water System Name: ST JOHN WATER DISTRICT 3  
 Facility ID: SCH048024  
 Collection Address: After Flush

Sample ID: B2005518-041  
 Sample Type: Special  
 Sample Collector: Favorth  
 Collection date: 10/22/2020 6:38:00AM  
 Lab Submittal date: 10/22/2020 9:30:00AM

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

**Sample Pt. Description:** TANK FOUNTAIN, MID HALLWAY, 2RIGHT  
**Sample Pt ID:** DF24  
 PWS ID: LA1095007  
 Water System Name: ST JOHN WATER DISTRICT 3  
 Facility ID: SCH048024  
 Collection Address: After Flush

Sample ID: B2005518-042  
 Sample Type: Special  
 Sample Collector: Favorth  
 Collection date: 10/22/2020 6:39:00AM  
 Lab Submittal date: 10/22/2020 9:30:00AM

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

**Sample Pt. Description:** 428 ORANGE LOOP  
**Sample Pt ID:** TCR-014  
 PWS ID: LA1095007  
 Water System Name: ST JOHN WATER DISTRICT 3  
 Facility ID: DS0950  
 Collection Address: Distribution

Sample ID: B2005518-043  
 Sample Type: Special  
 Sample Collector: Favorth  
 Collection date: 10/22/2020 7:38:00AM  
 Lab Submittal date: 10/22/2020 9:30:00AM

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

Reviewed by: Aaron Hawkins



State of Louisiana  
Louisiana Department of Health  
Public Health Laboratories  
1209 Leesville Avenue  
Baton Rouge, LA 70802  
225-219-5200  
<http://www.dhh.la.gov/lab>



October 26, 2020

The following analytical results have been obtained for the indicated sample(s) which was submitted to this laboratory:

---

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, 1FL RR, LEFT	Sample ID:	B2005576-001
<b>Sample Pt ID:</b>	DF01	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	MARTINEZ
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/23/2020 5:46:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/23/2020 9:15:00AM
Collection Address:	FIRST DRAW		

---

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

---

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, 1FL RR, RIGHT	Sample ID:	B2005576-002
<b>Sample Pt ID:</b>	DF02	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	MARTINEZ
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/23/2020 5:48:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/23/2020 9:15:00AM
Collection Address:	FIRST DRAW		

---

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

---

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, 1FL RR, LEFT	Sample ID:	B2005576-003
<b>Sample Pt ID:</b>	DF01	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	MARTINEZ
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/23/2020 6:06:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/23/2020 9:15:00AM
Collection Address:	AFTER FLUSH		

---

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, 1FL RR, RIGHT	Sample ID:	B2005576-004
<b>Sample Pt ID:</b>	DF02	Sample Type:	Special
PWS ID:	LA1095007	Sample Collector:	MARTINEZ
Water System Name:	ST JOHN WATER DISTRICT 3	Collection date:	10/23/2020 6:08:00AM
Facility ID:	SCH048024	Lab Submittal date:	10/23/2020 9:15:00AM
Collection Address:	AFTER FLUSH		

<b>Component Name</b>	<b>Results</b>	<b>Units</b>	<b>Rep. Limit</b>	<b>MCL</b>	<b>Qualifiers</b>
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

Reviewed by: Aaron Hawkins