



**State of Louisiana**  
Louisiana Department of Health  
Office of Public Health

November 9, 2020

Ms. Janet Tullos  
Superintendent of Schools  
LaSalle Parish School Board  
P.O. Box 90  
Jena, LA 71342-0090

RE: Results of School Drinking Water Testing  
Olla-Standard Elementary School (SCH030008)  
P.O. Box 1188, Olla, LA 71465

Dear Ms. Tullos,

Act 632 of the 2018 Regular Session required the Louisiana Department of Health (LDH) to establish a pilot program for drinking water testing at 12 public elementary schools that were constructed prior to 1986 or which may otherwise be susceptible to drinking water contamination. Thank you for your participation and cooperation in this pilot program.

On October 30 and November 5, 2020, a total of 32 water samples were collected from the above referenced school in accordance with guidance provided in the Environmental Protection Agency's (EPA's) - 3Ts for Reducing Lead in Drinking Water in Schools Manual. Attached are the lead and copper sample results. Please note that the sample result for sample point ID "TCR-001" is for a sample collected from the water system.

All sample results were evaluated against the state recommended Action Levels for Lead (0.015 mg/L) and Copper (1.3 mg/L) for drinking water. All sample results are well below the state recommended Action Levels for Lead and Copper.

Although these results indicate no exceedance of the lead action level (0.015 mg/L) in the school drinking water, LDH recommends that all schools follow the guidance provided in the EPA-3Ts manual to safeguard against lead in the drinking water. The EPA-3Ts manual was developed to assist schools with lead in drinking water prevention programs. This guidance is intended for use by school officials responsible for the maintenance and/or safety of school's drinking water. This document along with other helpful information is available for on EPA's website at: <https://www.epa.gov/dwreginfo/3ts-reducing-lead-drinking-water-schools-and-child-care-facilities>.

Please notify this office of any control or remediation measures taken by the school. LDH will perform follow up sampling to confirm the corrective actions were effective.

Please feel free to contact me or Caryn Benjamin regarding any of the enclosed information.

Sincerely,

Amanda Ames, P.E.  
 Chief Engineer and Safe Drinking Water Administrator, LDH

Attachment

cc: Ms. Rhonda Russel, Principal, Olla-Standard Elementary School

Sample Results Summary

Olla-Standard Elementary School (SCH030008)		Lead (mg/L)		Copper (mg/L)	
		AL = 0.015 mg/L		AL = 1.3 mg/L	
Sample Point Description and ID		First Draw Sample	After Flush Sample	First Draw Sample	After Flush Sample
TANK FOUNTAIN, PREK, MID	DF02	ND	ND	ND	0.3
TANK FOUNTAIN, 3GH	DF04	0.001	ND	1.0	0.2
TANK FOUNTAIN, 2GH	DF05	ND	ND	0.5	ND
TANK FOUNTAIN, 2GH	DF06	ND	ND	0.2	ND
TANK FOUNTAIN, 4-5GH	DF07	ND	ND	0.2	ND
TANK FOUNTAIN, GYM	DF08	ND	ND	1.2	0.1
TANK FOUNTAIN, OUTSIDE IVB	DF09	ND	ND	ND	ND
TANK FOUNTAIN, 1GH BOYS RR	DF10	ND	ND	0.2	ND
POT FILLER, ROUND KETTLE, KITCHEN	SK01	ND	ND	0.3	0.4
POT FILLER, SQUARE KETTLE, KITCHEN	SK02	ND	ND	0.3	0.4
SINK, KITCHEN	PF01	0.001	ND	0.2	0.4
2C SINK, KITCHEN	PF02	ND	ND	0.2	0.4
"ND" - None Detect - contaminant level is below the Laboratory Reporting Limit (<0.001 mg/L Lead or <0.1 mg/L Copper)					
"AL" - Action Level - state recommended action level					



State of Louisiana  
Louisiana Department of Health  
Public Health Laboratories  
1209 Leesville Avenue  
Baton Rouge, LA 70802  
225-219-5200  
<http://www.dhh.la.gov/lab>



November 02, 2020

The following analytical results have been obtained for the indicated sample(s) which was submitted to this laboratory:

---

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, PREK, MID	Sample ID:	B2005848-001
<b>Sample Pt ID:</b>	DF02	Sample Type:	Special
PWS ID:	LA1059004	Sample Collector:	Bruce
Water System Name:	TOWN OF OLLA WATER SYSTEM	Collection date:	10/30/2020 5:06:00AM
Facility ID:	SCH030008	Lab Submittal date:	11/2/2020 7:00:00AM
Collection Address:	First Draw		

---

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

---

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, 2GH	Sample ID:	B2005848-002
<b>Sample Pt ID:</b>	DF05	Sample Type:	Special
PWS ID:	LA1059004	Sample Collector:	Bruce
Water System Name:	TOWN OF OLLA WATER SYSTEM	Collection date:	10/30/2020 5:02:00AM
Facility ID:	SCH030008	Lab Submittal date:	11/2/2020 7:00:00AM
Collection Address:	First Draw		

---

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.5	mg/L	0.1	1.3	

---

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, 2GH	Sample ID:	B2005848-003
<b>Sample Pt ID:</b>	DF06	Sample Type:	Special
PWS ID:	LA1059004	Sample Collector:	Bruce
Water System Name:	TOWN OF OLLA WATER SYSTEM	Collection date:	10/30/2020 5:03:00AM
Facility ID:	SCH030008	Lab Submittal date:	11/2/2020 7:00:00AM
Collection Address:	First Draw		

---

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.2	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, 4-5GH	Sample ID:	B2005848-004
<b>Sample Pt ID:</b>	DF07	Sample Type:	Special
PWS ID:	LA1059004	Sample Collector:	Bruce
Water System Name:	TOWN OF OLLA WATER SYSTEM	Collection date:	10/30/2020 5:08:00AM
Facility ID:	SCH030008	Lab Submittal date:	11/2/2020 7:00:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.2	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, OUTSIDE IVB	Sample ID:	B2005848-005
<b>Sample Pt ID:</b>	DF09	Sample Type:	Special
PWS ID:	LA1059004	Sample Collector:	Bruce
Water System Name:	TOWN OF OLLA WATER SYSTEM	Collection date:	10/30/2020 5:05:00AM
Facility ID:	SCH030008	Lab Submittal date:	11/2/2020 7:00:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, 1GH BOYS RR	Sample ID:	B2005848-006
<b>Sample Pt ID:</b>	DF10	Sample Type:	Special
PWS ID:	LA1059004	Sample Collector:	Bruce
Water System Name:	TOWN OF OLLA WATER SYSTEM	Collection date:	10/30/2020 5:04:00AM
Facility ID:	SCH030008	Lab Submittal date:	11/2/2020 7:00:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.2	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	SINK, KITCHEN	Sample ID:	B2005848-007
<b>Sample Pt ID:</b>	SK01	Sample Type:	Special
PWS ID:	LA1059004	Sample Collector:	Bruce
Water System Name:	TOWN OF OLLA WATER SYSTEM	Collection date:	10/30/2020 5:02:00AM
Facility ID:	SCH030008	Lab Submittal date:	11/2/2020 7:00:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.3	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	2C SINK, KITCHEN	Sample ID:	B2005848-008
<b>Sample Pt ID:</b>	SK02	Sample Type:	Special
PWS ID:	LA1059004	Sample Collector:	Bruce
Water System Name:	TOWN OF OLLA WATER SYSTEM	Collection date:	10/30/2020 5:02:00AM
Facility ID:	SCH030008	Lab Submittal date:	11/2/2020 7:00:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.3	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	POT FILLER, ROUND KETTLE, KITCHEN	Sample ID:	B2005848-009
<b>Sample Pt ID:</b>	PF01	Sample Type:	Special
PWS ID:	LA1059004	Sample Collector:	Bruce
Water System Name:	TOWN OF OLLA WATER SYSTEM	Collection date:	10/30/2020 5:03:00AM
Facility ID:	SCH030008	Lab Submittal date:	11/2/2020 7:00:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.001	mg/L	0.001	0.015	
Copper	0.2	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	POT FILLER, SQUARE KETTLE, KITCHEN	Sample ID:	B2005848-010
<b>Sample Pt ID:</b>	PF02	Sample Type:	Special
PWS ID:	LA1059004	Sample Collector:	Bruce
Water System Name:	TOWN OF OLLA WATER SYSTEM	Collection date:	10/30/2020 5:04:00AM
Facility ID:	SCH030008	Lab Submittal date:	11/2/2020 7:00:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.2	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, PREK, MID	Sample ID:	B2005848-011
<b>Sample Pt ID:</b>	DF02	Sample Type:	Special
PWS ID:	LA1059004	Sample Collector:	Bruce
Water System Name:	TOWN OF OLLA WATER SYSTEM	Collection date:	10/30/2020 5:30:00AM
Facility ID:	SCH030008	Lab Submittal date:	11/2/2020 7:00:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.3	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, 2GH	Sample ID:	B2005848-012
<b>Sample Pt ID:</b>	DF05	Sample Type:	Special
PWS ID:	LA1059004	Sample Collector:	Bruce
Water System Name:	TOWN OF OLLA WATER SYSTEM	Collection date:	10/30/2020 5:26:00AM
Facility ID:	SCH030008	Lab Submittal date:	11/2/2020 7:00:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, 2GH	Sample ID:	B2005848-013
<b>Sample Pt ID:</b>	DF06	Sample Type:	Special
PWS ID:	LA1059004	Sample Collector:	Bruce
Water System Name:	TOWN OF OLLA WATER SYSTEM	Collection date:	10/30/2020 5:27:00AM
Facility ID:	SCH030008	Lab Submittal date:	11/2/2020 7:00:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, 4-5GH	Sample ID:	B2005848-014
<b>Sample Pt ID:</b>	DF07	Sample Type:	Special
PWS ID:	LA1059004	Sample Collector:	Bruce
Water System Name:	TOWN OF OLLA WATER SYSTEM	Collection date:	10/30/2020 5:49:00AM
Facility ID:	SCH030008	Lab Submittal date:	11/2/2020 7:00:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, OUTSIDE IVB	Sample ID:	B2005848-015
<b>Sample Pt ID:</b>	DF09	Sample Type:	Special
PWS ID:	LA1059004	Sample Collector:	Bruce
Water System Name:	TOWN OF OLLA WATER SYSTEM	Collection date:	10/30/2020 5:47:00AM
Facility ID:	SCH030008	Lab Submittal date:	11/2/2020 7:00:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, 1GH BOYS RR	Sample ID:	B2005848-016
<b>Sample Pt ID:</b>	DF10	Sample Type:	Special
PWS ID:	LA1059004	Sample Collector:	Bruce
Water System Name:	TOWN OF OLLA WATER SYSTEM	Collection date:	10/30/2020 5:30:00AM
Facility ID:	SCH030008	Lab Submittal date:	11/2/2020 7:00:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	SINK, KITCHEN	Sample ID:	B2005848-017
<b>Sample Pt ID:</b>	SK01	Sample Type:	Special
PWS ID:	LA1059004	Sample Collector:	Bruce
Water System Name:	TOWN OF OLLA WATER SYSTEM	Collection date:	10/30/2020 5:08:00AM
Facility ID:	SCH030008	Lab Submittal date:	11/2/2020 7:00:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.4	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	2C SINK, KITCHEN	Sample ID:	B2005848-018
<b>Sample Pt ID:</b>	SK02	Sample Type:	Special
PWS ID:	LA1059004	Sample Collector:	Bruce
Water System Name:	TOWN OF OLLA WATER SYSTEM	Collection date:	10/30/2020 5:09:00AM
Facility ID:	SCH030008	Lab Submittal date:	11/2/2020 7:00:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.4	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	POT FILLER, ROUND KETTLE, KITCHEN	Sample ID:	B2005848-019
<b>Sample Pt ID:</b>	PF01	Sample Type:	Special
PWS ID:	LA1059004	Sample Collector:	Bruce
Water System Name:	TOWN OF OLLA WATER SYSTEM	Collection date:	10/30/2020 5:11:00AM
Facility ID:	SCH030008	Lab Submittal date:	11/2/2020 7:00:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.4	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	POT FILLER, SQUARE KETTLE, KITCHEN	Sample ID:	B2005848-020
<b>Sample Pt ID:</b>	PF02	Sample Type:	Special
PWS ID:	LA1059004	Sample Collector:	Bruce
Water System Name:	TOWN OF OLLA WATER SYSTEM	Collection date:	10/30/2020 5:12:00AM
Facility ID:	SCH030008	Lab Submittal date:	11/2/2020 7:00:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.4	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	1700 FRONT STREET	Sample ID:	B2005848-021
<b>Sample Pt ID:</b>	TCR-001	Sample Type:	Special
PWS ID:	LA1059004	Sample Collector:	Bruce
Water System Name:	TOWN OF OLLA WATER SYSTEM	Collection date:	10/30/2020 6:10:00AM
Facility ID:	DS0950	Lab Submittal date:	11/2/2020 7:00:00AM
Collection Address:	Distribution System		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

Reviewed by: Aaron Hawkins





State of Louisiana  
Louisiana Department of Health  
Public Health Laboratories  
1209 Leesville Avenue  
Baton Rouge, LA 70802  
225-219-5200  
<http://www.dhh.la.gov/lab>



November 09, 2020

The following analytical results have been obtained for the indicated sample(s) which was submitted to this laboratory:

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, 3GH	Sample ID:	B2005973-001
<b>Sample Pt ID:</b>	DF04	Sample Type:	Special
PWS ID:	LA1059004	Sample Collector:	BRUCE
Water System Name:	TOWN OF OLLA WATER SYSTEM	Collection date:	11/5/2020 5:57:00AM
Facility ID:	SCH030008	Lab Submittal date:	11/6/2020 3:20:00PM
Collection Address:	FIRST DRAW		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.001	mg/L	0.001	0.015	
Copper	1.0	mg/L	0.1	1.3	> 1/2 MCL

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, 3GH	Sample ID:	B2005973-002
<b>Sample Pt ID:</b>	DF04	Sample Type:	Special
PWS ID:	LA1059004	Sample Collector:	BRUCE
Water System Name:	TOWN OF OLLA WATER SYSTEM	Collection date:	11/5/2020 6:31:00AM
Facility ID:	SCH030008	Lab Submittal date:	11/6/2020 3:20:00PM
Collection Address:	AFTER FLUSH		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.2	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, GYM	Sample ID:	B2005973-003
<b>Sample Pt ID:</b>	DF08	Sample Type:	Special
PWS ID:	LA1059004	Sample Collector:	BRUCE
Water System Name:	TOWN OF OLLA WATER SYSTEM	Collection date:	11/5/2020 5:59:00AM
Facility ID:	SCH030008	Lab Submittal date:	11/6/2020 3:20:00PM
Collection Address:	FIRST DRAW		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	1.2	mg/L	0.1	1.3	> 1/2 MCL

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, GYM	Sample ID:	B2005973-004
<b>Sample Pt ID:</b>	DF08	Sample Type:	Special
PWS ID:	LA1059004	Sample Collector:	BRUCE
Water System Name:	TOWN OF OLLA WATER SYSTEM	Collection date:	11/5/2020 6:15:00AM
Facility ID:	SCH030008	Lab Submittal date:	11/6/2020 3:20:00PM
Collection Address:	AFTER FLUSH		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.1	mg/L	0.1	1.3	

**Qualifier Key**

Qualifier	Description
> 1/2 MCL	Final Result > 1/2 MCL but < MCL

Reviewed by: Aaron Hawkins