



State of Louisiana
Louisiana Department of Health
Office of Public Health

October 9, 2019

Mr. James William
Superintendent of Schools
Vernon Parish School Board
201 Belview Road
Leesville, LA 71446

RE: Results of School Drinking Water Testing
Rosepine Elementary School (SCH058016)
1208 Texas Avenue, Rosepine, LA 70659

Dear Mr. William,

Act 632 of the 2018 Regular Session required the Louisiana Department of Health (LDH) to establish a pilot program for drinking water testing at 12 public elementary schools that were constructed prior to 1986 or which may otherwise be susceptible to drinking water contamination. Thank you for your participation and cooperation in this pilot program.

On September 19, 2019 and October 3, 2019 a total of 60 water samples were collected from the above referenced school in accordance with guidance provided in the Environmental Protection Agency's (EPA's) - 3Ts for Reducing Lead in Drinking Water in Schools Manual. Attached are the lead and copper sample results. Please note that the sample result for sample point ID "TCR-004" is for a sample collected from the water system.

All sample results are below the state recommended action level of 0.015 mg/L for Lead for drinking water. However, there are several drinking fountains that exceeded the state recommended action level of 1.3 mg/L for copper in both sampling events. LDH advised the school to replace some fountains (DF01-DF04), investigate plumbing materials for replacement (serving DF01-DF04) and perform routine flushing of other fountains (DF07-DF14) to reduce copper levels. LDH also advised the school to perform a daily flush prior to use of each water outlet in the kitchen used for food preparation to reduce lead levels.

Furthermore, two drinking water fountains manufactured by Halsey Taylor were identified with model numbers starting with S500 (DF07 and DF08). Per Appendix B of the EPA-3Ts manual, Halsey Taylor water coolers with model numbers starting with S500 are banned if manufactured between 1978 and 1987. Unless the manufactured year is determined to be after 1987, it is recommended that these fountains be turned off and removed.

October 9, 2019


Page 2

RE: Results of School Drinking Water Testing
Rosepine Elementary School (SCH058016)
1208 Texas Avenue, Rosepine, LA 70659

Although these results indicate no exceedance of the lead action level (0.015 mg/L) in the school drinking water, LDH recommends that all schools follow the guidance provided in the EPA-3Ts manual to safeguard against lead in the drinking water. The EPA-3Ts manual was developed to assist schools with lead in drinking water prevention programs. This guidance is intended for use by school officials responsible for the maintenance and/or safety of school's drinking water. The EPA-3Ts manual along with other helpful information is available for on EPA's website at: <https://www.epa.gov/dwreginfo/3ts-reducing-lead-drinking-water-schools-and-child-care-facilities>.

Please feel free to contact me regarding any of the enclosed information.

Sincerely,



Amanda Ames, P.E.

Chief Engineer and Safe Drinking Water Administrator, LDH

Attachment

cc: Ms. Sandra Blakeway, Principal, Rosepine Elementary School



State of Louisiana
Louisiana Department of Health
Public Health Laboratories
1209 Leesville Avenue
Baton Rouge, LA 70802
225-219-5200
<http://www.dhh.la.gov/lab>



September 24, 2019

The following analytical results have been obtained for the indicated sample(s) which was submitted to this laboratory:

Sample Pt. Description:	TANK FOUNTAIN, BLDA, BOYBR, LEFT	Sample ID:	B1904162-001
Sample Pt ID:	DF01	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	DeKeyzer
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	9/19/2019 5:36:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.001	mg/L	0.001	0.015	
Copper	2.4	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, BLDA, BOYBR, RIGHT	Sample ID:	B1904162-002
Sample Pt ID:	DF02	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	DeKeyzer
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	9/19/2019 5:36:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	3.2	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, BLDA, GIRLBR, LEFT	Sample ID:	B1904162-003
Sample Pt ID:	DF03	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	DeKeyzer
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	9/19/2019 5:55:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	3.2	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, BLDA, GIRLBR, RIGHT	Sample ID:	B1904162-004
Sample Pt ID:	DF04	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	DeKeyzer
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	9/19/2019 5:57:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	1.8	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, BLDA, RM17	Sample ID:	B1904162-005
Sample Pt ID:	DF05	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	DeKeyzer
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	9/19/2019 6:15:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	1.3	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, BLDC, NRBR, LEFT	Sample ID:	B1904162-006
Sample Pt ID:	DF07	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	DeKeyzer
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	9/19/2019 5:43:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	2.3	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, BLDC, NRBR, RIGHT	Sample ID:	B1904162-007
Sample Pt ID:	DF08	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	DeKeyzer
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	9/19/2019 5:44:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	3.0	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, BLDD, NRLOUNGE	Sample ID:	B1904162-008
Sample Pt ID:	DF09	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	DeKeyzer
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	9/19/2019 6:04:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	2.7	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, BLDD, NRBR, RM7	Sample ID:	B1904162-009
Sample Pt ID:	DF10	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	DeKeyzer
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	9/19/2019 6:07:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	5.4	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, BLDA, BOYBR, LEFT	Sample ID:	B1904162-010
Sample Pt ID:	DF01	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	DeKeyzer
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	9/19/2019 5:51:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.002	mg/L	0.001	0.015	
Copper	3.0	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, BLDA, BOYBR, RIGHT	Sample ID:	B1904162-011
Sample Pt ID:	DF02	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	DeKeyzer
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	9/19/2019 5:52:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.002	mg/L	0.001	0.015	
Copper	2.8	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, BLDA, GIRLBR, LEFT	Sample ID:	B1904162-012
Sample Pt ID:	DF03	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	DeKeyzer
Water System Name:	TOWN OF ROSEFINE WATER SYSTEM	Collection date:	9/19/2019 6:11:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.002	mg/L	0.001	0.015	
Copper	3.0	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, BLDA, GIRLBR, RIGHT	Sample ID:	B1904162-013
Sample Pt ID:	DF04	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	DeKeyzer
Water System Name:	TOWN OF ROSEFINE WATER SYSTEM	Collection date:	9/19/2019 6:12:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.002	mg/L	0.001	0.015	
Copper	3.1	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, BLDA, RM17	Sample ID:	B1904162-014
Sample Pt ID:	DF05	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	DeKeyzer
Water System Name:	TOWN OF ROSEFINE WATER SYSTEM	Collection date:	9/19/2019 6:31:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.3	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, BLDC, NRBR, LEFT	Sample ID:	B1904162-015
Sample Pt ID:	DF07	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	DeKeyzer
Water System Name:	TOWN OF ROSEFINE WATER SYSTEM	Collection date:	9/19/2019 6:00:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.4	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, BLDC, NRBR, RIGHT	Sample ID:	B1904162-016
Sample Pt ID:	DF08	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	DeKeyzer
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	9/19/2019 6:01:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.4	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, BLDD, NRLOUNGE	Sample ID:	B1904162-017
Sample Pt ID:	DF09	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	DeKeyzer
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	9/19/2019 6:22:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.5	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, BLDD, NRBR, RM7	Sample ID:	B1904162-018
Sample Pt ID:	DF10	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	DeKeyzer
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	9/19/2019 6:23:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	1.8	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	7400 MAIN STREET	Sample ID:	B1904162-019
Sample Pt ID:	TCR-004	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	DeKeyzer
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	9/19/2019 7:18:00AM
Facility ID:	DS0950	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	Distribution		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

Qualifier Key

<u>Qualifier</u>	<u>Description</u>
> MCL	Final Result Above MCL

Reviewed by: Aaron Hawkins



State of Louisiana
 Louisiana Department of Health
 Public Health Laboratories
 1209 Leesville Avenue
 Baton Rouge, LA 70802
 225-219-5200
<http://www.dhh.la.gov/lab>



September 24, 2019

The following analytical results have been obtained for the indicated sample(s) which was submitted to this laboratory:

Sample Pt. Description:	POT FILLER, KITCHEN	Sample ID:	B1904163-001
Sample Pt ID:	PF01	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	9/19/2019 5:39:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.003	mg/L	0.001	0.015	
Copper	0.7	mg/L	0.1	1.3	> 1/2 MCL

Sample Pt. Description:	SINK, KITCHEN, BACK WALL	Sample ID:	B1904163-002
Sample Pt ID:	SK01	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	9/19/2019 5:40:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.003	mg/L	0.001	0.015	
Copper	2.5	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, CAFETERIA	Sample ID:	B1904163-003
Sample Pt ID:	DF11	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	9/19/2019 5:46:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.001	mg/L	0.001	0.015	
Copper	2.7	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, GYM, GIRLBR	Sample ID:	B1904163-004
Sample Pt ID:	DF12	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	9/19/2019 5:49:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	2.5	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, GYM, BOYBR	Sample ID:	B1904163-005
Sample Pt ID:	DF13	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	9/19/2019 5:50:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	3.1	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, BLDA, RM20	Sample ID:	B1904163-006
Sample Pt ID:	DF06	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	9/20/2019 6:27:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.7	mg/L	0.1	1.3	> 1/2 MCL

Sample Pt. Description:	TANK FOUNTAIN, HEADSTART	Sample ID:	B1904163-007
Sample Pt ID:	DF14	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	9/20/2019 6:44:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	5.3	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	POT FILLER, KITCHEN	Sample ID:	B1904163-008
Sample Pt ID:	PF01	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	9/19/2019 5:43:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.001	mg/L	0.001	0.015	
Copper	1.8	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	SINK, KITCHEN, BACK WALL	Sample ID:	B1904163-009
Sample Pt ID:	SK01	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	9/19/2019 5:44:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.001	mg/L	0.001	0.015	
Copper	1.3	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, CAFETERIA	Sample ID:	B1904163-010
Sample Pt ID:	DF11	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	9/19/2019 6:14:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.001	mg/L	0.001	0.015	
Copper	0.7	mg/L	0.1	1.3	> 1/2 MCL

Sample Pt. Description:	TANK FOUNTAIN, GYM, GIRLBR	Sample ID:	B1904163-011
Sample Pt ID:	DF12	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	9/19/2019 6:31:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.8	mg/L	0.1	1.3	> 1/2 MCL

Sample Pt. Description:	TANK FOUNTAIN, GYM, BOYBR	Sample ID:	B1904163-012
Sample Pt ID:	DF13	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	9/19/2019 6:41:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.9	mg/L	0.1	1.3	> 1/2 MCL

Sample Pt. Description:	TANK FOUNTAIN, BLDA, RM20	Sample ID:	B1904163-013
Sample Pt ID:	DF06	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	9/20/2019 6:43:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.2	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, HEADSTART	Sample ID:	B1904163-014
Sample Pt ID:	DF14	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	9/20/2019 7:00:00AM
Facility ID:	SCH058016	Lab Submittal date:	9/20/2019 10:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.3	mg/L	0.1	1.3	

Qualifier Key

Qualifier	Description
> 1/2 MCL	Final Result > 1/2 MCL but < MCL
> MCL	Final Result Above MCL

Reviewed by: Aaron Hawkins



State of Louisiana
Louisiana Department of Health
Public Health Laboratories
1209 Leesville Avenue
Baton Rouge, LA 70802
225-219-5200
<http://www.dhh.la.gov/lab>



October 08, 2019

The following analytical results have been obtained for the indicated sample(s) which was submitted to this laboratory:

Sample Pt. Description:	TANK FOUNTAIN, BLDA, BOYBR, LEFT	Sample ID:	B1904436-001
Sample Pt ID:	DF01	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEFINE WATER SYSTEM	Collection date:	10/3/2019 8:12:00AM
Facility ID:	SCH058016	Lab Submittal date:	10/4/2019 9:50:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.002	mg/L	0.001	0.015	
Copper	2.6	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, BLDA, BOYBR, RIGHT	Sample ID:	B1904436-002
Sample Pt ID:	DF02	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEFINE WATER SYSTEM	Collection date:	10/3/2019 8:13:00AM
Facility ID:	SCH058016	Lab Submittal date:	10/4/2019 9:50:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.003	mg/L	0.001	0.015	
Copper	3.1	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, BLDA, GIRLBR, LEFT	Sample ID:	B1904436-003
Sample Pt ID:	DF03	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEFINE WATER SYSTEM	Collection date:	10/3/2019 8:13:00AM
Facility ID:	SCH058016	Lab Submittal date:	10/4/2019 9:50:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.002	mg/L	0.001	0.015	
Copper	3.3	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, BLDA, GIRLBR, RIGHT	Sample ID:	B1904436-004
Sample Pt ID:	DF04	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	10/3/2019 8:14:00AM
Facility ID:	SCH058016	Lab Submittal date:	10/4/2019 9:50:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.003	mg/L	0.001	0.015	
Copper	4.6	mg/L	0.0	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, BLDC, NRBR, LEFT	Sample ID:	B1904436-005
Sample Pt ID:	DF07	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	10/3/2019 8:12:00AM
Facility ID:	SCH058016	Lab Submittal date:	10/4/2019 9:50:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	2.1	mg/L	0.0	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, BLDC, NRBR, RIGHT	Sample ID:	B1904436-006
Sample Pt ID:	DF08	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	10/3/2019 8:14:00AM
Facility ID:	SCH058016	Lab Submittal date:	10/4/2019 9:50:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	2.5	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, BLDD, NRLOUNGE	Sample ID:	B1904436-007
Sample Pt ID:	DF09	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	10/3/2019 8:16:00AM
Facility ID:	SCH058016	Lab Submittal date:	10/4/2019 9:50:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	3.0	mg/L	0.0	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, BLDD, NRBR, RM7	Sample ID:	B1904436-008
Sample Pt ID:	DF10	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEFINE WATER SYSTEM	Collection date:	10/3/2019 8:17:00AM
Facility ID:	SCH058016	Lab Submittal date:	10/4/2019 9:50:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	7.9	mg/L	0.0	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, HEADSTART	Sample ID:	B1904436-009
Sample Pt ID:	DF14	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEFINE WATER SYSTEM	Collection date:	10/3/2019 8:32:00AM
Facility ID:	SCH058016	Lab Submittal date:	10/4/2019 9:50:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	1.9	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	POT FILLER, KITCHEN	Sample ID:	B1904436-010
Sample Pt ID:	PF01	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEFINE WATER SYSTEM	Collection date:	10/3/2019 8:19:00AM
Facility ID:	SCH058016	Lab Submittal date:	10/4/2019 9:50:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.008	mg/L	0.001	0.015	> 1/2 MCL
Copper	1.6	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	SINK, KITCHEN, BACK WALL	Sample ID:	B1904436-011
Sample Pt ID:	SK01	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEFINE WATER SYSTEM	Collection date:	10/3/2019 8:20:00AM
Facility ID:	SCH058016	Lab Submittal date:	10/4/2019 9:50:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.013	mg/L	0.001	0.015	> 1/2 MCL
Copper	1.0	mg/L	0.1	1.3	> 1/2 MCL

Sample Pt. Description:	TANK FOUNTAIN, CAFETERIA	Sample ID:	B1904436-012
Sample Pt ID:	DF11	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	10/3/2019 8:24:00AM
Facility ID:	SCH058016	Lab Submittal date:	10/4/2019 9:50:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.002	mg/L	0.001	0.015	
Copper	2.5	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, GYM, GIRLBR	Sample ID:	B1904436-013
Sample Pt ID:	DF12	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	10/3/2019 8:26:00AM
Facility ID:	SCH058016	Lab Submittal date:	10/4/2019 9:50:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	5.5	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, GYM, BOYBR	Sample ID:	B1904436-014
Sample Pt ID:	DF13	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	10/3/2019 8:27:00AM
Facility ID:	SCH058016	Lab Submittal date:	10/4/2019 9:50:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	5.4	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, BLDA, BOYBR, LEFT	Sample ID:	B1904436-015
Sample Pt ID:	DF01	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	10/3/2019 9:05:00AM
Facility ID:	SCH058016	Lab Submittal date:	10/4/2019 9:50:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.003	mg/L	0.001	0.015	
Copper	3.4	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, BLDA, BOYBR, RIGHT	Sample ID:	B1904436-016
Sample Pt ID:	DF02	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	10/3/2019 9:06:00AM
Facility ID:	SCH058016	Lab Submittal date:	10/4/2019 9:50:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.002	mg/L	0.001	0.015	
Copper	3.6	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, BLDA, GIRLBR, LEFT	Sample ID:	B1904436-017
Sample Pt ID:	DF03	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	10/3/2019 9:23:00AM
Facility ID:	SCH058016	Lab Submittal date:	10/4/2019 9:50:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.003	mg/L	0.001	0.015	
Copper	3.8	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, BLDA, GIRLBR, RIGHT	Sample ID:	B1904436-018
Sample Pt ID:	DF04	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	10/3/2019 9:22:00AM
Facility ID:	SCH058016	Lab Submittal date:	10/4/2019 9:50:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.003	mg/L	0.001	0.015	
Copper	3.9	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, BLDC, NRBR, LEFT	Sample ID:	B1904436-019
Sample Pt ID:	DF07	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	10/3/2019 9:10:00AM
Facility ID:	SCH058016	Lab Submittal date:	10/4/2019 9:50:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.5	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, BLDC, NRBR, RIGHT	Sample ID:	B1904436-020
Sample Pt ID:	DF08	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	10/3/2019 9:09:00AM
Facility ID:	SCH058016	Lab Submittal date:	10/4/2019 9:50:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.5	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, BLDD, NRLOUNGE	Sample ID:	B1904436-021
Sample Pt ID:	DF09	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	10/3/2019 8:51:00AM
Facility ID:	SCH058016	Lab Submittal date:	10/4/2019 9:50:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.7	mg/L	0.1	1.3	> 1/2 MCL

Sample Pt. Description:	TANK FOUNTAIN, BLDD, NRBR, RM7	Sample ID:	B1904436-022
Sample Pt ID:	DF10	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	10/3/2019 8:34:00AM
Facility ID:	SCH058016	Lab Submittal date:	10/4/2019 9:50:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	1.3	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, HEADSTART	Sample ID:	B1904436-023
Sample Pt ID:	DF14	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	10/3/2019 8:49:00AM
Facility ID:	SCH058016	Lab Submittal date:	10/4/2019 9:50:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.4	mg/L	0.1	1.3	

Sample Pt. Description:	POT FILLER, KITCHEN	Sample ID:	B1904436-024
Sample Pt ID:	PF01	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	10/3/2019 8:22:00AM
Facility ID:	SCH058016	Lab Submittal date:	10/4/2019 9:50:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.001	mg/L	0.001	0.015	
Copper	0.8	mg/L	0.1	1.3	> 1/2 MCL

Sample Pt. Description:	SINK, KITCHEN, BACK WALL	Sample ID:	B1904436-025
Sample Pt ID:	SK01	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	10/3/2019 8:23:00AM
Facility ID:	SCH058016	Lab Submittal date:	10/4/2019 9:50:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.002	mg/L	0.001	0.015	
Copper	1.7	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, CAFETERIA	Sample ID:	B1904436-026
Sample Pt ID:	DF11	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	10/3/2019 8:44:00AM
Facility ID:	SCH058016	Lab Submittal date:	10/4/2019 9:50:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.001	mg/L	0.001	0.015	
Copper	0.9	mg/L	0.1	1.3	> 1/2 MCL

Sample Pt. Description:	TANK FOUNTAIN, GYM, GIRLBR	Sample ID:	B1904436-027
Sample Pt ID:	DF12	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	10/3/2019 9:01:00AM
Facility ID:	SCH058016	Lab Submittal date:	10/4/2019 9:50:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.9	mg/L	0.1	1.3	> 1/2 MCL

Sample Pt. Description:	TANK FOUNTAIN, GYM, BOYBR	Sample ID:	B1904436-028
Sample Pt ID:	DF13	Sample Type:	Special
PWS ID:	LA1115028	Sample Collector:	Bruce
Water System Name:	TOWN OF ROSEPINE WATER SYSTEM	Collection date:	10/3/2019 9:17:00AM
Facility ID:	SCH058016	Lab Submittal date:	10/4/2019 9:50:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.9	mg/L	0.1	1.3	> 1/2 MCL

Qualifier Key

Qualifier	Description
> 1/2 MCL	Final Result > 1/2 MCL but < MCL
> MCL	Final Result Above MCL

Reviewed by: Aaron Hawkins