



State of Louisiana
Louisiana Department of Health
Office of Public Health

October 26, 2020

Mrs. Keisha L. Netterville
Superintendent of Schools
East Feliciana Parish School Board
P.O. Box 397
Clinton, LA 70722-0397

RE: Results of School Drinking Water Testing
Slaughter Elementary School (SCH019009)
3170 Church Street, Slaughter, LA 70777

Dear Mrs. Netterville,

Act 632 of the 2018 Regular Session required the Louisiana Department of Health (LDH) to establish a pilot program for drinking water testing at 12 public elementary schools that were constructed prior to 1986 or which may otherwise be susceptible to drinking water contamination. Thank you for your participation and cooperation in this pilot program.

On October 21, 2020 a total of 24 water samples were collected from the above referenced school in accordance with guidance provided in the Environmental Protection Agency's (EPA's) - 3Ts for Reducing Lead in Drinking Water in Schools Manual. Attached are the lead and copper sample results. Please note that the sample result for sample point ID "TCR-005" is for a sample collected from the water system.

All sample results were evaluated against the state recommended Action Levels for Lead (0.015 mg/L) and Copper (1.3 mg/L) for drinking water. All sample results are below the state recommended Action Levels for Lead and Copper.

Although these results indicate no exceedance of the lead action level (0.015 mg/L) in the school drinking water, LDH recommends that all schools follow the guidance provided in the EPA-3Ts manual to safeguard against lead in the drinking water. The EPA-3Ts manual was developed to assist schools with lead in drinking water prevention programs. This guidance is intended for use by school officials responsible for the maintenance and/or safety of school's drinking water. This document along with other helpful information is available for on EPA's website at: <https://www.epa.gov/dwreginfo/3ts-reducing-lead-drinking-water-schools-and-child-care-facilities>.

October 26, 2020

Page 2

RE: Results of School Drinking Water Testing
Slaughter Elementary School (SCH019009)

Please notify this office of any control or remediation measures taken by the school. LDH will perform follow up sampling to confirm the corrective actions were effective.

Please feel free to contact me or Caryn Benjamin regarding any of the enclosed information.

Sincerely,



Amanda Ames, P.E.
Chief Engineer and Safe Drinking Water Administrator, LDH

Attachments

cc: Ms. Kim Glacock, Principal, Slaughter Elementary School

Sample Results Summary

Slaughter Elementary (SCH019009)		Lead (mg/L) AL = 0.015 mg/L		Copper (mg/L) AL = 1.3 mg/L	
Sample Point Description and ID		First Draw Sample	After Flush Sample	First Draw Sample	After Flush Sample
TANK FOUNTAIN, RM 209 LEFT SIDE	DF01	ND	ND	0.2	ND
TANK FOUNTAIN. RM 209., RIGHT SIDE	DF02	0.004	ND	0.4	ND
TANK FOUNTAIN, RM 105, LEFT SIDE	DF03	0.001	ND	0.2	ND
TANK FOUNTAIN, RM 105, RIGHT SIDE	DF04	0.002	ND	ND	ND
POT FILLER, SWING FAUCET	PF01	ND	ND	ND	ND
3C, KITCHEN, MAIN WALL	SK01	0.002	ND	0.2	ND
"ND" - None Detect - contaminant level is below the Laboratory Reporting limit (<0.001 mg/L Lead or <0.1 mg/L Copper)					
"AL" - Action Level - state recommended action level					



State of Louisiana
Louisiana Department of Health
Public Health Laboratories
1209 Leesville Avenue
Baton Rouge, LA 70802
225-219-5200
<http://www.dhh.la.gov/lab>



October 26, 2020

The following analytical results have been obtained for the indicated sample(s) which was submitted to this laboratory:

Sample Pt. Description:	170 GRAVES ST.	Sample ID:	B2005512-001
Sample Pt ID:	TCR-005	Sample Type:	Special
PWS ID:	LA1037008	Sample Collector:	Broussard
Water System Name:	TOWN OF SLAUGHTER WATER SYSTEM	Collection date:	10/21/2020 8:56:00AM
Facility ID:	DS0950	Lab Submittal date:	10/21/2020 2:15:00PM
Collection Address:	Distribution		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, RM 209 LEFT SIDE	Sample ID:	B2005512-002
Sample Pt ID:	DF01	Sample Type:	Special
PWS ID:	LA1037008	Sample Collector:	Broussard
Water System Name:	TOWN OF SLAUGHTER WATER SYSTEM	Collection date:	10/21/2020 8:11:00AM
Facility ID:	SCH019009	Lab Submittal date:	10/21/2020 2:15:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.2	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN. RM 209., RIGHT SIDE	Sample ID:	B2005512-003
Sample Pt ID:	DF02	Sample Type:	Special
PWS ID:	LA1037008	Sample Collector:	Broussard
Water System Name:	TOWN OF SLAUGHTER WATER SYSTEM	Collection date:	10/21/2020 8:11:00AM
Facility ID:	SCH019009	Lab Submittal date:	10/21/2020 2:15:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.004	mg/L	0.001	0.015	
Copper	0.4	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, RM 105, LEFT SIDE	Sample ID:	B2005512-004
Sample Pt ID:	DF03	Sample Type:	Special
PWS ID:	LA1037008	Sample Collector:	Broussard
Water System Name:	TOWN OF SLAUGHTER WATER SYSTEM	Collection date:	10/21/2020 8:21:00AM
Facility ID:	SCH019009	Lab Submittal date:	10/21/2020 2:15:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.001	mg/L	0.001	0.015	
Copper	0.2	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, RM 105, RIGHT SIDE	Sample ID:	B2005512-005
Sample Pt ID:	DF04	Sample Type:	Special
PWS ID:	LA1037008	Sample Collector:	Broussard
Water System Name:	TOWN OF SLAUGHTER WATER SYSTEM	Collection date:	10/21/2020 8:17:00AM
Facility ID:	SCH019009	Lab Submittal date:	10/21/2020 2:15:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.002	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

Sample Pt. Description:	POT FILLER, SWING FAUCET	Sample ID:	B2005512-006
Sample Pt ID:	PF01	Sample Type:	Special
PWS ID:	LA1037008	Sample Collector:	Broussard
Water System Name:	TOWN OF SLAUGHTER WATER SYSTEM	Collection date:	10/21/2020 8:05:00AM
Facility ID:	SCH019009	Lab Submittal date:	10/21/2020 2:15:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

Sample Pt. Description:	3C, KITCHEN, MAIN WALL	Sample ID:	B2005512-007
Sample Pt ID:	SK01	Sample Type:	Special
PWS ID:	LA1037008	Sample Collector:	Broussard
Water System Name:	TOWN OF SLAUGHTER WATER SYSTEM	Collection date:	10/21/2020 8:06:00AM
Facility ID:	SCH019009	Lab Submittal date:	10/21/2020 2:15:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.002	mg/L	0.001	0.015	
Copper	0.2	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, RM 209 LEFT SIDE	Sample ID:	B2005512-008
Sample Pt ID:	DF01	Sample Type:	Special
PWS ID:	LA1037008	Sample Collector:	Broussard
Water System Name:	TOWN OF SLAUGHTER WATER SYSTEM	Collection date:	10/21/2020 3:47:00PM
Facility ID:	SCH019009	Lab Submittal date:	10/22/2020 8:15:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN. RM 209., RIGHT SIDE	Sample ID:	B2005512-009
Sample Pt ID:	DF02	Sample Type:	Special
PWS ID:	LA1037008	Sample Collector:	Broussard
Water System Name:	TOWN OF SLAUGHTER WATER SYSTEM	Collection date:	10/21/2020 3:47:00PM
Facility ID:	SCH019009	Lab Submittal date:	10/22/2020 8:15:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, RM 105, LEFT SIDE	Sample ID:	B2005512-010
Sample Pt ID:	DF03	Sample Type:	Special
PWS ID:	LA1037008	Sample Collector:	Broussard
Water System Name:	TOWN OF SLAUGHTER WATER SYSTEM	Collection date:	10/21/2020 3:27:00PM
Facility ID:	SCH019009	Lab Submittal date:	10/22/2020 8:15:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, RM 105, RIGHT SIDE	Sample ID:	B2005512-011
Sample Pt ID:	DF04	Sample Type:	Special
PWS ID:	LA1037008	Sample Collector:	Broussard
Water System Name:	TOWN OF SLAUGHTER WATER SYSTEM	Collection date:	10/21/2020 3:28:00PM
Facility ID:	SCH019009	Lab Submittal date:	10/22/2020 8:15:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

Sample Pt. Description:	POT FILLER, SWING FAUCET	Sample ID:	B2005512-012
Sample Pt ID:	PF01	Sample Type:	Special
PWS ID:	LA1037008	Sample Collector:	Broussard
Water System Name:	TOWN OF SLAUGHTER WATER SYSTEM	Collection date:	10/21/2020 3:51:00PM
Facility ID:	SCH019009	Lab Submittal date:	10/22/2020 8:15:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

Sample Pt. Description:	3C, KITCHEN, MAIN WALL	Sample ID:	B2005512-013
Sample Pt ID:	SK01	Sample Type:	Special
PWS ID:	LA1037008	Sample Collector:	Broussard
Water System Name:	TOWN OF SLAUGHTER WATER SYSTEM	Collection date:	10/21/2020 3:52:00PM
Facility ID:	SCH019009	Lab Submittal date:	10/22/2020 8:15:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

Reviewed by: Aaron Hawkins