



# State of Louisiana

Louisiana Department of Health  
Office of Public Health

October 16, 2019

Voleria Millikin, Ph.D.  
Superintendent of Schools  
East Carroll Parish School Board  
P.O. Box 792, Lake Providence, LA 71254

RE: Results of School Drinking Water Lead Testing  
Southside Elementary School (SCH018005)  
1307 Gould Street, Lake Providence, LA 71254  
Griffin Middle School Academy (SCH018001)  
1205 Gould Street, Lake Providence, LA 71254

Dear Dr. Millikin,

Act 632 of the 2018 Regular Session required the Louisiana Department of Health (LDH) to establish a pilot program for drinking water testing at 12 public elementary schools that were constructed prior to 1986 or which may otherwise be susceptible to drinking water contamination. Thank you for your participation and cooperation in this pilot program.

On September 13, 2019 and October 11 and 12, 2019 a total of 58 water samples were collected from the above referenced schools in accordance with guidance provided in the Environmental Protection Agency's (EPA's) - 3Ts Manual for Reducing Lead in Drinking Water in Schools. Attached are the lead and copper sample results. Please note that the sample result for sample point ID "TCR-011" is for a sample collected from the water system.

All sample results were below the state recommended action level of 0.015 mg/L for lead. However, there are several drinking fountains that exceeded the state recommended action level of 1.3 mg/L for copper in both sampling events. LDH advised the school that replacing some fountains and related plumbing may help reduce copper levels. LDH also advised the school to perform a daily flush prior to use of each water outlet in the Griffin kitchen used for food preparation to reduce lead levels. Refer to the EPA-3Ts Manual for all remediation/control measures.

Although these results indicate no exceedance of the lead action level (0.015 mg/L) in the school drinking water, LDH recommends that all schools follow the guidance provided in the EPA-3Ts manual to safeguard against lead in the drinking water. The EPA-3Ts manual was developed to assist schools with lead in drinking water prevention programs. This guidance is intended for use by school officials responsible for the maintenance and/or safety of school's drinking water. This document along with other helpful information is available for on EPA's website at: <https://www.epa.gov/dwreginfo/3ts-reducing-lead-drinking-water-schools-and-child-care-facilities>.

October 16, 2019

Page 2

RE: Results of School Drinking Water Testing  
Southside Elementary School (SCH018005)  
Griffin Middle School Academy (SCH018001)

Please notify this office of any control or remediation measures taken by the school. LDH will perform follow up sampling to confirm the corrective actions were effective.

Please feel free to contact me regarding any of the enclosed information.

Sincerely,



Amanda Ames, P.E.

Chief Engineer and Safe Drinking Water Administrator, LDH

Attachments

cc: Muriel Williams, Principal, Southside Elementary School  
Christopher Smith, Principal, Griffin Middle School



**State of Louisiana**  
 Louisiana Department of Health  
 Public Health Laboratories  
 1209 Leesville Avenue  
 Baton Rouge, LA 70802  
 225-219-5200  
<http://www.dhh.la.gov/lab>



September 16, 2019

The following analytical results have been obtained for the indicated sample(s) which was submitted to this laboratory:

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, CAFETERIA	Sample ID:	B1904066-001
<b>Sample Pt ID:</b>	DF01	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Lollis, Tyler
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 5:43:00AM
Facility ID:	SCH018005	Lab Submittal date:	9/13/2019 4:20:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.002	mg/L	0.001	0.015	
Copper	1.7	mg/L	0.1	1.3	> MCL

<b>Sample Pt. Description:</b>	BI-LEVEL WATER COOLER, HIGH, S. WING	Sample ID:	B1904066-002
<b>Sample Pt ID:</b>	DF02	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Lollis, Tyler
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 6:09:00AM
Facility ID:	SCH018005	Lab Submittal date:	9/13/2019 4:20:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.4	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	BI-LEVEL WATER COOLER, LOW, S. WING	Sample ID:	B1904066-003
<b>Sample Pt ID:</b>	DF03	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Lollis, Tyler
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 6:10:00AM
Facility ID:	SCH018005	Lab Submittal date:	9/13/2019 4:20:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.6	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, LEFT, N. WING, E. END	Sample ID:	B1904066-004
<b>Sample Pt ID:</b>	DF04	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Lollis, Tyler
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 5:48:00AM
Facility ID:	SCH018005	Lab Submittal date:	9/13/2019 4:20:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.6	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, RIGHT, N. WING, E. END	Sample ID:	B1904066-005
<b>Sample Pt ID:</b>	DF05	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Lollis, Tyler
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 5:49:00AM
Facility ID:	SCH018005	Lab Submittal date:	9/13/2019 4:20:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.7	mg/L	0.1	1.3	> 1/2 MCL

<b>Sample Pt. Description:</b>	BI-LEVEL WTR COOLR, HIGH, N WING, W END	Sample ID:	B1904066-006
<b>Sample Pt ID:</b>	DF06	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Lollis, Tyler
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 6:02:00AM
Facility ID:	SCH018005	Lab Submittal date:	9/13/2019 4:20:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.6	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	BI-LEVEL WTR COOLER, LOW, N WING, W END	Sample ID:	B1904066-007
<b>Sample Pt ID:</b>	DF07	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Lollis, Tyler
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 6:03:00AM
Facility ID:	SCH018005	Lab Submittal date:	9/13/2019 4:20:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.7	mg/L	0.1	1.3	> 1/2 MCL

<b>Sample Pt. Description:</b>	LEFT 3-COMPARTMENT SINK, KITCHEN	Sample ID:	B1904066-008
<b>Sample Pt ID:</b>	SK01	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Lollis, Tyler
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 5:38:00AM
Facility ID:	SCH018005	Lab Submittal date:	9/13/2019 4:20:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.003	mg/L	0.001	0.015	
Copper	0.7	mg/L	0.1	1.3	> 1/2 MCL

<b>Sample Pt. Description:</b>	RIGHT 3-COMPARTMENT SINK, KITCHEN	Sample ID:	B1904066-009
<b>Sample Pt ID:</b>	SK02	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Lollis, Tyler
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 5:40:00AM
Facility ID:	SCH018005	Lab Submittal date:	9/13/2019 4:20:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.003	mg/L	0.001	0.015	
Copper	0.8	mg/L	0.1	1.3	> 1/2 MCL

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, CAFETERIA	Sample ID:	B1904066-010
<b>Sample Pt ID:</b>	DF01	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Lollis, Tyler
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 5:59:00AM
Facility ID:	SCH018005	Lab Submittal date:	9/13/2019 4:20:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	1.9	mg/L	0.1	1.3	> MCL

<b>Sample Pt. Description:</b>	BI-LEVEL WATER COOLER, HIGH, S. WING	Sample ID:	B1904066-011
<b>Sample Pt ID:</b>	DF02	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Lollis, Tyler
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 6:25:00AM
Facility ID:	SCH018005	Lab Submittal date:	9/13/2019 4:20:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.7	mg/L	0.1	1.3	> 1/2 MCL

<b>Sample Pt. Description:</b>	BI-LEVEL WATER COOLER, LOW, S. WING	Sample ID:	B1904066-012
<b>Sample Pt ID:</b>	DF03	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Lollis, Tyler
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 6:26:00AM
Facility ID:	SCH018005	Lab Submittal date:	9/13/2019 4:20:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.7	mg/L	0.1	1.3	> 1/2 MCL

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, LEFT, N. WING, E. END	Sample ID:	B1904066-013
<b>Sample Pt ID:</b>	DF04	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Lollis, Tyler
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 6:05:00AM
Facility ID:	SCH018005	Lab Submittal date:	9/13/2019 4:20:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	1.7	mg/L	0.1	1.3	> MCL

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, RIGHT, N. WING, E. END	Sample ID:	B1904066-014
<b>Sample Pt ID:</b>	DF05	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Lollis, Tyler
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 6:05:00AM
Facility ID:	SCH018005	Lab Submittal date:	9/13/2019 4:20:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	1.7	mg/L	0.1	1.3	> MCL

<b>Sample Pt. Description:</b>	BI-LEVEL WTR COOLR, HIGH, N WING, W END	Sample ID:	B1904066-015
<b>Sample Pt ID:</b>	DF06	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Lollis, Tyler
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 6:19:00AM
Facility ID:	SCH018005	Lab Submittal date:	9/13/2019 4:20:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	1.3	mg/L	0.1	1.3	> MCL

<b>Sample Pt. Description:</b>	BI-LEVEL WTR COOLER, LOW, N WING, W END	Sample ID:	B1904066-016
<b>Sample Pt ID:</b>	DF07	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Lollis, Tyler
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 6:20:00AM
Facility ID:	SCH018005	Lab Submittal date:	9/13/2019 4:20:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
<b>Copper</b>	<b>1.3</b>	mg/L	0.1	1.3	> MCL

<b>Sample Pt. Description:</b>	LEFT 3-COMPARTMENT SINK, KITCHEN	Sample ID:	B1904066-017
<b>Sample Pt ID:</b>	SK01	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Lollis, Tyler
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 5:39:00AM
Facility ID:	SCH018005	Lab Submittal date:	9/13/2019 4:20:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.3	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	RIGHT 3-COMPARTMENT SINK, KITCHEN	Sample ID:	B1904066-018
<b>Sample Pt ID:</b>	SK02	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Lollis, Tyler
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 5:41:00AM
Facility ID:	SCH018005	Lab Submittal date:	9/13/2019 4:20:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.4	mg/L	0.1	1.3	

**Qualifier Key**

Qualifier	Description
> 1/2 MCL	Final Result > 1/2 MCL but < MCL
> MCL	Final Result Above MCL

Reviewed by: Aaron Hawkins



State of Louisiana  
Louisiana Department of Health  
Public Health Laboratories  
1209 Leesville Avenue  
Baton Rouge, LA 70802  
225-219-5200  
<http://www.dhh.la.gov/lab>



October 15, 2019

The following analytical results have been obtained for the indicated sample(s) which was submitted to this laboratory:

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, CAFETERIA	<b>Sample ID:</b>	B1904589-001
<b>Sample Pt ID:</b>	DF01	<b>Sample Type:</b>	Special
<b>PWS ID:</b>	LA1035002	<b>Sample Collector:</b>	Morris
<b>Water System Name:</b>	LAKE PROVIDENCE WATER SYSTEM	<b>Collection date:</b>	10/11/2019 5:44:00AM
<b>Facility ID:</b>	SCH018005	<b>Lab Submittal date:</b>	10/11/2019 1:30:00PM
<b>Collection Address:</b>	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.6	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, LEFT, N. WING, E. END	<b>Sample ID:</b>	B1904589-002
<b>Sample Pt ID:</b>	DF04	<b>Sample Type:</b>	Special
<b>PWS ID:</b>	LA1035002	<b>Sample Collector:</b>	Morris
<b>Water System Name:</b>	LAKE PROVIDENCE WATER SYSTEM	<b>Collection date:</b>	10/11/2019 6:09:00AM
<b>Facility ID:</b>	SCH018005	<b>Lab Submittal date:</b>	10/11/2019 1:30:00PM
<b>Collection Address:</b>	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.001	mg/L	0.001	0.015	
Copper	1.8	mg/L	0.1	1.3	> MCL

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, RIGHT, N. WING, E. END	<b>Sample ID:</b>	B1904589-003
<b>Sample Pt ID:</b>	DF05	<b>Sample Type:</b>	Special
<b>PWS ID:</b>	LA1035002	<b>Sample Collector:</b>	Morris
<b>Water System Name:</b>	LAKE PROVIDENCE WATER SYSTEM	<b>Collection date:</b>	10/11/2019 6:06:00AM
<b>Facility ID:</b>	SCH018005	<b>Lab Submittal date:</b>	10/11/2019 1:30:00PM
<b>Collection Address:</b>	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	1.1	mg/L	0.1	1.3	> 1/2 MCL



<b>Sample Pt. Description:</b>	TANK FOUNTAIN, CAFETERIA	Sample ID:	B1904589-004
<b>Sample Pt ID:</b>	DF01	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Morris
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	10/11/2019 5:59:00AM
Facility ID:	SCH018005	Lab Submittal date:	10/11/2019 1:30:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
<b>Copper</b>	<b>1.6</b>	mg/L	0.1	1.3	> MCL

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, LEFT, N. WING, E. END	Sample ID:	B1904589-005
<b>Sample Pt ID:</b>	DF04	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Morris
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	10/11/2019 6:24:00AM
Facility ID:	SCH018005	Lab Submittal date:	10/11/2019 1:30:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
<b>Copper</b>	<b>1.8</b>	mg/L	0.1	1.3	> MCL

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, RIGHT, N. WING, E. END	Sample ID:	B1904589-006
<b>Sample Pt ID:</b>	DF05	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Morris
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	10/11/2019 6:21:00AM
Facility ID:	SCH018005	Lab Submittal date:	10/11/2019 1:30:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
<b>Copper</b>	<b>1.8</b>	mg/L	0.1	1.3	> MCL

**Qualifier Key**

Qualifier	Description
> 1/2 MCL	Final Result > 1/2 MCL but < MCL
> MCL	Final Result Above MCL

Reviewed by: Aaron Hawkins



State of Louisiana  
Louisiana Department of Health  
Public Health Laboratories  
1209 Leesville Avenue  
Baton Rouge, LA 70802  
225-219-5200  
<http://www.dhh.la.gov/lab>



September 17, 2019

The following analytical results have been obtained for the indicated sample(s) which was submitted to this laboratory:

<b>Sample Pt. Description:</b>	POT FILLER	Sample ID:	B1904063-001
<b>Sample Pt ID:</b>	PF01	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Ray, Steve
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 5:42:00AM
Facility ID:	SCH018001	Lab Submittal date:	9/13/2019 4:20:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.007	mg/L	0.001	0.015	
Copper	1.0	mg/L	0.1	1.3	> 1/2 MCL

<b>Sample Pt. Description:</b>	BI-LEVEL WTR COOLR, LOW, E WING, S END	Sample ID:	B1904063-002
<b>Sample Pt ID:</b>	DF04	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Ray, Steve
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 6:37:00AM
Facility ID:	SCH018001	Lab Submittal date:	9/13/2019 4:20:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.6	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	RIGHT 3-COMPT SINK, KITCHEN (GRIFFIN)	Sample ID:	B1904063-003
<b>Sample Pt ID:</b>	SK02	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Ray, Steve
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 5:37:00AM
Facility ID:	SCH018001	Lab Submittal date:	9/13/2019 4:20:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.012	mg/L	0.001	0.015	> 1/2 MCL
Copper	0.8	mg/L	0.1	1.3	> 1/2 MCL

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, LOCKER RM, WEST WING	Sample ID:	B1904063-008
<b>Sample Pt ID:</b>	DF11	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Ray, Steve
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 6:18:00AM
Facility ID:	SCH018001	Lab Submittal date:	9/13/2019 4:20:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.007	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	LEFT 3-COMPT SINK, KITCHEN (GRIFFIN)	Sample ID:	B1904063-009
<b>Sample Pt ID:</b>	SK01	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Ray, Steve
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 5:36:00AM
Facility ID:	SCH018001	Lab Submittal date:	9/13/2019 4:20:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.014	mg/L	0.001	0.015	> 1/2 MCL
Copper	0.7	mg/L	0.1	1.3	> 1/2 MCL

<b>Sample Pt. Description:</b>	POT FILLER	Sample ID:	B1904063-010
<b>Sample Pt ID:</b>	PF01	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Ray, Steve
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 5:43:00AM
Facility ID:	SCH018001	Lab Submittal date:	9/13/2019 4:20:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.002	mg/L	0.001	0.015	
Copper	0.7	mg/L	0.1	1.3	> 1/2 MCL

<b>Sample Pt. Description:</b>	BI-LEVEL WTR COOLR, LOW, E WING, S END	Sample ID:	B1904063-011
<b>Sample Pt ID:</b>	DF04	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Ray, Steve
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 6:53:00AM
Facility ID:	SCH018001	Lab Submittal date:	9/13/2019 4:20:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	1.8	mg/L	0.1	1.3	> MCL

<b>Sample Pt. Description:</b>	RIGHT 3-COMPT SINK, KITCHEN (GRIFFIN)	Sample ID:	B1904063-012
<b>Sample Pt ID:</b>	SK02	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Ray, Steve
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 5:40:00AM
Facility ID:	SCH018001	Lab Submittal date:	9/13/2019 4:20:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.002	mg/L	0.001	0.015	
Copper	0.6	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	BI-LEVEL WTR COOLR, LOW, W WING, N END	Sample ID:	B1904063-013
<b>Sample Pt ID:</b>	DF07	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Ray, Steve
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 6:07:00AM
Facility ID:	SCH018001	Lab Submittal date:	9/13/2019 4:20:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.5	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	BI-LEVEL WTR COOLR, HIGH, W WING, N ENCS	Sample ID:	B1904063-014
<b>Sample Pt ID:</b>	DF08	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Ray, Steve
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 6:08:00AM
Facility ID:	SCH018001	Lab Submittal date:	9/13/2019 4:20:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.5	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	BI-LEVEL WTR COOLR, LOW, W WING, S END	Sample ID:	B1904063-015
<b>Sample Pt ID:</b>	DF09	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Ray, Steve
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 6:11:00AM
Facility ID:	SCH018001	Lab Submittal date:	9/13/2019 4:20:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
<b>Copper</b>	<b>1.6</b>	mg/L	0.1	1.3	> MCL

<b>Sample Pt. Description:</b>	BI-LEVEL WTR COOLR, HIGH, W WING, S ENDS	Sample ID:	B1904063-016
<b>Sample Pt ID:</b>	DF10	Sample Type:	Special
<b>PWS ID:</b>	LA1035002	Sample Collector:	Ray, Steve
<b>Water System Name:</b>	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 6:12:00AM
<b>Facility ID:</b>	SCH018001	Lab Submittal date:	9/13/2019 4:20:00PM
<b>Collection Address:</b>	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
<b>Copper</b>	<b>1.6</b>	mg/L	0.1	1.3	> MCL

<b>Sample Pt. Description:</b>	TANK FOUNTAIN, LOCKER RM, WEST WING	Sample ID:	B1904063-017
<b>Sample Pt ID:</b>	DF11	Sample Type:	Special
<b>PWS ID:</b>	LA1035002	Sample Collector:	Ray, Steve
<b>Water System Name:</b>	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 6:34:00AM
<b>Facility ID:</b>	SCH018001	Lab Submittal date:	9/13/2019 4:20:00PM
<b>Collection Address:</b>	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.001	mg/L	0.001	0.015	
Copper	0.4	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	LEFT 3-COMPT SINK, KITCHEN (GRIFFIN)	Sample ID:	B1904063-018
<b>Sample Pt ID:</b>	SK01	Sample Type:	Special
<b>PWS ID:</b>	LA1035002	Sample Collector:	Ray, Steve
<b>Water System Name:</b>	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 5:38:00AM
<b>Facility ID:</b>	SCH018001	Lab Submittal date:	9/13/2019 4:20:00PM
<b>Collection Address:</b>	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	0.002	mg/L	0.001	0.015	
Copper	0.7	mg/L	0.1	1.3	> 1/2 MCL

<b>Sample Pt. Description:</b>	350 MILLS ST	Sample ID:	B1904063-019
<b>Sample Pt ID:</b>	TCR-011	Sample Type:	Special
<b>PWS ID:</b>	LA1035002	Sample Collector:	Ray, Steve
<b>Water System Name:</b>	LAKE PROVIDENCE WATER SYSTEM	Collection date:	9/13/2019 7:26:00AM
<b>Facility ID:</b>	DS0950	Lab Submittal date:	9/13/2019 4:20:00PM
<b>Collection Address:</b>	Distribution		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

**Qualifier Key**

<u>Qualifier</u>	<u>Description</u>
> 1/2 MCL	Final Result > 1/2 MCL but < MCL
> MCL	Final Result Above MCL

Reviewed by: Aaron Hawkins



State of Louisiana  
Louisiana Department of Health  
Public Health Laboratories  
1209 Leesville Avenue  
Baton Rouge, LA 70802  
225-219-5200  
<http://www.dhh.la.gov/lab>



October 15, 2019

The following analytical results have been obtained for the indicated sample(s) which was submitted to this laboratory:

<b>Sample Pt. Description:</b>	BI-LEVEL WTR COOLR, LOW, E WING, N END	<b>Sample ID:</b>	B1904588-001
<b>Sample Pt ID:</b>	DF01	<b>Sample Type:</b>	Special
<b>PWS ID:</b>	LA1035002	<b>Sample Collector:</b>	Ray
<b>Water System Name:</b>	LAKE PROVIDENCE WATER SYSTEM	<b>Collection date:</b>	10/10/2019 5:51:00AM
<b>Facility ID:</b>	SCH018001	<b>Lab Submittal date:</b>	10/11/2019 1:30:00PM
<b>Collection Address:</b>	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.6	mg/L	0.1	1.3	

<b>Sample Pt. Description:</b>	WATER COOLER, EAST WING, NORTH SIDE-MID	<b>Sample ID:</b>	B1904588-002
<b>Sample Pt ID:</b>	DF03	<b>Sample Type:</b>	Special
<b>PWS ID:</b>	LA1035002	<b>Sample Collector:</b>	Ray
<b>Water System Name:</b>	LAKE PROVIDENCE WATER SYSTEM	<b>Collection date:</b>	10/10/2019 5:48:00AM
<b>Facility ID:</b>	SCH018001	<b>Lab Submittal date:</b>	10/11/2019 1:30:00PM
<b>Collection Address:</b>	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	1.8	mg/L	0.1	1.3	> MCL

<b>Sample Pt. Description:</b>	BI-LEVEL WTR COOLR, LOW, E WING, S END	<b>Sample ID:</b>	B1904588-003
<b>Sample Pt ID:</b>	DF04	<b>Sample Type:</b>	Special
<b>PWS ID:</b>	LA1035002	<b>Sample Collector:</b>	Ray
<b>Water System Name:</b>	LAKE PROVIDENCE WATER SYSTEM	<b>Collection date:</b>	10/10/2019 6:12:00AM
<b>Facility ID:</b>	SCH018001	<b>Lab Submittal date:</b>	10/11/2019 1:30:00PM
<b>Collection Address:</b>	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	1.7	mg/L	0.1	1.3	> MCL

<b>Sample Pt. Description:</b>	BI-LEVEL WTR COOLR, HIGH, E WING, S END	Sample ID:	B1904588-004
<b>Sample Pt ID:</b>	DF05	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Ray
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	10/10/2019 5:45:00AM
Facility ID:	SCH018001	Lab Submittal date:	10/11/2019 1:30:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
<b>Copper</b>	<b>1.4</b>	mg/L	0.1	1.3	> MCL

<b>Sample Pt. Description:</b>	BI-LEVEL WTR COOLR, LOW, W WING, N END	Sample ID:	B1904588-005
<b>Sample Pt ID:</b>	DF07	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Ray
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	10/10/2019 6:10:00AM
Facility ID:	SCH018001	Lab Submittal date:	10/11/2019 1:30:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
<b>Copper</b>	<b>0.9</b>	mg/L	0.1	1.3	> 1/2 MCL

<b>Sample Pt. Description:</b>	BI-LEVEL WTR COOLR, HIGH, W WING, N END	Sample ID:	B1904588-006
<b>Sample Pt ID:</b>	DF08	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Ray
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	10/10/2019 6:11:00AM
Facility ID:	SCH018001	Lab Submittal date:	10/11/2019 1:30:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
<b>Copper</b>	<b>1.5</b>	mg/L	0.1	1.3	> MCL

<b>Sample Pt. Description:</b>	BI-LEVEL WTR COOLR, LOW, W WING, S END	Sample ID:	B1904588-007
<b>Sample Pt ID:</b>	DF09	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Ray
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	10/10/2019 6:33:00AM
Facility ID:	SCH018001	Lab Submittal date:	10/11/2019 1:30:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
<b>Copper</b>	<b>1.3</b>	mg/L	0.1	1.3	> MCL



<b>Sample Pt. Description:</b>	BI-LEVEL WTR COOLR, HIGH, W WING, S END	Sample ID:	B1904588-008
<b>Sample Pt ID:</b>	DF10	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Ray
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	10/10/2019 6:32:00AM
Facility ID:	SCH018001	Lab Submittal date:	10/11/2019 1:30:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.9	mg/L	0.1	1.3	> 1/2 MCL

<b>Sample Pt. Description:</b>	BI-LEVEL WTR COOLR, LOW, E WING, N END	Sample ID:	B1904588-009
<b>Sample Pt ID:</b>	DF01	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Ray
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	10/10/2019 6:06:00AM
Facility ID:	SCH018001	Lab Submittal date:	10/11/2019 1:30:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.7	mg/L	0.1	1.3	> 1/2 MCL

<b>Sample Pt. Description:</b>	WATER COOLER, EAST WING, NORTH SIDE-MID	Sample ID:	B1904588-010
<b>Sample Pt ID:</b>	DF03	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Ray
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	10/10/2019 6:03:00AM
Facility ID:	SCH018001	Lab Submittal date:	10/11/2019 1:30:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.7	mg/L	0.1	1.3	> 1/2 MCL

<b>Sample Pt. Description:</b>	BI-LEVEL WTR COOLR, LOW, E WING, S END	Sample ID:	B1904588-011
<b>Sample Pt ID:</b>	DF04	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Ray
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	10/10/2019 6:30:00AM
Facility ID:	SCH018001	Lab Submittal date:	10/11/2019 1:30:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
Copper	1.0	mg/L	0.1	1.3	> 1/2 MCL

<b>Sample Pt. Description:</b>	BI-LEVEL WTR COOLR, HIGH, E WING, S END	Sample ID:	B1904588-012
<b>Sample Pt ID:</b>	DF05	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Ray
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	10/10/2019 6:00:00AM
Facility ID:	SCH018001	Lab Submittal date:	10/11/2019 1:30:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
<b>Copper</b>	<b>1.7</b>	mg/L	0.1	1.3	> MCL

<b>Sample Pt. Description:</b>	BI-LEVEL WTR COOLR, LOW, W WING, N END	Sample ID:	B1904588-013
<b>Sample Pt ID:</b>	DF07	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Ray
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	10/10/2019 6:25:00AM
Facility ID:	SCH018001	Lab Submittal date:	10/11/2019 1:30:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
<b>Copper</b>	<b>0.8</b>	mg/L	0.1	1.3	> 1/2 MCL

<b>Sample Pt. Description:</b>	BI-LEVEL WTR COOLR, HIGH, W WING, N END	Sample ID:	B1904588-014
<b>Sample Pt ID:</b>	DF08	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Ray
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	10/10/2019 6:26:00AM
Facility ID:	SCH018001	Lab Submittal date:	10/11/2019 1:30:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
<b>Copper</b>	<b>0.8</b>	mg/L	0.1	1.3	> 1/2 MCL

<b>Sample Pt. Description:</b>	BI-LEVEL WTR COOLR, LOW, W WING, S END	Sample ID:	B1904588-015
<b>Sample Pt ID:</b>	DF09	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Ray
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	10/10/2019 6:49:00AM
Facility ID:	SCH018001	Lab Submittal date:	10/11/2019 1:30:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
<b>Copper</b>	<b>1.6</b>	mg/L	0.1	1.3	> MCL

<b>Sample Pt. Description:</b>	BI-LEVEL WTR COOLR, HIGH, W WING, S END	Sample ID:	B1904588-016
<b>Sample Pt ID:</b>	DF10	Sample Type:	Special
PWS ID:	LA1035002	Sample Collector:	Ray
Water System Name:	LAKE PROVIDENCE WATER SYSTEM	Collection date:	10/10/2019 6:48:00AM
Facility ID:	SCH018001	Lab Submittal date:	10/11/2019 1:30:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
<b>Lead and Copper (200.8)</b>					
Lead	<0.001	mg/L	0.001	0.015	
<b>Copper</b>	<b>1.5</b>	mg/L	0.1	1.3	> MCL

**Qualifier Key**

Qualifier	Description
> 1/2 MCL	Final Result > 1/2 MCL but < MCL
> MCL	Final Result Above MCL

Reviewed by: Aaron Hawkins