



State of Louisiana
Louisiana Department of Health
Office of Public Health

September 25, 2019

Mr. Al Blanchard
Superintendent of Schools
St. Martin Parish School Board
P.O. Box 1000
Breaux Bridge, LA 70517

RE: Results of School Drinking Water Testing
St. Martinville Primary School (SCH05016)
716 N. Main Street, St. Martinville, LA 70582

Dear Mr. Blanchard,

Act 632 of the 2018 Regular Session required the Louisiana Department of Health (LDH) to establish a pilot program for drinking water testing at 12 public elementary schools that were constructed prior to 1986 or which may otherwise be susceptible to drinking water contamination. Thank you for your participation and cooperation in this pilot program.

On September 20 and 24, 2019 a total of 26 water samples were collected from the above referenced school in accordance with guidance provided in the Environmental Protection Agency's (EPA's) - 3Ts for Reducing Lead in Drinking Water in Schools Manual. Attached are the lead and copper sample results. Please note that the sample result for sample point ID "TCR-008" is for a sample collected from the water system.

All sample results are below the state recommended action level of 0.015 mg/L for lead and 1.3 mg/L for copper for drinking water.

Although these results indicate no exceedance of lead action level (0.015 mg/L) in the school drinking water, LDH recommends that all schools follow the guidance provided in the EPA-3Ts manual to safeguard against lead in the drinking water. The EPA-3Ts manual was developed to assist schools with lead in drinking water prevention programs. This guidance is intended for use by school officials responsible for the maintenance and/or safety of school's drinking water. This document along with other helpful information is available for on EPA's website at: <https://www.epa.gov/dwreginfo/3ts-reducing-lead-drinking-water-schools-and-child-care-facilities>.

Please feel free to contact me regarding any of the enclosed information.

Sincerely,

A handwritten signature in blue ink, appearing to read "Amanda Ames".

Amanda Ames, P.E.
Chief Engineer and Safe Drinking Water Administrator, LDH

Attachment

cc: Ms. Lisa Sylvester, Principal, St. Martinville Primary School



State of Louisiana
Louisiana Department of Health
Public Health Laboratories
1209 Leesville Avenue
Baton Rouge, LA 70802
225-219-5200
<http://www.dhh.la.gov/lab>



September 25, 2019

The following analytical results have been obtained for the indicated sample(s) which was submitted to this laboratory:

Sample Pt. Description:	120 OLIVIER ST	Sample ID:	B1904174-001
Sample Pt ID:	TCR-008	Sample Type:	Special
PWS ID:	LA1099007	Sample Collector:	Brent Bouy
Water System Name:	CITY OF ST MARTINVILLE WATER SYSTEM	Collection date:	9/20/2019 6:34:00AM
Facility ID:	DS0950	Lab Submittal date:	9/20/2019 4:00:00PM
Collection Address:			

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, HEALTH CENTER	Sample ID:	B1904174-002
Sample Pt ID:	DF01	Sample Type:	Special
PWS ID:	LA1099007	Sample Collector:	Brent Bouy
Water System Name:	CITY OF ST MARTINVILLE WATER SYSTEM	Collection date:	9/20/2019 5:30:00AM
Facility ID:	SCH050016	Lab Submittal date:	9/20/2019 4:00:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.4	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, BLDGA ENT, LT	Sample ID:	B1904174-003
Sample Pt ID:	DF02	Sample Type:	Special
PWS ID:	LA1099007	Sample Collector:	Brent Bouy
Water System Name:	CITY OF ST MARTINVILLE WATER SYSTEM	Collection date:	9/20/2019 5:10:00AM
Facility ID:	SCH050016	Lab Submittal date:	9/20/2019 4:00:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.3	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, BLDGA ENT, RT	Sample ID:	B1904174-004
Sample Pt ID:	DF03	Sample Type:	Special
PWS ID:	LA1099007	Sample Collector:	Brent Bouy
Water System Name:	CITY OF ST MARTINVILLE WATER SYSTEM	Collection date:	9/20/2019 5:04:00AM
Facility ID:	SCH050016	Lab Submittal date:	9/20/2019 4:00:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.2	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, CAFETERIA, LT	Sample ID:	B1904174-005
Sample Pt ID:	DF05	Sample Type:	Special
PWS ID:	LA1099007	Sample Collector:	Brent Bouy
Water System Name:	CITY OF ST MARTINVILLE WATER SYSTEM	Collection date:	9/20/2019 5:07:00AM
Facility ID:	SCH050016	Lab Submittal date:	9/20/2019 4:00:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, CAFETERIA, RT	Sample ID:	B1904174-006
Sample Pt ID:	DF06	Sample Type:	Special
PWS ID:	LA1099007	Sample Collector:	Brent Bouy
Water System Name:	CITY OF ST MARTINVILLE WATER SYSTEM	Collection date:	9/20/2019 5:09:00AM
Facility ID:	SCH050016	Lab Submittal date:	9/20/2019 4:00:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	1.2	mg/L	0.1	1.3	> 1/2 MCL

Sample Pt. Description:	TANK FOUNTAIN, BLDGB, RMB-3	Sample ID:	B1904174-007
Sample Pt ID:	DF09	Sample Type:	Special
PWS ID:	LA1099007	Sample Collector:	Brent Bouy
Water System Name:	CITY OF ST MARTINVILLE WATER SYSTEM	Collection date:	9/20/2019 5:12:00AM
Facility ID:	SCH050016	Lab Submittal date:	9/20/2019 4:00:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.4	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, GYM, SIDE HALL NR RR	Sample ID:	B1904174-008
Sample Pt ID:	DF14	Sample Type:	Special
PWS ID:	LA1099007	Sample Collector:	Brent Bouy
Water System Name:	CITY OF ST MARTINVILLE WATER SYSTEM	Collection date:	9/20/2019 5:02:00AM
Facility ID:	SCH050016	Lab Submittal date:	9/20/2019 4:00:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.001	mg/L	0.001	0.015	
Copper	0.5	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, BLDGC, RMC-7	Sample ID:	B1904174-009
Sample Pt ID:	DF15	Sample Type:	Special
PWS ID:	LA1099007	Sample Collector:	Brent Bouy
Water System Name:	CITY OF ST MARTINVILLE WATER SYSTEM	Collection date:	9/20/2019 5:04:00AM
Facility ID:	SCH050016	Lab Submittal date:	9/20/2019 4:00:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.3	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, BLDGC, RMC-14	Sample ID:	B1904174-010
Sample Pt ID:	DF16	Sample Type:	Special
PWS ID:	LA1099007	Sample Collector:	Brent Bouy
Water System Name:	CITY OF ST MARTINVILLE WATER SYSTEM	Collection date:	9/20/2019 5:05:00AM
Facility ID:	SCH050016	Lab Submittal date:	9/20/2019 4:00:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.6	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, HEALTH CENTER	Sample ID:	B1904174-011
Sample Pt ID:	DF01	Sample Type:	Special
PWS ID:	LA1099007	Sample Collector:	Brent Bouy
Water System Name:	CITY OF ST MARTINVILLE WATER SYSTEM	Collection date:	9/20/2019 5:45:00AM
Facility ID:	SCH050016	Lab Submittal date:	9/20/2019 4:00:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.2	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, BLDGA ENT, LT	Sample ID:	B1904174-012
Sample Pt ID:	DF02	Sample Type:	Special
PWS ID:	LA1099007	Sample Collector:	Brent Bouy
Water System Name:	CITY OF ST MARTINVILLE WATER SYSTEM	Collection date:	9/20/2019 5:47:00AM
Facility ID:	SCH050016	Lab Submittal date:	9/20/2019 4:00:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.2	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, BLDGA ENT, RT	Sample ID:	B1904174-013
Sample Pt ID:	DF03	Sample Type:	Special
PWS ID:	LA1099007	Sample Collector:	Brent Bouy
Water System Name:	CITY OF ST MARTINVILLE WATER SYSTEM	Collection date:	9/20/2019 5:47:00AM
Facility ID:	SCH050016	Lab Submittal date:	9/20/2019 4:00:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.2	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, CAFETERIA, LT	Sample ID:	B1904174-014
Sample Pt ID:	DF05	Sample Type:	Special
PWS ID:	LA1099007	Sample Collector:	Brent Bouy
Water System Name:	CITY OF ST MARTINVILLE WATER SYSTEM	Collection date:	9/20/2019 5:36:00AM
Facility ID:	SCH050016	Lab Submittal date:	9/20/2019 4:00:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, CAFETERIA, RT	Sample ID:	B1904174-015
Sample Pt ID:	DF06	Sample Type:	Special
PWS ID:	LA1099007	Sample Collector:	Brent Bouy
Water System Name:	CITY OF ST MARTINVILLE WATER SYSTEM	Collection date:	9/20/2019 5:32:00AM
Facility ID:	SCH050016	Lab Submittal date:	9/20/2019 4:00:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.2	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, BLDGB, RMB-3	Sample ID:	B1904174-016
Sample Pt ID:	DF09	Sample Type:	Special
PWS ID:	LA1099007	Sample Collector:	Brent Bouy
Water System Name:	CITY OF ST MARTINVILLE WATER SYSTEM	Collection date:	9/20/2019 5:51:00AM
Facility ID:	SCH050016	Lab Submittal date:	9/20/2019 4:00:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.4	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, GYM, SIDE HALL NR RR	Sample ID:	B1904174-017
Sample Pt ID:	DF14	Sample Type:	Special
PWS ID:	LA1099007	Sample Collector:	Brent Bouy
Water System Name:	CITY OF ST MARTINVILLE WATER SYSTEM	Collection date:	9/20/2019 5:33:00AM
Facility ID:	SCH050016	Lab Submittal date:	9/20/2019 4:00:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.4	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, BLDGC, RMC-7	Sample ID:	B1904174-018
Sample Pt ID:	DF15	Sample Type:	Special
PWS ID:	LA1099007	Sample Collector:	Brent Bouy
Water System Name:	CITY OF ST MARTINVILLE WATER SYSTEM	Collection date:	9/20/2019 5:34:00AM
Facility ID:	SCH050016	Lab Submittal date:	9/20/2019 4:00:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.2	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, BLDGC, RMC-14	Sample ID:	B1904174-019
Sample Pt ID:	DF16	Sample Type:	Special
PWS ID:	LA1099007	Sample Collector:	Brent Bouy
Water System Name:	CITY OF ST MARTINVILLE WATER SYSTEM	Collection date:	9/20/2019 5:49:00AM
Facility ID:	SCH050016	Lab Submittal date:	9/20/2019 4:00:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.3	mg/L	0.1	1.3	

Qualifier Key

<u>Qualifier</u>	<u>Description</u>
> 1/2 MCL	Final Result > 1/2 MCL but < MCL

Reviewed by: Aaron Hawkins



State of Louisiana
Louisiana Department of Health
Public Health Laboratories
1209 Leesville Avenue
Baton Rouge, LA 70802
225-219-5200
<http://www.dhh.la.gov/lab>



September 25, 2019

The following analytical results have been obtained for the indicated sample(s) which was submitted to this laboratory:

Sample Pt. Description:	2C-SINK, CAFETERIA	Sample ID:	B1904217-001
Sample Pt ID:	SK01	Sample Type:	Special
PWS ID:	LA1099007	Sample Collector:	Bouy
Water System Name:	CITY OF ST MARTINVILLE WATER SYSTEM	Collection date:	9/24/2019 4:43:00AM
Facility ID:	SCH050016	Lab Submittal date:	9/24/2019 12:30:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.009	mg/L	0.001	0.015	> 1/2 MCL
Copper	0.2	mg/L	0.1	1.3	

Sample Pt. Description:	POT FILLER, TILT POT, KITCHEN	Sample ID:	B1904217-002
Sample Pt ID:	PF01	Sample Type:	Special
PWS ID:	LA1099007	Sample Collector:	Bouy
Water System Name:	CITY OF ST MARTINVILLE WATER SYSTEM	Collection date:	9/24/2019 4:41:00AM
Facility ID:	SCH050016	Lab Submittal date:	9/24/2019 12:30:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.011	mg/L	0.001	0.015	> 1/2 MCL
Copper	0.3	mg/L	0.1	1.3	

Sample Pt. Description:	POT FILLER, TILT POT, KITCHEN	Sample ID:	B1904217-003
Sample Pt ID:	PF02	Sample Type:	Special
PWS ID:	LA1099007	Sample Collector:	Bouy
Water System Name:	CITY OF ST MARTINVILLE WATER SYSTEM	Collection date:	9/24/2019 4:42:00AM
Facility ID:	SCH050016	Lab Submittal date:	9/24/2019 12:30:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.005	mg/L	0.001	0.015	
Copper	0.6	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, CAFETERIA SIDE HALL	Sample ID:	B1904217-004
Sample Pt ID:	DF04	Sample Type:	Special
PWS ID:	LA1099007	Sample Collector:	Bouy
Water System Name:	CITY OF ST MARTINVILLE WATER SYSTEM	Collection date:	9/24/2019 4:43:00AM
Facility ID:	SCH050016	Lab Submittal date:	9/24/2019 12:30:00PM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.3	mg/L	0.1	1.3	

Sample Pt. Description:	2C-SINK, CAFETERIA	Sample ID:	B1904217-005
Sample Pt ID:	SK01	Sample Type:	Special
PWS ID:	LA1099007	Sample Collector:	Bouy
Water System Name:	CITY OF ST MARTINVILLE WATER SYSTEM	Collection date:	9/24/2019 4:50:00AM
Facility ID:	SCH050016	Lab Submittal date:	9/24/2019 12:30:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.3	mg/L	0.1	1.3	

Sample Pt. Description:	POT FILLER, TILT POT, KITCHEN	Sample ID:	B1904217-006
Sample Pt ID:	PF01	Sample Type:	Special
PWS ID:	LA1099007	Sample Collector:	Bouy
Water System Name:	CITY OF ST MARTINVILLE WATER SYSTEM	Collection date:	9/24/2019 4:48:00AM
Facility ID:	SCH050016	Lab Submittal date:	9/24/2019 12:30:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.003	mg/L	0.001	0.015	
Copper	0.5	mg/L	0.1	1.3	

Sample Pt. Description:	POT FILLER, TILT POT, KITCHEN	Sample ID:	B1904217-007
Sample Pt ID:	PF02	Sample Type:	Special
PWS ID:	LA1099007	Sample Collector:	Bouy
Water System Name:	CITY OF ST MARTINVILLE WATER SYSTEM	Collection date:	9/24/2019 4:47:00AM
Facility ID:	SCH050016	Lab Submittal date:	9/24/2019 12:30:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.004	mg/L	0.001	0.015	
Copper	0.8	mg/L	0.1	1.3	> 1/2 MCL

Sample Pt. Description:	TANK FOUNTAIN, CAFETERIA SIDE HALL	Sample ID:	B1904217-008
Sample Pt ID:	DF04	Sample Type:	Special
PWS ID:	LA1099007	Sample Collector:	Bouy
Water System Name:	CITY OF ST MARTINVILLE WATER SYSTEM	Collection date:	9/24/2019 4:59:00AM
Facility ID:	SCH050016	Lab Submittal date:	9/24/2019 12:30:00PM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.4	mg/L	0.1	1.3	

Qualifier Key

Qualifier	Description
> 1/2 MCL	Final Result > 1/2 MCL but < MCL

Reviewed by: Aaron Hawkins