



State of Louisiana
Louisiana Department of Health
Office of Public Health

September 20, 2021

Mr. Karl Bruchhaus
Superintendent of Schools
Calcasieu Parish School Board
P.O. Box 800
Lake Charles, LA 70602-0800

RE: Results of School Drinking Water Testing
Sulphur High School (SCH010052)
100 Sycamore Street Sulphur, LA 70663

Dear Mr. Bruchhaus,

Act 632 of the 2018 Regular Session required the Louisiana Department of Health (LDH) to establish a pilot program for drinking water testing at public schools that were constructed prior to 1986 or which may otherwise be susceptible to drinking water lead contamination. Thank you for your participation and cooperation in this program.

On September 9, 2021, a total of 46 water samples were collected from the above referenced school in accordance with guidance provided in the Environmental Protection Agency's (EPA's) - 3Ts for Reducing Lead in Drinking Water in Schools Manual. Attached are the lead and copper sample results. See page 3 for a summary of the results. Please note that the sample result for sample point ID "TCR-061" is for a sample collected from the City of Sulphur water system.

All sample results were evaluated against the state recommended action level of 0.015 mg/L for lead and 1.3 mg/L for copper for drinking water. Ten (10) of the fixtures sampled had a "first draw" lead level that exceeds the state recommended lead action level of 0.015 mg/L. The "after flush" lead results for all fixtures were below the lead action level of 0.015 mg/L. Eight (8) of the fixtures sampled had a "first draw" copper level that exceeds the EPA established copper action level of 1.3 mg/L. Two (2) of the fixtures had an "after flush" copper result that exceeds the EPA established copper action level of 1.3 mg/L.

Based on the results, LDH recommends the following remediation actions:

- Remove drinking fountains DF1, DF2 and DF3 from service in order to prevent student use. Furthermore, it is strongly recommended that any drinking fountains on campus that are not "lead free" be removed from service until they are replaced with newer "lead free" models that comply with the Louisiana State Uniform Construction Code (LAC 17.I).
- Perform routine daily flushing (30-seconds or more) at all fixtures located in Classrooms 2102 and 2108. The flushing shall occur first thing in the morning or prior to use each day to reduce lead levels. To ensure flushing is performed daily, it is recommended that a fixture flushing policy is developed and disseminated to personnel for implementation. It is also strongly

September 20, 2021

Page 2

RE: Results of School Drinking Water Testing
Sulphur High School (SCH010052)

recommended that these fixtures be replaced with newer “lead free” models that comply with the Louisiana State Uniform Construction Code.

- Ensure that the filters* located on the bottle filling stations in Rooms 3101 and 3201 are continually replaced and maintained in accordance with the manufacturer’s recommendation. Failure to do so can result in elevated lead and/or copper levels. *It is important to use drinking water filters that meet NSF/ANSI 53 Standard for lead reduction.

LDH recommends that all schools follow the guidance provided in the EPA-3Ts manual to safeguard against lead in the drinking water. The EPA-3Ts manual was developed to assist schools with lead in drinking water prevention programs. This guidance is intended for use by school officials responsible for the maintenance and/or safety of school’s drinking water. This document along with other helpful information is available for on EPA’s website at: <https://www.epa.gov/ground-water-and-drinking-water/3ts-reducing-lead-drinking-water>.

Please notify this office of any control or remediation measures taken by the school. LDH will perform follow up sampling to confirm the corrective actions were effective.

Please feel free to contact me or Caryn Benjamin regarding any of the enclosed information.

Sincerely,



Amanda Ames, P.E.
Chief Engineer and Safe Drinking Water Administrator, LDH

Attachments

cc: David Pool, Principal Sulphur High School

Sample Results Summary

Sulphur High School (SCH010052) Sample date 9/9/2021		Lead (mg/L) AL = 0.015 mg/L		Copper (mg/L) AL = 1.3 mg/L	
Sample Point Description and ID		First Draw (mg/L)	After Flush (mg/L)	First Draw (mg/L)	After Flush (mg/L)
BOTTLE FILLER, LEFT, ACROSS FROM 3101	BF01	ND	ND	ND	ND
BOTTLE FILLER, ACROSS FROM RM 3201 ON EL	BF02	ND	ND	ND	ND
TANK FOUNTAIN, LEFT, NEXT TO WASHROOM	DF01	0.033	ND	3.8	0.7
TANK FOUNTAIN, RIGHT, NEXT TO WASHROOM	DF02	0.079	ND	11.5	0.5
TANK FOUNTAIN (ELKAY)	DF03	0.006	0.001	2.4	0.2
POT FILLER, BTWN TILT SKILLET & KETTLE	PF01	0.002	0.004	0.5	0.9
3 COMP SINK IN CAFETERIA, LEFT	SK01	0.005	0.002	0.8	0.8
3 COMP SINK IN CAFETERIA, RIGHT	SK02	0.006	0.002	0.9	0.7
3 COMP SINK IN CAFETERIA, STAND ALONE	SK03	0.010	ND	0.7	0.8
RM 2102, SINK ON LEFT NEAR CORNER	SK04	0.019	ND	0.7	0.5
RM 2102, SINK NEAR TEA	SK05	0.020	ND	1.0	0.4
RM 2102, 3 COMP SINK, LEFT NEAR COLERS	SK06	0.009	0.003	0.9	0.5
RM 2102, 3 COMP SINK, RIGHT NEAR COOLERS	SK07	0.022	0.001	0.5	0.6
RM 2102, SINK, LEFT NEAR SPICES (ORANGE)	SK08	0.014	ND	1.6	0.6
RM 2102 SINK, MIDDLE (GREEN)	SK09	0.012	0.002	1.2	0.8
RM 2102, SINK, RIGHT (YELLOW)	SK10	0.013	0.002	1.5	0.9
RM 2108, SINK LEFT (RED)	SK11	0.049	0.012	0.8	1.9
RM 2108, SINK MIDDLE (ORANGE)	SK12	0.100	ND	1.4	0.4
RM 2108, SINK RIGHT (YELLOW)	SK13	0.062	0.006	0.5	0.4
RM 2108, SINK LEFT (PURPLE)	SK14	0.030	0.013	1.8	2.1
RM 2108, SINK MIDDLE (BLUE)	SK15	0.037	0.001	1.5	0.6
RM 2108, SINK RIGHT (GREEN)	SK16	0.011	0.002	1.3	0.8
WORKSHOP, 3 COMP SINK	SK17	0.015	0.001	0.3	0.1

"ND" -- Non-Detect - contaminant level is below the Laboratory Report Limit (<0.001 mg/L Lead or <0.1 mg/L Copper)

"AL" -- Action Level - state recommended action level

Most drinking fountains on campus have been valved off for some time to prevent use by the students and faculty. Samples were not pulled from these valved off fixtures.



State of Louisiana
Louisiana Department of Health
Public Health Laboratories
1209 Leesville Avenue
Baton Rouge, LA 70802
225-219-5200
<http://www.dhh.la.gov/lab>



September 20, 2021

The following analytical results have been obtained for the indicated sample(s) which was submitted to this laboratory:

Sample Pt. Description:	BOTTLE FILLER, LEFT, ACROSS FROM 3101	Sample ID:	B2104354-001
Sample Pt ID:	BF01	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:42:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

Sample Pt. Description:	BOTTLE FILLER, ACROSS FROM RM 3201 ON EL	Sample ID:	B2104354-002
Sample Pt ID:	BF02	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:40:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, LEFT, NEXT TO WASHROOM	Sample ID:	B2104354-003
Sample Pt ID:	DF01	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:43:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.033	mg/L	0.001	0.015	> MCL
Copper	3.8	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN, RIGHT, NEXT TO WASHROOM	Sample ID:	B2104354-004
Sample Pt ID:	DF02	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:44:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.079	mg/L	0.001	0.015	> MCL
Copper	11.5	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	TANK FOUNTAIN (ELKAY)	Sample ID:	B2104354-005
Sample Pt ID:	DF03	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:40:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.006	mg/L	0.001	0.015	
Copper	2.4	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	POT FILLER, BTWN TILT SKILLET & KETTLE	Sample ID:	B2104354-006
Sample Pt ID:	PF01	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:41:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.002	mg/L	0.001	0.015	
Copper	0.5	mg/L	0.1	1.3	

Sample Pt. Description:	3 COMP SINK IN CAFETERIA, LEFT	Sample ID:	B2104354-007
Sample Pt ID:	SK01	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:42:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.005	mg/L	0.001	0.015	
Copper	0.8	mg/L	0.1	1.3	> 1/2 MCL

Sample Pt. Description:	3 COMP SINK IN CAFETERIA, RIGHT	Sample ID:	B2104354-008
Sample Pt ID:	SK02	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:43:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.006	mg/L	0.001	0.015	
Copper	0.9	mg/L	0.1	1.3	> 1/2 MCL

Sample Pt. Description:	3 COMP SINK IN CAFETERIA, STAND ALONE	Sample ID:	B2104354-009
Sample Pt ID:	SK03	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:42:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.010	mg/L	0.001	0.015	> 1/2 MCL
Copper	0.7	mg/L	0.1	1.3	> 1/2 MCL

Sample Pt. Description:	RM 2102, SINK ON LEFT NEAR CORNER	Sample ID:	B2104354-010
Sample Pt ID:	SK04	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:40:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.019	mg/L	0.001	0.015	> MCL
Copper	0.7	mg/L	0.1	1.3	> 1/2 MCL

Sample Pt. Description:	RM 2102, SINK NEAR TEA	Sample ID:	B2104354-011
Sample Pt ID:	SK05	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:42:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.020	mg/L	0.001	0.015	> MCL
Copper	1.0	mg/L	0.1	1.3	> 1/2 MCL

Sample Pt. Description:	RM 2102, 3 COMP SINK, LEFT NEAR COLERS	Sample ID:	B2104354-012
Sample Pt ID:	SK06	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:43:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.009	mg/L	0.001	0.015	> 1/2 MCL
Copper	0.9	mg/L	0.1	1.3	> 1/2 MCL

Sample Pt. Description:	RM 2102, 3 COMP SINK, RIGHT NEAR COOLERS	Sample ID:	B2104354-013
Sample Pt ID:	SK07	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:44:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.022	mg/L	0.001	0.015	> MCL
Copper	0.5	mg/L	0.1	1.3	

Sample Pt. Description:	RM 2102, SINK, LEFT NEAR SPICES (ORANGE)	Sample ID:	B2104354-014
Sample Pt ID:	SK08	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:46:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.014	mg/L	0.001	0.015	> 1/2 MCL
Copper	1.6	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	RM 2102 SINK, MIDDLE (GREEN)	Sample ID:	B2104354-015
Sample Pt ID:	SK09	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:46:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.012	mg/L	0.001	0.015	> 1/2 MCL
Copper	1.2	mg/L	0.1	1.3	> 1/2 MCL

Sample Pt. Description:	RM 2102, SINK, RIGHT (YELLOW)	Sample ID:	B2104354-016
Sample Pt ID:	SK10	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:45:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.013	mg/L	0.001	0.015	> 1/2 MCL
Copper	1.5	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	RM 2108, SINK LEFT (RED)	Sample ID:	B2104354-017
Sample Pt ID:	SK11	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:40:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.049	mg/L	0.001	0.015	> MCL
Copper	0.8	mg/L	0.1	1.3	> 1/2 MCL

Sample Pt. Description:	RM 2108, SINK MIDDLE (ORANGE)	Sample ID:	B2104354-018
Sample Pt ID:	SK12	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:41:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.100	mg/L	0.001	0.015	> MCL
Copper	1.4	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	RM 2108, SINK RIGHT (YELLOW)	Sample ID:	B2104354-019
Sample Pt ID:	SK13	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:41:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.062	mg/L	0.001	0.015	> MCL
Copper	0.5	mg/L	0.1	1.3	

Sample Pt. Description:	RM 2108, SINK LEFT (PURPLE)	Sample ID:	B2104354-020
Sample Pt ID:	SK14	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:42:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.030	mg/L	0.001	0.015	> MCL
Copper	1.8	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	RM 2108, SINK MIDDLE (BLUE)	Sample ID:	B2104354-021
Sample Pt ID:	SK15	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:43:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.037	mg/L	0.001	0.015	> MCL
Copper	1.5	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	RM 2108, SINK RIGHT (GREEN)	Sample ID:	B2104354-022
Sample Pt ID:	SK16	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:44:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.011	mg/L	0.001	0.015	> 1/2 MCL
Copper	1.3	mg/L	0.1	1.3	> 1/2 MCL

Sample Pt. Description:	WORKSHOP, 3 COMP SINK	Sample ID:	B2104354-023
Sample Pt ID:	SK17	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:41:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	First Draw		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.015	mg/L	0.001	0.015	> 1/2 MCL
Copper	0.3	mg/L	0.1	1.3	

Sample Pt. Description:	BOTTLE FILLER, LEFT, ACROSS FROM 3101	Sample ID:	B2104354-024
Sample Pt ID:	BF01	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 5:00:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

Sample Pt. Description:	BOTTLE FILLER, ACROSS FROM RM 3201 ON EL	Sample ID:	B2104354-025
Sample Pt ID:	BF02	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 5:15:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN, LEFT, NEXT TO WASHROOM	Sample ID:	B2104354-026
Sample Pt ID:	DF01	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 5:06:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.7	mg/L	0.1	1.3	> 1/2 MCL

Sample Pt. Description:	TANK FOUNTAIN, RIGHT, NEXT TO WASHROOM	Sample ID:	B2104354-027
Sample Pt ID:	DF02	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 5:07:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.5	mg/L	0.1	1.3	

Sample Pt. Description:	TANK FOUNTAIN (ELKAY)	Sample ID:	B2104354-028
Sample Pt ID:	DF03	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 5:01:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.001	mg/L	0.001	0.015	
Copper	0.2	mg/L	0.1	1.3	

Sample Pt. Description:	POT FILLER, BTWN TILT SKILLET & KETTLE	Sample ID:	B2104354-029
Sample Pt ID:	PF01	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:46:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.004	mg/L	0.001	0.015	
Copper	0.9	mg/L	0.1	1.3	> 1/2 MCL

Sample Pt. Description:	3 COMP SINK IN CAFETERIA, LEFT	Sample ID:	B2104354-030
Sample Pt ID:	SK01	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:50:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.002	mg/L	0.001	0.015	
Copper	0.8	mg/L	0.1	1.3	> 1/2 MCL

Sample Pt. Description:	3 COMP SINK IN CAFETERIA, RIGHT	Sample ID:	B2104354-031
Sample Pt ID:	SK02	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:51:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.002	mg/L	0.001	0.015	
Copper	0.7	mg/L	0.1	1.3	> 1/2 MCL

Sample Pt. Description:	3 COMP SINK IN CAFETERIA, STAND ALONE	Sample ID:	B2104354-032
Sample Pt ID:	SK03	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:48:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.8	mg/L	0.1	1.3	> 1/2 MCL

Sample Pt. Description:	RM 2102, SINK ON LEFT NEAR CORNER	Sample ID:	B2104354-033
Sample Pt ID:	SK04	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:49:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.5	mg/L	0.1	1.3	

Sample Pt. Description:	RM 2102, SINK NEAR TEA	Sample ID:	B2104354-034
Sample Pt ID:	SK05	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:50:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.4	mg/L	0.1	1.3	

Sample Pt. Description:	RM 2102, 3 COMP SINK, LEFT NEAR COLERS	Sample ID:	B2104354-035
Sample Pt ID:	SK06	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:52:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.003	mg/L	0.001	0.015	
Copper	0.5	mg/L	0.1	1.3	

Sample Pt. Description:	RM 2102, 3 COMP SINK, RIGHT NEAR COOLERS	Sample ID:	B2104354-036
Sample Pt ID:	SK07	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:52:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.001	mg/L	0.001	0.015	
Copper	0.6	mg/L	0.1	1.3	

Sample Pt. Description:	RM 2102, SINK, LEFT NEAR SPICES (ORANGE)	Sample ID:	B2104354-037
Sample Pt ID:	SK08	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:56:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.6	mg/L	0.1	1.3	

Sample Pt. Description:	RM 2102 SINK, MIDDLE (GREEN)	Sample ID:	B2104354-038
Sample Pt ID:	SK09	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:54:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.002	mg/L	0.001	0.015	
Copper	0.8	mg/L	0.1	1.3	> 1/2 MCL

Sample Pt. Description:	RM 2102, SINK, RIGHT (YELLOW)	Sample ID:	B2104354-039
Sample Pt ID:	SK10	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:54:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.002	mg/L	0.001	0.015	
Copper	0.9	mg/L	0.1	1.3	> 1/2 MCL

Sample Pt. Description:	RM 2108, SINK LEFT (RED)	Sample ID:	B2104354-040
Sample Pt ID:	SK11	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:47:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.012	mg/L	0.001	0.015	> 1/2 MCL
Copper	1.9	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	RM 2108, SINK MIDDLE (ORANGE)	Sample ID:	B2104354-041
Sample Pt ID:	SK12	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:48:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	0.4	mg/L	0.1	1.3	

Sample Pt. Description:	RM 2108, SINK RIGHT (YELLOW)	Sample ID:	B2104354-042
Sample Pt ID:	SK13	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:49:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.006	mg/L	0.001	0.015	
Copper	0.4	mg/L	0.1	1.3	

Sample Pt. Description:	RM 2108, SINK LEFT (PURPLE)	Sample ID:	B2104354-043
Sample Pt ID:	SK14	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:51:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.013	mg/L	0.001	0.015	> 1/2 MCL
Copper	2.1	mg/L	0.1	1.3	> MCL

Sample Pt. Description:	RM 2108, SINK MIDDLE (BLUE)	Sample ID:	B2104354-044
Sample Pt ID:	SK15	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:52:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.001	mg/L	0.001	0.015	
Copper	0.6	mg/L	0.1	1.3	

Sample Pt. Description:	RM 2108, SINK RIGHT (GREEN)	Sample ID:	B2104354-045
Sample Pt ID:	SK16	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 4:53:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.002	mg/L	0.001	0.015	
Copper	0.8	mg/L	0.1	1.3	> 1/2 MCL

Sample Pt. Description:	WORKSHOP, 3 COMP SINK	Sample ID:	B2104354-046
Sample Pt ID:	SK17	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 5:03:00AM
Facility ID:	SCH010052	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	After Flush		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	0.001	mg/L	0.001	0.015	
Copper	0.1	mg/L	0.1	1.3	

Sample Pt. Description:	420 CHERRY ST.	Sample ID:	B2104354-047
Sample Pt ID:	TCR-061	Sample Type:	Special
PWS ID:	LA1019044	Sample Collector:	Babineaux
Water System Name:	SULPHUR CITY OF WATER SYSTEM	Collection date:	9/9/2021 5:28:00AM
Facility ID:	DS0950	Lab Submittal date:	9/16/2021 11:45:00AM
Collection Address:	Distribution		

Component Name	Results	Units	Rep. Limit	MCL	Qualifiers
Lead and Copper (200.8)					
Lead	<0.001	mg/L	0.001	0.015	
Copper	<0.1	mg/L	0.1	1.3	

Qualifier Key

<u>Qualifier</u>	<u>Description</u>
> 1/2 MCL	Final Result > 1/2 MCL but < MCL
> MCL	Final Result Above MCL

Reviewed by: Aaron Hawkins