

Sampling Date: May 21, 2021
Submission Date: June 10, 2021

Amended Water Sampling Report

Belle Chasse Primary and Head Start

601 F. Edward Hebert Blvd., Belle Chasse, LA 70037
(MMG Job # 3921 LDH-38)



Prepared for:

Caryn Benjamin
LDH-OPH, Engineering Services
628 N. Fourth Street
P.O. Box 4489
Baton Rouge, LA 70821



By:



Materials Management Group, Inc.
2401 Westbend Parkway, Suite 3010
New Orleans, LA 70114

Amended Water Sampling Report (Sampling Date 5/1/2021)

Belle Chasse Primary School
601 F. Edward Hebert Blvd., Belle Chasse, LA 70037

Report Date: 6/10/2021
MMG # 3921 LDH 38

Table of Contents

Table of Contents	1
1.0 Introduction.....	2
2.0 Summary of Activities	2
2.1 MMG Personnel.....	2
2.2 Methodology	3
2.3 Field Activities	3
3.0 Analytical Results.....	3
4.0 Amended Analytical Results	Error! Bookmark not defined.
5.0 Recommendation(s) from LDH	13
6.0 Signatures	13
Appendices.....	13
Appendix A:	Sampling Maps
Appendix B:	Laboratory Report and Chain of Custody Documentation
Appendix C:	Laboratory Accreditations and Certifications
Appendix D:	Amended Laboratory Report and Chain of Custody Documentation

1.0 Introduction

Materials Management Group, Inc. (MMG) was retained by the Louisiana Department of Health – Office of Public Health (LDH) to conduct water sampling for the potential presence and concentration of lead in drinking water at primary schools and day care facilities throughout Louisiana. MMG's scope of work includes testing all sources of water used for consumption in a given school or day care facility. This report summarizes water testing performed at Belle Chasse Primary School, located at 601 F. Edward Hebert Blvd., Belle Chasse, LA 70037 (School).

MMG personnel Erin LeCompte and Dr. C. Paul Lo, performed the initial facility assessment on March 4, 2021. A water sampling plan submitted to LDH on March 12, 2021 and approved on March 16, 2021. Water sampling was performed at the School on May 1, 2021 by LDEQ Certified Lead Inspectors Erin LeCompte, Dr. C. Paul Lo, Richard Lo, Mimi Lo, and Sue-Claire Lichtveld.

2.0 Summary of Activities

2.1 MMG Personnel

MMG personnel listed below participated in water sample collection. They are LDEQ-accredited Lead Inspectors and Lead Risk Assessors. Table 2.1 below includes a summary of the relevant lead certification information.

Table 2.1 MMG Personnel Accreditation Information Summary

MMG Personnel	Accreditation Type	Certification Number	Date of Expiration
Mimi Lo	Lead Inspector	J1155140	07/09/2021
	Lead Risk Assessor	JR155140	07/10/2021
	Lead Project Supervisor	JS155140	07/11/2021
Richard Lo	Lead Inspector	AI192398	08/18/2021
	Lead Risk Assessor	AR192398	08/24/2021
Erin LeCompte	Lead Inspector	OI217986	10/13/2021
	Lead Risk Assessor	OR217986	10/14/2021
Dr. Paul Lo	Lead Inspector	J1121486	1/8/2022
	Lead Risk Assessor	JR121486	1/9/2022
	Lead Project Supervisor	JS121486	1/10/2022
	Lead Designer	JD121486	1/10/2022
Sue-Claire Lichtveld	Lead Inspector	J1210196	07/09/2021
	Lead Risk Assessor	JR210196	07/10/2021

2.2 Methodology

The MMG team utilized the water sampling methodology described in the guidance document, “3 T’s for Reducing Lead in Drinking Water in Schools and Child Care Facilities: A Training, Testing, and Taking Action Approach”, authored by the Environmental Protection Agency (EPA), Office of Ground Water and Drinking Water.

The EPA recommends schools and childcare facilities use a 2-step sampling procedure which specifies the collection of two (2) water samples per fixture. The “1st Draw” sample is taken from the fixture once water has been sitting stagnant in the fixture for no less than 8 hours and no more than 18 hours. The “2nd Draw” sample is then collected from the same fixture after the fixture has been “flushed” for a pre-determined length of time. “Flushing” a fixture is accomplished by running water through the fixture at a moderate flow rate for 30 seconds (in the case of faucets and bubblers) or 15 minutes (in the case of water coolers or other fixtures which include a holding tank or similar water storage/refrigeration component). Using the “2-draw” method of water sampling described in the “3 T’s” document is meant to ensure that the water samples collected at a given facility are representative of water quality and usage under “normal” conditions.

2.3 Field Activities

MMG performed all water sampling activities at the School on May 1, 2021 beginning at approximately 8:00 AM. Samples were collected from fixtures pre-approved by LDH. No banned water fountains were identified at the School on March 4, 2021. See Appendix A: Sampling Maps for illustrated locations of each sample. Some fixtures (water coolers) were not sampled due to no flow.

After collection, water samples were transported via courier to Waypoint Analytical located at 5041 Taravella Road, Marrero, LA 70072. All samples were analyzed for lead concentration using the EPA 200.8 Method with ICP-MS. The laboratory certification issued for Waypoint Analytical by the Louisiana Department of Health (LDH) is included in Appendix C.

3.0 Analytical Results

Tables 3.1 and 3.2 summarizes the analytical results for the water samples taken by MMG at Belle Chasse Primary School on May 1, 2021. The table also compares the results to the LDH lead action level of 15 parts per billion, which is equivalent to 15 µg/L. The complete analytical reports for all water samples taken over the course of the investigation, including chain-of-custody documentation, can be found in Appendix B.

MMG conducted follow-up testing in Rooms 13 and 14 at the request of LDH. Follow-up testing was conducted at approximately 6:00 AM on May 21, 2021 by Erin LeCompte. Fixtures from both rooms were analyzed using EPA Method 200.8 for lead. Due to the presence of Bismuth in the samples for Room 13, the lead samples from this room had

Amended Water Sampling Report (Sampling Date 5/1/2021)**Belle Chasse Primary School
601 F. Edward Hebert Blvd., Belle Chasse, LA 70037****Report Date: 6/10/2021
MMG # 3921 LDH 38**

to be diluted. Table 3.3 summarizes the analytical results for the lead water samples taken by MMG at Belle Chasse Primary School on May 21, 2021.

Table 3.1 Water Sampling Results - Belle Chasse Primary (Building 1 – Primary School)

Sample ID	Sample Location	Description	Result (µg/L)	Lead Action Level (µg/L)	Exceed? (Yes/No)
BCP1-H1BA1-F1-D1	Hallway 1, Bathroom 1	Bathroom Faucet	<0.500	15.0	No
BCP1-H1BA1-F1-D2	Hallway 1, Bathroom 1	Bathroom Faucet	<0.500	15.0	No
BCP1-H1BA2-F1-D1	Hallway 1, Bathroom 2	Bathroom Faucet	0.704	15.0	No
BCP1-H1BA2-F1-D2	Hallway 1, Bathroom 2	Bathroom Faucet	<0.500	15.0	No
BCP1-H1-WC1-D1	Hallway 1 (left)	Water Cooler, Elkay	<0.500	15.0	No
BCP1-H1-WC1-D2	Hallway 1 (left)	Water Cooler, Elkay	<0.500	15.0	No
BCP1-H1-WC2-D1	Hallway 1 (right)	Water Cooler, Elkay	<0.500	15.0	No
BCP1-H1-WC2-D2	Hallway 1 (right)	Water Cooler, Elkay	<0.500	15.0	No
BCP1-RM1-F1-D1	Room 1	Faucet	<0.500	15.0	No
BCP1-RM1-F1-D2	Room 1	Faucet	<0.500	15.0	No
BCP1-RM2-F1-D1	Room 2 (left)	Faucet	<0.500	15.0	No
BCP1-RM2-F1-D2	Room 2 (left)	Faucet	<0.500	15.0	No
BCP1-RM2-F2-D1	Room 2 (middle)	Faucet	0.818	15.0	No
BCP1-RM2-F2-D2	Room 2 (middle)	Faucet	<0.500	15.0	No
BCP1-RM2-F3-D1	Room 2 (right)	Faucet	1.8	15.0	No
BCP1-RM2-F3-D2	Room 2 (right)	Faucet	0.879	15.0	No
BCP1-H2-WC1-D1	Hallway 2 (left)	Water Cooler, Elkay	<0.500	15.0	No
BCP1-H2-WC1-D2	Hallway 2 (left)	Water Cooler, Elkay	<0.500	15.0	No
BCP1-H2-WC2-D1	Hallway 2 (right)	Water Cooler, Elkay	<0.500	15.0	No
BCP1-H2-WC2-D2	Hallway 2 (right)	Water Cooler, Elkay	<0.500	15.0	No
BCP1-RM3-F1-D1	Room 3 (left)	Classroom Faucet	0.901	15.0	No
BCP1-RM3-F1-D2	Room 3 (left)	Classroom Faucet	<0.500	15.0	No
BCP1-RM3-F2-D1	Room 3 (middle)	Classroom Faucet	0.678	15.0	No
BCP1-RM3-F2-D2	Room 3 (middle)	Classroom Faucet	<0.500	15.0	No
BCP1-RM3-F3-D1	Room 3 (right)	Classroom Faucet	0.711	15.0	No

Amended Water Sampling Report (Sampling Date 5/1/2021)**Belle Chasse Primary School
601 F. Edward Hebert Blvd., Belle Chasse, LA 70037****Report Date: 6/10/2021
MMG # 3921 LDH 38**

Sample ID	Sample Location	Description	Result (µg/L)	Lead Action Level (µg/L)	Exceed? (Yes/No)
BCP1-RM3-F3-D2	Room 3 (right)	Classroom Faucet	<0.500	15.0	No
BCP1-RM4-F1-D1	Room 4 (left)	Classroom Faucet	<0.500	15.0	No
BCP1-RM4-F1-D2	Room 4 (left)	Classroom Faucet	<0.500	15.0	No
BCP1-RM4-F2-D1	Room 4 (middle)	Classroom Faucet	<0.500	15.0	No
BCP1-RM4-F2-D2	Room 4 (middle)	Classroom Faucet	<0.500	15.0	No
BCP1- RM4-F3-D1	Room 4 (right)	Classroom Faucet	2.08	15.0	No
BCP1-RM4-F3-D2	Room 4 (right)	Classroom Faucet	0.516	15.0	No
BCP1-RM5-F1-D1	Room 5 (left)	Classroom Faucet	1.22	15.0	No
BCP1-RM5-F1-D2	Room 5 (left)	Classroom Faucet	<0.500	15.0	No
BCP1-RM5-F2-D1	Room 5 (middle)	Classroom Faucet	<0.500	15.0	No
BCP1-RM5-F2-D2	Room 5 (middle)	Classroom Faucet	<0.500	15.0	No
BCP1-RM5-F3-D1	Room 5 (right)	Classroom Faucet	0.936	15.0	No
BCP1-RM5-F3-D2	Room 5 (right)	Classroom Faucet	<0.500	15.0	No
BCP1-RM6-F1-D1	Room 6 (left)	Classroom Faucet	0.755	15.0	No
BCP1-RM6-F1-D2	Room 6 (left)	Classroom Faucet	<0.500	15.0	No
BCP1-RM6-F2-D1	Room 6 (middle)	Classroom Faucet	<0.500	15.0	No
BCP1-RM6-F2-D2	Room 6 (middle)	Classroom Faucet	<0.500	15.0	No
BCP1-RM6-F3-D1	Room 6 (right)	Classroom Faucet	<0.500	15.0	No
BCP1-RM6-F3-D2	Room 6 (right)	Classroom Faucet	<0.500	15.0	No
BCP1-RM7-F1-D1	Room 7 (left)	Classroom Faucet	<0.500	15.0	No
BCP1-RM7-F1-D2	Room 7 (left)	Classroom Faucet	<0.500	15.0	No
BCP1-RM7-F2-D1	Room 7 (middle)	Classroom Faucet	<0.500	15.0	No
BCP1-RM7-F2-D2	Room 7 (middle)	Classroom Faucet	<0.500	15.0	No
BCP1-RM7-F3-D1	Room 7 (right)	Classroom Faucet	0.708	15.0	No
BCP1-RM7-F3-D2	Room 7 (right)	Classroom	<0.500	15.0	No

Amended Water Sampling Report (Sampling Date 5/1/2021)**Belle Chasse Primary School
601 F. Edward Hebert Blvd., Belle Chasse, LA 70037****Report Date: 6/10/2021
MMG # 3921 LDH 38**

Sample ID	Sample Location	Description	Result (µg/L)	Lead Action Level (µg/L)	Exceed? (Yes/No)
		Faucet			
BCP1-RM8-F1-D1	Room 8 (left)	Classroom Faucet	<0.500	15.0	No
BCP1-RM8-F1-D2	Room 8 (left)	Classroom Faucet	<0.500	15.0	No
BCP1-RM8-F2-D1	Room 8 (middle)	Classroom Faucet	<0.500	15.0	No
BCP1-RM8-F2-D2	Room 8 (middle)	Classroom Faucet	<0.500	15.0	No
BCP1-RM8-F3-D1	Room 8 (right)	Classroom Faucet	<0.500	15.0	No
BCP1-RM8-F3-D2	Room 8 (right)	Classroom Faucet	<0.500	15.0	No
BCP1-RM9-F1-D1	Room 9 (left)	Classroom Faucet	<0.500	15.0	No
BCP1-RM9-F1-D2	Room 9 (left)	Classroom Faucet	<0.500	15.0	No
BCP1-RM9-F2-D1	Room 9 (middle)	Classroom Faucet	<0.500	15.0	No
BCP1-RM9-F2-D2	Room 9 (middle)	Classroom Faucet	<0.500	15.0	No
BCP1-RM9-F3-D1	Room 9 (right)	Classroom Faucet	<0.500	15.0	No
BCP1-RM9-F3-D2	Room 9 (right)	Classroom Faucet	<0.500	15.0	No
BCP1-RM10-F1-D1	Room 10 (left)	Classroom Faucet	0.925	15.0	No
BCP1-RM10-F1-D2	Room 10 (left)	Classroom Faucet	<0.500	15.0	No
BCP1-RM10-F2-D1	Room 10 (middle)	Classroom Faucet	1.08	15.0	No
BCP1-RM10-F2-D2	Room 10 (middle)	Classroom Faucet	<0.500	15.0	No
BCP1-RM10-F3-D1	Room 10 (right)	Classroom Faucet	0.695	15.0	No
BCP1-RM10-F3-D2	Room 10 (right)	Classroom Faucet	<0.500	15.0	No
BCP1-RM11-F1-D1	Room 11 (left)	Classroom Faucet	0.926	15.0	No
BCP1-RM11-F1-D2	Room 11 (left)	Classroom Faucet	<0.500	15.0	No
BCP1-RM11-F2-D1	Room 11 (middle)	Classroom Faucet	1.28	15.0	No
BCP1-RM11-F2-D2	Room 11 (middle)	Classroom Faucet	<0.500	15.0	No
BCP1-RM11-F3-D1	Room 11 (right)	Classroom Faucet	0.639	15.0	No
BCP1-RM11-F3-D2	Room 11 (right)	Classroom Faucet	<0.500	15.0	No

Amended Water Sampling Report (Sampling Date 5/1/2021)**Belle Chasse Primary School
601 F. Edward Hebert Blvd., Belle Chasse, LA 70037****Report Date: 6/10/2021
MMG # 3921 LDH 38**

Sample ID	Sample Location	Description	Result (µg/L)	Lead Action Level (µg/L)	Exceed? (Yes/No)
BCP1-RM12-F1-D1	Room 12 (left)	Classroom Faucet	1.39	15.0	No
BCP1-RM12-F1-D2	Room 12 (left)	Classroom Faucet	<0.500	15.0	No
BCP1-RM12-F2-D1	Room 12 (middle)	Classroom Faucet	1.1	15.0	No
BCP1-RM12-F2-D2	Room 12 (middle)	Classroom Faucet	<0.500	15.0	No
BCP1-RM12-F3-D1	Room 12 (right)	Classroom Faucet	0.863	15.0	No
BCP1-RM12-F3-D2	Room 12 (right)	Classroom Faucet	<0.500	15.0	No
BCP1-RM13-F1-D1*	Room 13 (left)	Classroom Faucet	<10.0	15.0	No
BCP1-RM13-F1-D2*	Room 13 (left)	Classroom Faucet	<5.00	15.0	No
BCP1-RM13-F2-D1*	Room 13 (right)	Classroom Faucet	<10.0	15.0	No
BCP1-RM13-F2-D2*	Room 13 (right)	Classroom Faucet	<2.50	15.0	No
BCP1-RM14-F1-D1*	Room 14 (left)	Classroom Faucet	3.91	15.0	No
BCP1-RM14-F1-D2	Room 14 (left)	Classroom Faucet	1.41	15.0	No
BCP1-RM14-F2-D1*	Room 14 (right)	Classroom Faucet	5.35	15.0	No
BCP1-RM14-F2-D2	Room 14 (right)	Classroom Faucet	<0.500	15.0	No
BCP1-H4-WC1-D1	Hallway 4 (left)	Water Cooler, Elkay	<0.500	15.0	No
BCP1-H4-WC1-D2	Hallway 4 (left)	Water Cooler, Elkay	<0.500	15.0	No
BCP1-H4-WC2-D1	Hallway 4 (right)	Water Cooler, Elkay	<0.500	15.0	No
BCP1-H4-WC2-D2	Hallway 4 (right)	Water Cooler, Elkay	<0.500	15.0	No
BCP1-RM15-F1-D1	Room 15	Classroom Faucet	<0.500	15.0	No
BCP1-RM15-F1-D2	Room 15	Classroom Faucet	<0.500	15.0	No
BCP1-RM16-F1-D1	Room 16	Classroom Faucet	<0.500	15.0	No
BCP1-RM16-F1-D2	Room 16	Classroom Faucet	<0.500	15.0	No
BCP1-RM17-F1-D1	Room 17	Classroom Faucet	<0.500	15.0	No
BCP1-RM17-F1-D2	Room 17	Classroom Faucet	<0.500	15.0	No
BCP1-RM18-F1-D1	Room 18	Classroom	<0.500	15.0	No

Amended Water Sampling Report (Sampling Date 5/1/2021)

Belle Chasse Primary School
601 F. Edward Hebert Blvd., Belle Chasse, LA 70037

Report Date: 6/10/2021
MMG # 3921 LDH 38

Sample ID	Sample Location	Description	Result (µg/L)	Lead Action Level (µg/L)	Exceed? (Yes/No)
		Faucet			
BCP1-RM18-F1-D2	Room 18	Classroom Faucet	<0.500	15.0	No
BCP1-RM19-F1-D1	Room 19	Classroom Faucet	<0.500	15.0	No
BCP1-RM19-F1-D2	Room 19	Classroom Faucet	<0.500	15.0	No
BCP1-RM20-F1-D1	Room 20	Classroom Faucet	<0.500	15.0	No
BCP1-RM20-F1-D2	Room 20	Classroom Faucet	<0.500	15.0	No
BCP1-RM21-F1-D1	Room 21	Classroom Faucet	<0.500	15.0	No
BCP1-RM21-F1-D2	Room 21	Classroom Faucet	<0.500	15.0	No
BCP1-RM22-F1-D1	Room 22	Classroom Faucet	<0.500	15.0	No
BCP1-RM22-F1-D2	Room 22	Classroom Faucet	<0.500	15.0	No
BCP1-RM23-F1-D1	Room 23	Classroom Faucet	<0.500	15.0	No
BCP1-RM23-F1-D2	Room 23	Classroom Faucet	<0.500	15.0	No
BCP1-RM24-F1-D1	Room 24	Classroom Faucet	<0.500	15.0	No
BCP1-RM24-F1-D2	Room 24	Classroom Faucet	<0.500	15.0	No
BCP1-RM25-F1-D1	Room 25	Classroom Faucet	1.8	15.0	No
BCP1-RM25-F1-D2	Room 25	Classroom Faucet	<0.500	15.0	No
BCP1-RM26-F1-D1	Room 26 (left)	Classroom Faucet	1.14	15.0	No
BCP1-RM26-F1-D2	Room 26 (left)	Classroom Faucet	<0.500	15.0	No
BCP1-RM26-F2-D1	Room 26 (middle)	Classroom Faucet	0.856	15.0	No
BCP1-RM26-F2-D2	Room 26 (middle)	Classroom Faucet	<0.500	15.0	No
BCP1-RM26-F3-D1	Room 26 (right)	Classroom Faucet	<0.500	15.0	No
BCP1-RM26-F3-D2	Room 26 (right)	Classroom Faucet	<0.500	15.0	No
BCP1-H6-WC1-D1	Hallway 6 (left)	Water Cooler, Elkay	<0.500	15.0	No
BCP1-H6-WC1-D2	Hallway 6 (left)	Water Cooler, Elkay	<0.500	15.0	No
BCP1-H6-WC2-D1	Hallway 6 (right)	Water Cooler, Elkay	<0.500	15.0	No

Amended Water Sampling Report (Sampling Date 5/1/2021)**Belle Chasse Primary School
601 F. Edward Hebert Blvd., Belle Chasse, LA 70037****Report Date: 6/10/2021
MMG # 3921 LDH 38**

Sample ID	Sample Location	Description	Result (µg/L)	Lead Action Level (µg/L)	Exceed? (Yes/No)
BCP1-H6-WC2-D2	Hallway 6 (right)	Water Cooler, Elkay	<0.500	15.0	No
BCP1-RM27-F1-D1	Room 27	Classroom Faucet	0.628	15.0	No
BCP1-RM27-F1-D2	Room 27	Classroom Faucet	<0.500	15.0	No
BCP1-RM28-F1-D1	Room 28	Classroom Faucet	<0.500	15.0	No
BCP1-RM28-F1-D2	Room 28	Classroom Faucet	<0.500	15.0	No
BCP1-RM29-F1-D1	Room 29	Classroom Faucet	<0.500	15.0	No
BCP1-RM29-F1-D2	Room 29	Classroom Faucet	<0.500	15.0	No
BCP1-RM30-F1-D1	Room 30	Classroom Faucet	<0.500	15.0	No
BCP1-RM30-F1-D2	Room 30	Classroom Faucet	<0.500	15.0	No
BCP1-RM31-F1-D1	Room 31	Classroom Faucet	<0.500	15.0	No
BCP1-RM31-F1-D2	Room 31	Classroom Faucet	<0.500	15.0	No
BCP1-H8BA1-F1-D1	Hallway 8 Bathroom	Bathroom Faucet	0.76	15.0	No
BCP1-H8BA1-F1-D2	Hallway 8 Bathroom	Bathroom Faucet	<0.500	15.0	No
BCP1-RM32-F1-D1	Room 32	Classroom Faucet	<0.500	15.0	No
BCP1-RM32-F1-D2	Room 32	Classroom Faucet	<0.500	15.0	No
BCP1-RM33-F1-D1	Room 33	Classroom Faucet	0.509	15.0	No
BCP1-RM33-F1-D2	Room 33	Classroom Faucet	<0.500	15.0	No
BCP1-RM34-F1-D1	Room 34	Classroom Faucet	<0.500	15.0	No
BCP1-RM34-F1-D2	Room 34	Classroom Faucet	<0.500	15.0	No
BCP1-RM35-F1-D1	Room 35	Classroom Faucet	<0.500	15.0	No
BCP1-RM35-F1-D2	Room 35	Classroom Faucet	<0.500	15.0	No
BCP1-RM36-F1-D1	Room 36	Classroom Faucet	<0.500	15.0	No
BCP1-RM36-F1-D2	Room 36	Classroom Faucet	<0.500	15.0	No
BCP1-RM37-F1-D1	Room 37	Classroom Faucet	<0.500	15.0	No
BCP1-RM37-F1-D2	Room 37	Classroom	<0.500	15.0	No

Amended Water Sampling Report (Sampling Date 5/1/2021)

Belle Chasse Primary School
601 F. Edward Hebert Blvd., Belle Chasse, LA 70037

Report Date: 6/10/2021
MMG # 3921 LDH 38

Sample ID	Sample Location	Description	Result (µg/L)	Lead Action Level (µg/L)	Exceed? (Yes/No)
		Faucet			
BCP1-CAF-F1-D1	Cafeteria	Handwash Station	0.663	15.0	No
BCP1-CAF-F1-D2	Cafeteria	Handwash Station	<0.500	15.0	No
BCP1-KIT-F1-D1	Kitchen	Kitchen Sink (Tri-basin left)	<0.500	15.0	No
BCP1-KIT-F1-D2	Kitchen	Kitchen Sink (Tri-basin left)	<0.500	15.0	No
BCP1-KIT-F2-D1	Kitchen	Kitchen Sink (Tri-basin right)	0.877	15.0	No
BCP1-KIT-F2-D2	Kitchen	Kitchen Sink (Tri-basin right)	<0.500	15.0	No
BCP1-KIT-F3-D1	Kitchen	Kitchen Sink (Dual-basin)	<0.500	15.0	No
BCP1-KIT-F3-D2	Kitchen	Kitchen Sink (Dual-basin)	<0.500	15.0	No

**Sample was diluted by laboratory for analytical purposes. See laboratory analytical report for more information*

Table 3.2 Water Sampling Results - Belle Chasse Primary (Building 2 - Head Start)

Sample ID	Sample Location	Description	Result (µg/L)	Lead Action Level (µg/L)	Exceed? (Yes/No)
BCP2-RM1-F1-D1	Room 1	Classroom Faucet	1.67	15.0	No
BCP2-RM1-F1-D2	Room 1	Classroom Faucet	<0.500	15.0	No
BCP2-RM1BA1-F1-D1	Room 1 Bathroom (left)	Attached Bathroom Faucet	1	15.0	No
BCP2-RM1-BA1-F1-D2	Room 1 Bathroom (left)	Attached Bathroom Faucet	<0.500	15.0	No
BCP2-RM2-F1-D1	Room 2	Classroom Faucet	1.45	15.0	No
BCP2-RM2-F1-D2	Room 2	Classroom Faucet	0.5	15.0	No
BCP2-RM2-WC1-D1	Room 2	Water Cooler, Elkay	<0.500	15.0	No
BCP2-RM2-WC1-D2	Room 2	Water Cooler, Elkay	<0.500	15.0	No
BCP2-RM2BA1-F1-D1	Room 2 Bathroom	Attached Bathroom	1.35	15.0	No

Amended Water Sampling Report (Sampling Date 5/1/2021)

Belle Chasse Primary School
601 F. Edward Hebert Blvd., Belle Chasse, LA 70037

Report Date: 6/10/2021
MMG # 3921 LDH 38

Sample ID	Sample Location	Description	Result (µg/L)	Lead Action Level (µg/L)	Exceed? (Yes/No)
	(left)	Faucet			
BCP2-RM2BA1-F1-D2	Room 2 Bathroom (left)	Attached Bathroom Faucet	<0.500	15.0	No
BCP2-RM3-F1-D1	Room 3	Classroom Faucet	1.19	15.0	No
BCP2-RM3-F1-D2	Room 3	Classroom Faucet	0.613	15.0	No
BCP2-RM3BA1-F2-D1	Room 3 Bathroom (right)	Attached Bathroom Faucet	1.41	15.0	No
BCP2-RM3BA1-F2-D2	Room 3 Bathroom (right)	Attached Bathroom Faucet	0.509	15.0	No
BCP2-RM4-F1-D1	Room 4	Classroom Faucet	1.77	15.0	No
BCP2-RM4-F1-D2	Room 4	Classroom Faucet	0.676	15.0	No
BCP2-RM4BA1-F2-D1	Room 4 Bathroom (right)	Attached Bathroom Faucet	0.749	15.0	No
BCP2-RM4BA1-F2-D2	Room 4 Bathroom (right)	Attached Bathroom Faucet	<0.500	15.0	No
BCP2-RM5-WC1-D1	Room 5	Water Cooler, BRAND UNKNOWN	<0.500	15.0	No
BCP2-RM5-WC1-D2	Room 5	Water Cooler, BRAND UNKNOWN	<0.500	15.0	No

Table 3.3 Additional Water Sampling Results – Room 13 and Room 14

Sample ID	Sample Location	Description	Lead Result (µg/L)	Lead Action Level (µg/L)	Exceed? (Yes/No)
R-BCP1-RM13-F1-D1*	Room 13 (left)	Classroom Faucet	<25.0	15	Unknown
R-BCP1-RM13-F1-D2*	Room 13 (left)	Classroom Faucet	<2.50	15	No
R-BCP1-RM13-F2-D1*	Room 13 (right)	Classroom Faucet	<25.0	15	Unknown
R-BCP1-RM13-F2-D2*	Room 13 (right)	Classroom Faucet	<2.50	15	No
R-BCP1-RM14-F1-D1	Room 14 (left)	Classroom Faucet	1.87	15	No

Amended Water Sampling Report (Sampling Date 5/1/2021)**Belle Chasse Primary School
601 F. Edward Hebert Blvd., Belle Chasse, LA 70037****Report Date: 6/10/2021
MMG # 3921 LDH 38**

Sample ID	Sample Location	Description	Result (µg/L)	Lead Action Level (µg/L)	Exceed? (Yes/No)
R-BCP1-RM14-F1-D2	Room 14 (left)	Classroom Faucet	<0.500	15	No
R-BCP1-RM14-F2-D1	Room 14 (right)	Classroom Faucet	2.95	15	No
R-BCP1-RM14-F2-D2	Room 14 (right)	Classroom Faucet	<0.500	15	No

**Sample was diluted by laboratory for analytical purposes. See laboratory analytical report for more information.*

5.0 Recommendation(s) from LDH

At the request of LDH, MMG has included the following recommendation(s) in this report:

- LDH recommends a daily flushing practice (30-seconds) for the fixtures with a first draw lead sample result of 5 ug/L or greater (i.e., classroom 14 sinks).
- LDH advises against using the sinks in classroom 13 (art room) for drinking due to the unknown lead concentration. For classroom 13, the precise lead concentration could not be determined due to lab analysis interference caused by the presence of Bismuth (likely from the art supplies) in the samples.
- LDH advises against using bathroom sinks for drinking due to unsanitary conditions.

6.0 Signatures



C. Paul Lo, ScD

Principal Environmental Health Scientist & LDEQ Lead Project Designer

Appendices

Appendix A:	Sampling Maps
Appendix B:	Laboratory Report and Chain of Custody Documentation
Appendix C:	Laboratory Accreditations and Certifications
Appendix D:	Amended Laboratory Report and Chain of Custody Documentation

Water Sampling Report (Sampling Date: 5/1/2021)

Belle Chasse Primary School

601 F. Edward Hebert Blvd., Belle Chasse, LA 70037

Report Date: 5/21/2021

MMG # 3921 LDH 38


Appendix A: Sampling Maps

(Building 1)
Belle Chasse Primary School

HSWC1 & 2

Kinder-
garden
Wing

A



B


H4WC1 & 2

H6WC1 & 2


H7WC1 & 2

1st grade Wing

H8BA1



C



Room 2

Room 1

Rm 10

Rm 11

Rm 12

Rm 9

Rm 3

Rm 8

Rm 7

Rm 6

Rm 5

Rm 4

cafeteria

Kitchen

HALLWAY 1

HALLWAY 8

H1BA1

H1BA2

H1WC1 & 2

D

H2WC1 & 2

Pre-Kindergarten Wing

Bldg.
2

⊗ = water cooler location

Water Sampling Report (Sampling Date: 5/1/2021)

Belle Chasse Primary School

601 F. Edward Hebert Blvd., Belle Chasse, LA 70037

Report Date: 5/21/2021

MMG # 3921 LDH 38

**Appendix B: Laboratory Report and Chain of Custody
Documentation**

5/14/2021

Materials Management Group, Inc.
Dr. Paul Lo
2401 Westbend Parkway
Suite 3010
New Orleans, LA, 70141

Ref: Report Number: 21-123-0031
Project Description: Lead in H2O at Belle Chase Primary School
3921LDH-38

Dear Dr. Paul Lo:

Waypoint Analytical Louisiana, Inc. received sample(s) on 5/3/2021 for the analyses presented in the following report. The above referenced project has been analyzed per your instructions. Unless otherwise noted, the analyses were performed in our laboratory in accordance with Standard Methods, The Solid Waste Manual SW-846, EPA Methods for Chemical Analysis of Water and Wastes and /or 40 CFR part 136.

Certain parameters (chlorine, pH, dissolved oxygen, sulfite...) are required to be analyzed within 15 minutes of sampling. Usually, but not always, any field parameter analyzed at the laboratory is outside of this holding time. Refer to sample analysis time for confirmation of holding time compliance. Analyses reported which indicate "Field" for these parameters were analyzed by the client in the field. Results for solid samples are reported on an as received or "wet weight" basis unless otherwise specified.

The analytical data has been validated using standard quality control measures performed as required by the analytical method. Quality Assurance, method validations, instrumentation maintenance and calibration for all parameters (NELAP and non-NELAP) were performed in accordance with guidelines established by the USEPA (including 40 CFR 136 Method Update Rule August 2017) and NELAC unless otherwise indicated. Any parameter for which the laboratory is not officially NELAP accredited is indicated by a '~' symbol. These are not included in the scope because NELAP accreditation is either not available or has not been applied for. Additional certifications may be held/are available for parameters, where NELAP accreditation is not required or applicable. A full list of certifications is available upon request.

All quality control measures undertaken in accordance with Waypoint Analytical Louisiana, Inc. CompQAP990807A and revisions under the terms of the Louisiana Environmental Laboratory Accreditation Program (Certificate #02041) are within acceptance ranges established in that document with the exception of the items indicated and/or discussed in a Case Narrative.

The results are shown on the attached analysis sheet(s). Be aware that the time analyzed for certain samples (e.g. - BOD, CBOD, etc.) refer to the time the sample batch was begun and not necessarily to the time an individual sample was begun. Thank you for allowing Waypoint Analytical Louisiana, Inc. to serve you. Should I be of further assistance, if you have any questions or need additional information please contact me or client services.

Sincerely,



Anthony J. Albert
Laboratory Director

Laboratory's liability in any claim relating to analyses performed shall be limited to, at laboratory's option, repeating the analysis in question at laboratory's expense, or the refund of the charges paid for performance of said analysis. This report may be reproduced in full only with the written permission of the laboratory and/or the entity to which it is addressed. Results contained herein relate only to the sample(s) submitted to the laboratory.



Sample Summary Table

Report Number: 21-123-0031
Client Project Description: Lead in H2O at Belle Chase Primary Schoo
3921LDH-38

Lab No	Client Sample ID	Matrix	Date Collected	Date Received	Method	Lab ID
88849	BCP1-H1BA1-F1-D1	Aqueous	05/01/2021 08:34	05/03/2021	EPA-200.8 (DW)	WP MTN
88850	BCP1-H1BA1-F1-D2	Aqueous	05/01/2021 08:48	05/03/2021	EPA-200.8 (DW)	WP MTN
88851	BCP1-H1BA2-F1-D1	Aqueous	05/01/2021 08:35	05/03/2021	EPA-200.8 (DW)	WP MTN
88852	BCP1-H1BA2-F1-D2	Aqueous	05/01/2021 08:49	05/03/2021	EPA-200.8 (DW)	WP MTN
88853	BCP1-H1-WC1-D1	Aqueous	05/01/2021 08:35	05/03/2021	EPA-200.8 (DW)	WP MTN
88854	BCP1-H1-WC1-D2	Aqueous	05/01/2021 09:19	05/03/2021	EPA-200.8 (DW)	WP MTN
88855	BCP1-H1-WC2-D1	Aqueous	05/01/2021 08:35	05/03/2021	EPA-200.8 (DW)	WP MTN
88856	BCP1-H1-WC2-D2	Aqueous	05/01/2021 09:19	05/03/2021	EPA-200.8 (DW)	WP MTN
88857	BCP1-RM1-F1-D1	Aqueous	05/01/2021 08:37	05/03/2021	EPA-200.8 (DW)	WP MTN
88858	BCP1-RM1-F1-D2	Aqueous	05/01/2021 08:49	05/03/2021	EPA-200.8 (DW)	WP MTN
88859	BCP1-RM2-F1-D1	Aqueous	05/01/2021 08:36	05/03/2021	EPA-200.8 (DW)	WP MTN
88860	BCP1-RM2-F1-D2	Aqueous	05/01/2021 08:51	05/03/2021	EPA-200.8 (DW)	WP MTN
88861	BCP1-RM2-F2-D1	Aqueous	05/01/2021 08:37	05/03/2021	EPA-200.8 (DW)	WP MTN
88862	BCP1-RM2-F2-D2	Aqueous	05/01/2021 08:52	05/03/2021	EPA-200.8 (DW)	WP MTN
88863	BCP1-RM2-F3-D1	Aqueous	05/01/2021 08:38	05/03/2021	EPA-200.8 (DW)	WP MTN
88864	BCP1-RM2-F3-D2	Aqueous	05/01/2021 08:53	05/03/2021	EPA-200.8 (DW)	WP MTN
88865	BCP1-H2-WC1-D1	Aqueous	05/01/2021 08:37	05/03/2021	EPA-200.8 (DW)	WP MTN
88866	BCP1-H2-WC1-D2	Aqueous	05/01/2021 09:20	05/03/2021	EPA-200.8 (DW)	WP MTN
88867	BCP1-H2-WC2-D1	Aqueous	05/01/2021 08:37	05/03/2021	EPA-200.8 (DW)	WP MTN
88868	BCP1-H2-WC2-D2	Aqueous	05/01/2021 09:20	05/03/2021	EPA-200.8 (DW)	WP MTN
88869	BCP1-RM3-F1-D1	Aqueous	05/01/2021 08:40	05/03/2021	EPA-200.8 (DW)	WP MTN
88870	BCP1-RM3-F1-D2	Aqueous	05/01/2021 08:50	05/03/2021	EPA-200.8 (DW)	WP MTN
88871	BCP1-RM3-F2-D1	Aqueous	05/01/2021 08:40	05/03/2021	EPA-200.8 (DW)	WP MTN
88872	BCP1-RM3-F2-D2	Aqueous	05/01/2021 08:51	05/03/2021	EPA-200.8 (DW)	WP MTN
88873	BCP1-RM3-F3-D1	Aqueous	05/01/2021 08:39	05/03/2021	EPA-200.8 (DW)	WP MTN
88874	BCP1-RM3-F3-D2	Aqueous	05/01/2021 08:52	05/03/2021	EPA-200.8 (DW)	WP MTN

Sample Summary Table

Report Number: 21-123-0031
Client Project Description: Lead in H2O at Belle Chase Primary Schoo
3921LDH-38

Lab No	Client Sample ID	Matrix	Date Collected	Date Received	Method	Lab ID
88875	BCP1-RM4-F1-D1	Aqueous	05/01/2021 08:39	05/03/2021	EPA-200.8 (DW)	WP MTN
88876	BCP1-RM4-F1-D2	Aqueous	05/01/2021 08:55	05/03/2021	EPA-200.8 (DW)	WP MTN
88877	BCP1-RM4-F2-D1	Aqueous	05/01/2021 08:39	05/03/2021	EPA-200.8 (DW)	WP MTN
88878	BCP1-RM4-F2-D2	Aqueous	05/01/2021 08:55	05/03/2021	EPA-200.8 (DW)	WP MTN
88879	BCP1-RM4-F3-D1	Aqueous	05/01/2021 08:40	05/03/2021	EPA-200.8 (DW)	WP MTN
88880	BCP1-RM4-F3-D2	Aqueous	05/01/2021 08:56	05/03/2021	EPA-200.8 (DW)	WP MTN
88881	BCP1-RM5-F1-D1	Aqueous	05/01/2021 08:42	05/03/2021	EPA-200.8 (DW)	WP MTN
88882	BCP1-RM5-F1-D2	Aqueous	05/01/2021 08:53	05/03/2021	EPA-200.8 (DW)	WP MTN
88883	BCP1-RM5-F2-D1	Aqueous	05/01/2021 08:41	05/03/2021	EPA-200.8 (DW)	WP MTN
88884	BCP1-RM5-F2-D2	Aqueous	05/01/2021 08:54	05/03/2021	EPA-200.8 (DW)	WP MTN
88885	BCP1-RM5-F3-D1	Aqueous	05/01/2021 08:41	05/03/2021	EPA-200.8 (DW)	WP MTN
88886	BCP1-RM5-F3-D2	Aqueous	05/01/2021 08:55	05/03/2021	EPA-200.8 (DW)	WP MTN
88887	BCP1-RM6-F1-D1	Aqueous	05/01/2021 08:40	05/03/2021	EPA-200.8 (DW)	WP MTN
88888	BCP1-RM6-F1-D2	Aqueous	05/01/2021 08:57	05/03/2021	EPA-200.8 (DW)	WP MTN
88889	BCP1-RM6-F2-D1	Aqueous	05/01/2021 08:41	05/03/2021	EPA-200.8 (DW)	WP MTN
88890	BCP1-RM6-F2-D2	Aqueous	05/01/2021 08:57	05/03/2021	EPA-200.8 (DW)	WP MTN
88891	BCP1-RM6-F3-D1	Aqueous	05/01/2021 08:46	05/03/2021	EPA-200.8 (DW)	WP MTN
88892	BCP1-RM6-F3-D2	Aqueous	05/01/2021 08:56	05/03/2021	EPA-200.8 (DW)	WP MTN
88893	BCP1-RM7-F1-D1	Aqueous	05/01/2021 08:42	05/03/2021	EPA-200.8 (DW)	WP MTN
88894	BCP1-RM7-F1-D2	Aqueous	05/01/2021 08:56	05/03/2021	EPA-200.8 (DW)	WP MTN
88895	BCP1-RM7-F2-D1	Aqueous	05/01/2021 08:43	05/03/2021	EPA-200.8 (DW)	WP MTN
88896	BCP1-RM7-F2-D2	Aqueous	05/01/2021 08:57	05/03/2021	EPA-200.8 (DW)	WP MTN
88897	BCP1-RM7-F3-D1	Aqueous	05/01/2021 08:44	05/03/2021	EPA-200.8 (DW)	WP MTN
88898	BCP1-RM7-F3-D2	Aqueous	05/01/2021 08:57	05/03/2021	EPA-200.8 (DW)	WP MTN
88899	BCP1-RM8-F1-D1	Aqueous	05/01/2021 08:44	05/03/2021	EPA-200.8 (DW)	WP MTN
88900	BCP1-RM8-F1-D2	Aqueous	05/01/2021 09:00	05/03/2021	EPA-200.8 (DW)	WP MTN

Sample Summary Table

Report Number: 21-123-0031
Client Project Description: Lead in H2O at Belle Chase Primary Schoo
3921LDH-38

Lab No	Client Sample ID	Matrix	Date Collected	Date Received	Method	Lab ID
88901	BCP1-RM8-F2-D1	Aqueous	05/01/2021 08:44	05/03/2021	EPA-200.8 (DW)	WP MTN
88902	BCP1-RM8-F2-D2	Aqueous	05/01/2021 08:59	05/03/2021	EPA-200.8 (DW)	WP MTN
88903	BCP1-RM8-F3-D1	Aqueous	05/01/2021 08:45	05/03/2021	EPA-200.8 (DW)	WP MTN
88904	BCP1-RM8-F3-D2	Aqueous	05/01/2021 08:59	05/03/2021	EPA-200.8 (DW)	WP MTN
88905	BCP1-RM9-F1-D1	Aqueous	05/01/2021 08:42	05/03/2021	EPA-200.8 (DW)	WP MTN
88906	BCP1-RM9-F1-D2	Aqueous	05/01/2021 08:59	05/03/2021	EPA-200.8 (DW)	WP MTN
88907	BCP1-RM9-F2-D1	Aqueous	05/01/2021 08:42	05/03/2021	EPA-200.8 (DW)	WP MTN
88908	BCP1-RM9-F2-D2	Aqueous	05/01/2021 09:00	05/03/2021	EPA-200.8 (DW)	WP MTN
88909	BCP1-RM9-F3-D1	Aqueous	05/01/2021 08:42	05/03/2021	EPA-200.8 (DW)	WP MTN
88910	BCP1-RM9-F3-D2	Aqueous	05/01/2021 09:00	05/03/2021	EPA-200.8 (DW)	WP MTN
88911	BCP1-RM10-F1-D1	Aqueous	05/01/2021 08:41	05/03/2021	EPA-200.8 (DW)	WP MTN
88912	BCP1-RM10-F1-D2	Aqueous	05/01/2021 09:02	05/03/2021	EPA-200.8 (DW)	WP MTN
88913	BCP1-RM10-F2-D1	Aqueous	05/01/2021 08:41	05/03/2021	EPA-200.8 (DW)	WP MTN
88914	BCP1-RM10-F2-D2	Aqueous	05/01/2021 09:01	05/03/2021	EPA-200.8 (DW)	WP MTN
88915	BCP1-RM10-F3-D1	Aqueous	05/01/2021 08:41	05/03/2021	EPA-200.8 (DW)	WP MTN
88916	BCP1-RM10-F3-D2	Aqueous	05/01/2021 09:01	05/03/2021	EPA-200.8 (DW)	WP MTN
88917	BCP1-RM11-F1-D1	Aqueous	05/01/2021 08:40	05/03/2021	EPA-200.8 (DW)	WP MTN
88918	BCP1-RM11-F1-D2	Aqueous	05/01/2021 09:01	05/03/2021	EPA-200.8 (DW)	WP MTN
88919	BCP1-RM11-F2-D1	Aqueous	05/01/2021 08:40	05/03/2021	EPA-200.8 (DW)	WP MTN
88920	BCP1-RM11-F2-D2	Aqueous	05/01/2021 09:03	05/03/2021	EPA-200.8 (DW)	WP MTN
88921	BCP1-RM11-F3-D1	Aqueous	05/01/2021 08:41	05/03/2021	EPA-200.8 (DW)	WP MTN
88922	BCP1-RM11-F3-D2	Aqueous	05/01/2021 09:02	05/03/2021	EPA-200.8 (DW)	WP MTN
88923	BCP1-RM12-F1-D1	Aqueous	05/01/2021 08:39	05/03/2021	EPA-200.8 (DW)	WP MTN
88924	BCP1-RM12-F1-D2	Aqueous	05/01/2021 09:03	05/03/2021	EPA-200.8 (DW)	WP MTN
88925	BCP1-RM12-F2-D1	Aqueous	05/01/2021 08:39	05/03/2021	EPA-200.8 (DW)	WP MTN
88926	BCP1-RM12-F2-D2	Aqueous	05/01/2021 09:04	05/03/2021	EPA-200.8 (DW)	WP MTN

Sample Summary Table

Report Number: 21-123-0031
Client Project Description: Lead in H2O at Belle Chase Primary Schoo
3921LDH-38

Lab No	Client Sample ID	Matrix	Date Collected	Date Received	Method	Lab ID
88927	BCP1-RM12-F3-D1	Aqueous	05/01/2021 08:39	05/03/2021	EPA-200.8 (DW)	WP MTN
88928	BCP1-RM12-F3-D2	Aqueous	05/01/2021 09:05	05/03/2021	EPA-200.8 (DW)	WP MTN
88929	BCP1-RM13-F1-D1	Aqueous	05/01/2021 08:13	05/03/2021	EPA-200.8 (DW)	WP MTN
88930	BCP1-RM13-F1-D2	Aqueous	05/01/2021 08:14	05/03/2021	EPA-200.8 (DW)	WP MTN
88931	BCP1-RM13-F2-D1	Aqueous	05/01/2021 08:13	05/03/2021	EPA-200.8 (DW)	WP MTN
88932	BCP1-RM13-F2-D2	Aqueous	05/01/2021 08:14	05/03/2021	EPA-200.8 (DW)	WP MTN
88933	BCP1-RM14-F1-D1	Aqueous	05/01/2021 08:15	05/03/2021	EPA-200.8 (DW)	WP MTN
88934	BCP1-RM14-F1-D2	Aqueous	05/01/2021 08:16	05/03/2021	EPA-200.8 (DW)	WP MTN
88935	BCP1-RM14-F2-D1	Aqueous	05/01/2021 08:15	05/03/2021	EPA-200.8 (DW)	WP MTN
88936	BCP1-RM14-F2-D2	Aqueous	05/01/2021 08:16	05/03/2021	EPA-200.8 (DW)	WP MTN
88937	BCP1-H4-WC1-D1	Aqueous	05/01/2021 08:50	05/03/2021	EPA-200.8 (DW)	WP MTN
88938	BCP1-H4-WC1-D2	Aqueous	05/01/2021 09:10	05/03/2021	EPA-200.8 (DW)	WP MTN
88939	BCP1-H4-WC2-D1	Aqueous	05/01/2021 08:50	05/03/2021	EPA-200.8 (DW)	WP MTN
88940	BCP1-H4-WC2-D2	Aqueous	05/01/2021 09:10	05/03/2021	EPA-200.8 (DW)	WP MTN
88941	BCP1-RM15-F1-D1	Aqueous	05/01/2021 08:18	05/03/2021	EPA-200.8 (DW)	WP MTN
88942	BCP1-RM15-F1-D2	Aqueous	05/01/2021 08:19	05/03/2021	EPA-200.8 (DW)	WP MTN
88943	BCP1-RM16-F1-D1	Aqueous	05/01/2021 08:20	05/03/2021	EPA-200.8 (DW)	WP MTN
88944	BCP1-RM16-F1-D2	Aqueous	05/01/2021 08:21	05/03/2021	EPA-200.8 (DW)	WP MTN
88945	BCP1-RM17-F1-D1	Aqueous	05/01/2021 08:22	05/03/2021	EPA-200.8 (DW)	WP MTN
88946	BCP1-RM17-F1-D2	Aqueous	05/01/2021 08:23	05/03/2021	EPA-200.8 (DW)	WP MTN
88947	BCP1-RM18-F1-D1	Aqueous	05/01/2021 08:24	05/03/2021	EPA-200.8 (DW)	WP MTN
88948	BCP1-RM18-F1-D2	Aqueous	05/01/2021 08:25	05/03/2021	EPA-200.8 (DW)	WP MTN
88949	BCP1-RM19-F1-D1	Aqueous	05/01/2021 08:26	05/03/2021	EPA-200.8 (DW)	WP MTN
88950	BCP1-RM19-F1-D2	Aqueous	05/01/2021 08:27	05/03/2021	EPA-200.8 (DW)	WP MTN
88951	BCP1-RM20-F1-D1	Aqueous	05/01/2021 08:27	05/03/2021	EPA-200.8 (DW)	WP MTN
88952	BCP1-RM20-F1-D2	Aqueous	05/01/2021 08:28	05/03/2021	EPA-200.8 (DW)	WP MTN

Sample Summary Table

Report Number: 21-123-0031
Client Project Description: Lead in H2O at Belle Chase Primary Schoo
3921LDH-38

Lab No	Client Sample ID	Matrix	Date Collected	Date Received	Method	Lab ID
88953	BCP1-RM21-F1-D1	Aqueous	05/01/2021 08:29	05/03/2021	EPA-200.8 (DW)	WP MTN
88954	BCP1-RM21-F1-D2	Aqueous	05/01/2021 08:30	05/03/2021	EPA-200.8 (DW)	WP MTN
88955	BCP1-RM22-F1-D1	Aqueous	05/01/2021 08:32	05/03/2021	EPA-200.8 (DW)	WP MTN
88956	BCP1-RM22-F1-D2	Aqueous	05/01/2021 08:33	05/03/2021	EPA-200.8 (DW)	WP MTN
88957	BCP1-RM23-F1-D1	Aqueous	05/01/2021 08:33	05/03/2021	EPA-200.8 (DW)	WP MTN
88958	BCP1-RM23-F1-D2	Aqueous	05/01/2021 08:34	05/03/2021	EPA-200.8 (DW)	WP MTN
88959	BCP1-RM24-F1-D1	Aqueous	05/01/2021 08:35	05/03/2021	EPA-200.8 (DW)	WP MTN
88960	BCP1-RM24-F1-D2	Aqueous	05/01/2021 08:36	05/03/2021	EPA-200.8 (DW)	WP MTN
88961	BCP1-RM25-F1-D1	Aqueous	05/01/2021 08:37	05/03/2021	EPA-200.8 (DW)	WP MTN
88962	BCP1-RM25-F1-D2	Aqueous	05/01/2021 08:38	05/03/2021	EPA-200.8 (DW)	WP MTN
88963	BCP1-RM26-F1-D1	Aqueous	05/01/2021 08:51	05/03/2021	EPA-200.8 (DW)	WP MTN
88964	BCP1-RM26-F1-D2	Aqueous	05/01/2021 08:53	05/03/2021	EPA-200.8 (DW)	WP MTN
88965	BCP1-RM26-F2-D1	Aqueous	05/01/2021 08:51	05/03/2021	EPA-200.8 (DW)	WP MTN
88966	BCP1-RM26-F2-D2	Aqueous	05/01/2021 08:53	05/03/2021	EPA-200.8 (DW)	WP MTN
88967	BCP1-RM26-F3-D1	Aqueous	05/01/2021 08:51	05/03/2021	EPA-200.8 (DW)	WP MTN
88968	BCP1-RM26-F3-D2	Aqueous	05/01/2021 08:52	05/03/2021	EPA-200.8 (DW)	WP MTN
88969	BCP1-H6-WC1-D1	Aqueous	05/01/2021 08:15	05/03/2021	EPA-200.8 (DW)	WP MTN
88970	BCP1-H6-WC1-D2	Aqueous	05/01/2021 09:16	05/03/2021	EPA-200.8 (DW)	WP MTN
88971	BCP1-H6-WC2-D1	Aqueous	05/01/2021 08:15	05/03/2021	EPA-200.8 (DW)	WP MTN
88972	BCP1-H6-WC2-D2	Aqueous	05/01/2021 09:16	05/03/2021	EPA-200.8 (DW)	WP MTN
88973	BCP1-RM27-F1-D1	Aqueous	05/01/2021 08:16	05/03/2021	EPA-200.8 (DW)	WP MTN
88974	BCP1-RM27-F1-D2	Aqueous	05/01/2021 08:55	05/03/2021	EPA-200.8 (DW)	WP MTN
88975	BCP1-RM28-F1-D1	Aqueous	05/01/2021 08:16	05/03/2021	EPA-200.8 (DW)	WP MTN
88976	BCP1-RM28-F1-D2	Aqueous	05/01/2021 08:56	05/03/2021	EPA-200.8 (DW)	WP MTN
88977	BCP1-RM29-F1-D1	Aqueous	05/01/2021 08:17	05/03/2021	EPA-200.8 (DW)	WP MTN
88978	BCP1-RM29-F1-D2	Aqueous	05/01/2021 08:57	05/03/2021	EPA-200.8 (DW)	WP MTN

Sample Summary Table

Report Number: 21-123-0031
Client Project Description: Lead in H2O at Belle Chase Primary Schoo
3921LDH-38

Lab No	Client Sample ID	Matrix	Date Collected	Date Received	Method	Lab ID
88979	BCP1-RM30-F1-D1	Aqueous	05/01/2021 08:18	05/03/2021	EPA-200.8 (DW)	WP MTN
88980	BCP1-RM30-F1-D2	Aqueous	05/01/2021 08:58	05/03/2021	EPA-200.8 (DW)	WP MTN
88981	BCP1-RM31-F1-D1	Aqueous	05/01/2021 08:19	05/03/2021	EPA-200.8 (DW)	WP MTN
88982	BCP1-RM31-F1-D2	Aqueous	05/01/2021 08:59	05/03/2021	EPA-200.8 (DW)	WP MTN
88983	BCP1-H8BA1-F1-D1	Aqueous	05/01/2021 08:22	05/03/2021	EPA-200.8 (DW)	WP MTN
88984	BCP1-H8BA1-F1-D2	Aqueous	05/01/2021 08:59	05/03/2021	EPA-200.8 (DW)	WP MTN
88985	BCP1-RM32-F1-D1	Aqueous	05/01/2021 08:20	05/03/2021	EPA-200.8 (DW)	WP MTN
88986	BCP1-RM32-F1-D2	Aqueous	05/01/2021 09:00	05/03/2021	EPA-200.8 (DW)	WP MTN
88987	BCP1-RM33-F1-D1	Aqueous	05/01/2021 08:21	05/03/2021	EPA-200.8 (DW)	WP MTN
88988	BCP1-RM33-F1-D2	Aqueous	05/01/2021 09:00	05/03/2021	EPA-200.8 (DW)	WP MTN
88989	BCP1-RM34-F1-D1	Aqueous	05/01/2021 08:22	05/03/2021	EPA-200.8 (DW)	WP MTN
88990	BCP1-RM34-F1-D2	Aqueous	05/01/2021 08:58	05/03/2021	EPA-200.8 (DW)	WP MTN
88991	BCP1-RM35-F1-D1	Aqueous	05/01/2021 08:23	05/03/2021	EPA-200.8 (DW)	WP MTN
88992	BCP1-RM35-F1-D2	Aqueous	05/01/2021 08:57	05/03/2021	EPA-200.8 (DW)	WP MTN
88993	BCP1-RM36-F1-D1	Aqueous	05/01/2021 08:23	05/03/2021	EPA-200.8 (DW)	WP MTN
88994	BCP1-RM36-F1-D2	Aqueous	05/01/2021 08:56	05/03/2021	EPA-200.8 (DW)	WP MTN
88995	BCP1-RM37-F1-D1	Aqueous	05/01/2021 08:24	05/03/2021	EPA-200.8 (DW)	WP MTN
88996	BCP1-RM37-F1-D2	Aqueous	05/01/2021 08:55	05/03/2021	EPA-200.8 (DW)	WP MTN
88997	BCP1-CAF-F1-D1	Aqueous	05/01/2021 09:43	05/03/2021	EPA-200.8 (DW)	WP MTN
88998	BCP1-CAF-F1-D2	Aqueous	05/01/2021 09:44	05/03/2021	EPA-200.8 (DW)	WP MTN
88999	BCP1-KIT-F1-D1	Aqueous	05/01/2021 07:58	05/03/2021	EPA-200.8 (DW)	WP MTN
89000	BCP1-KIT-F1-D2	Aqueous	05/01/2021 08:49	05/03/2021	EPA-200.8 (DW)	WP MTN
89001	BCP1-KIT-F2-D1	Aqueous	05/01/2021 07:58	05/03/2021	EPA-200.8 (DW)	WP MTN
89002	BCP1-KIT-F2-D2	Aqueous	05/01/2021 08:50	05/03/2021	EPA-200.8 (DW)	WP MTN
89003	BCP1-KIT-F3-D1	Aqueous	05/01/2021 07:58	05/03/2021	EPA-200.8 (DW)	WP MTN
89004	BCP1-KIT-F3-D2	Aqueous	05/01/2021 08:50	05/03/2021	EPA-200.8 (DW)	WP MTN

Sample Summary Table

Report Number: 21-123-0031
Client Project Description: Lead in H2O at Belle Chase Primary Schoo
3921LDH-38

Lab No	Client Sample ID	Matrix	Date Collected	Date Received	Method	Lab ID
89005	BCP2-RM1-F1-D1	Aqueous	05/01/2021 09:43	05/03/2021	EPA-200.8 (DW)	WP MTN
89006	BCP2-RM1-F1-D2	Aqueous	05/01/2021 09:47	05/03/2021	EPA-200.8 (DW)	WP MTN
89007	BCP2-RM1BA1-F1-D1	Aqueous	05/01/2021 09:44	05/03/2021	EPA-200.8 (DW)	WP MTN
89008	BCP2-RM1BA1-F1-D2	Aqueous	05/01/2021 09:48	05/03/2021	EPA-200.8 (DW)	WP MTN
89009	BCP2-RM2-F1-D1	Aqueous	05/01/2021 09:43	05/03/2021	EPA-200.8 (DW)	WP MTN
89010	BCP2-RM2-F1-D2	Aqueous	05/01/2021 09:51	05/03/2021	EPA-200.8 (DW)	WP MTN
89011	BCP2-RM2-WC1-D1	Aqueous	05/01/2021 09:45	05/03/2021	EPA-200.8 (DW)	WP MTN
89012	BCP2-RM2-WC1-D2	Aqueous	05/01/2021 10:01	05/03/2021	EPA-200.8 (DW)	WP MTN
89013	BCP2-RM2BA1-F1-D1	Aqueous	05/01/2021 09:44	05/03/2021	EPA-200.8 (DW)	WP MTN
89014	BCP2-RM2BA1-F1-D2	Aqueous	05/01/2021 09:49	05/03/2021	EPA-200.8 (DW)	WP MTN
89015	BCP2-RM3-F1-D1	Aqueous	05/01/2021 09:45	05/03/2021	EPA-200.8 (DW)	WP MTN
89016	BCP2-RM3-F1-D2	Aqueous	05/01/2021 09:48	05/03/2021	EPA-200.8 (DW)	WP MTN
89017	BCP2-RM3BA1-F2-D1	Aqueous	05/01/2021 09:46	05/03/2021	EPA-200.8 (DW)	WP MTN
89018	BCP2-RM3BA1-F2-D2	Aqueous	05/01/2021 09:47	05/03/2021	EPA-200.8 (DW)	WP MTN
89019	BCP2-RM4-F1-D1	Aqueous	05/01/2021 09:45	05/03/2021	EPA-200.8 (DW)	WP MTN
89020	BCP2-RM4-F1-D2	Aqueous	05/01/2021 09:49	05/03/2021	EPA-200.8 (DW)	WP MTN
89021	BCP2-RM4BA1-F2-D1	Aqueous	05/01/2021 09:45	05/03/2021	EPA-200.8 (DW)	WP MTN
89022	BCP2-RM4BA1-F2-D2	Aqueous	05/01/2021 09:51	05/03/2021	EPA-200.8 (DW)	WP MTN
89023	BCP2-RM5-WC1-D1	Aqueous	05/01/2021 09:45	05/03/2021	EPA-200.8 (DW)	WP MTN
89024	BCP2-RM5-WC1-D1	Aqueous	05/01/2021 10:02	05/03/2021	EPA-200.8 (DW)	WP MTN



Client: Materials Management Group, Inc.
Project: Lead in H2O at Belle Chase Primary School
Lab Report Number: 21-123-0031
Date: 5/14/2021

CASE NARRATIVE

Metals Analyses Method EPA-200.8 (DW)

Sample 88929 (BCP1-RM13-F1-D1)

Analyte: Lead

QC Batch No: L552648/L551712

One or more Internal Standards are outside method acceptance criteria. Re-analysis and/or sample dilutions are required.

Sample 88930 (BCP1-RM13-F1-D2)

Analyte: Lead

QC Batch No: L552648/L551712

One or more Internal Standards are outside method acceptance criteria. Re-analysis and/or sample dilutions are required.

Sample 88931 (BCP1-RM13-F2-D1)

Analyte: Lead

QC Batch No: L552648/L551712

One or more Internal Standards are outside method acceptance criteria. Re-analysis and/or sample dilutions are required.

Sample 88932 (BCP1-RM13-F2-D2)

Analyte: Lead

QC Batch No: L552648/L551712

One or more Internal Standards are outside method acceptance criteria. Re-analysis and/or sample dilutions are required.

Sample 88933 (BCP1-RM14-F1-D1)

Analyte: Lead

QC Batch No: L552648/L551712

One or more Internal Standards are outside method acceptance criteria. Re-analysis and/or sample dilutions are required.

Sample 88935 (BCP1-RM14-F2-D1)

Analyte: Lead

QC Batch No: L552648/L551712

One or more Internal Standards are outside method acceptance criteria. Re-analysis and/or sample dilutions are required.

Sample 88929 (BCP1-RM13-F1-D1)

Analyte: Lead

QC Batch No: L553168/L551712

One or more Internal Standards are outside method acceptance criteria. Re-analysis and/or sample dilutions are required.

Sample 88931 (BCP1-RM13-F2-D1)

Analyte: Lead

QC Batch No: L553168/L551712

One or more Internal Standards are outside method acceptance criteria. Re-analysis and/or sample dilutions are required.

Summary of Detected Analytes

Project: Lead in H2O at Belle Chase Primary Schoo

Report Number: 21-123-0031

Client Sample ID	Lab Sample ID					
Method	Parameters	Result	Units	Report Limit	Analyzed	Qualifiers
BCP1-H1BA2-F1-D1	A 88851					
EPA-200.8 (DW)	Lead	0.704	µg/L	0.500	05/06/2021 17:10	
BCP1-RM2-F2-D1	A 88861					
EPA-200.8 (DW)	Lead	0.818	µg/L	0.500	05/06/2021 17:33	
BCP1-RM2-F3-D1	A 88863					
EPA-200.8 (DW)	Lead	1.80	µg/L	0.500	05/06/2021 17:37	
BCP1-RM2-F3-D2	A 88864					
EPA-200.8 (DW)	Lead	0.879	µg/L	0.500	05/06/2021 17:39	
BCP1-RM3-F1-D1	A 88869					
EPA-200.8 (DW)	Lead	0.901	µg/L	0.500	05/06/2021 18:04	
BCP1-RM3-F2-D1	A 88871					
EPA-200.8 (DW)	Lead	0.678	µg/L	0.500	05/06/2021 18:12	
BCP1-RM3-F3-D1	A 88873					
EPA-200.8 (DW)	Lead	0.711	µg/L	0.500	05/06/2021 18:16	
BCP1-RM4-F3-D1	A 88879					
EPA-200.8 (DW)	Lead	2.08	µg/L	0.500	05/06/2021 18:27	
BCP1-RM4-F3-D2	A 88880					
EPA-200.8 (DW)	Lead	0.516	µg/L	0.500	05/06/2021 18:29	
BCP1-RM5-F1-D1	A 88881					
EPA-200.8 (DW)	Lead	1.22	µg/L	0.500	05/06/2021 18:35	
BCP1-RM5-F3-D1	A 88885					
EPA-200.8 (DW)	Lead	0.936	µg/L	0.500	05/06/2021 18:42	
BCP1-RM6-F1-D1	A 88887					
EPA-200.8 (DW)	Lead	0.755	µg/L	0.500	05/06/2021 18:46	
BCP1-RM7-F3-D1	A 88897					
EPA-200.8 (DW)	Lead	0.708	µg/L	0.500	05/06/2021 19:25	
BCP1-RM10-F1-D1	A 88911					
EPA-200.8 (DW)	Lead	0.925	µg/L	0.500	05/06/2021 20:12	

Summary of Detected Analytes

Project: Lead in H2O at Belle Chase Primary Schoo

Report Number: 21-123-0031

Client Sample ID	Lab Sample ID					
Method	Parameters	Result	Units	Report Limit	Analyzed	Qualifiers
BCP1-RM10-F2-D1	A 88913					
EPA-200.8 (DW)	Lead	1.08	µg/L	0.500	05/06/2021 20:15	
BCP1-RM10-F3-D1	A 88915					
EPA-200.8 (DW)	Lead	0.695	µg/L	0.500	05/06/2021 20:19	
BCP1-RM11-F1-D1	A 88917					
EPA-200.8 (DW)	Lead	0.926	µg/L	0.500	05/06/2021 20:23	
BCP1-RM11-F2-D1	A 88919					
EPA-200.8 (DW)	Lead	1.28	µg/L	0.500	05/06/2021 20:31	
BCP1-RM11-F3-D1	A 88921					
EPA-200.8 (DW)	Lead	0.639	µg/L	0.500	05/06/2021 20:35	
BCP1-RM12-F1-D1	A 88923					
EPA-200.8 (DW)	Lead	1.39	µg/L	0.500	05/06/2021 20:39	
BCP1-RM12-F2-D1	A 88925					
EPA-200.8 (DW)	Lead	1.10	µg/L	0.500	05/06/2021 20:43	
BCP1-RM12-F3-D1	A 88927					
EPA-200.8 (DW)	Lead	0.863	µg/L	0.500	05/06/2021 20:46	
BCP1-RM14-F1-D1	A 88933					
EPA-200.8 (DW)	Lead	3.91	µg/L	2.50	05/12/2021 15:16	
BCP1-RM14-F1-D2	A 88934					
EPA-200.8 (DW)	Lead	1.41	µg/L	0.500	05/06/2021 21:06	
BCP1-RM14-F2-D1	A 88935					
EPA-200.8 (DW)	Lead	5.35	µg/L	2.50	05/12/2021 15:18	
BCP1-RM25-F1-D1	A 88961					
EPA-200.8 (DW)	Lead	1.80	µg/L	0.500	05/06/2021 22:21	
BCP1-RM26-F1-D1	A 88963					
EPA-200.8 (DW)	Lead	1.14	µg/L	0.500	05/06/2021 22:29	
BCP1-RM26-F2-D1	A 88965					
EPA-200.8 (DW)	Lead	0.856	µg/L	0.500	05/06/2021 22:33	

Summary of Detected Analytes

Project: Lead in H2O at Belle Chase Primary Schoo

Report Number: 21-123-0031

Client Sample ID	Lab Sample ID					
Method	Parameters	Result	Units	Report Limit	Analyzed	Qualifiers
BCP1-RM27-F1-D1	A 88973					
EPA-200.8 (DW)	Lead	0.628	µg/L	0.500	05/06/2021 22:53	
BCP1-H8BA1-F1-D1	A 88983					
EPA-200.8 (DW)	Lead	0.760	µg/L	0.500	05/11/2021 16:38	
BCP1-RM33-F1-D1	A 88987					
EPA-200.8 (DW)	Lead	0.509	µg/L	0.500	05/11/2021 16:50	
BCP1-CAF-F1-D1	A 88997					
EPA-200.8 (DW)	Lead	0.663	µg/L	0.500	05/11/2021 17:24	
BCP1-KIT-F2-D1	A 89001					
EPA-200.8 (DW)	Lead	0.877	µg/L	0.500	05/11/2021 17:37	
BCP2-RM1-F1-D1	A 89005					
EPA-200.8 (DW)	Lead	1.67	µg/L	0.500	05/11/2021 17:44	
BCP2-RM1BA1-F1-I	A 89007					
EPA-200.8 (DW)	Lead	1.00	µg/L	0.500	05/11/2021 17:48	
BCP2-RM2-F1-D1	A 89009					
EPA-200.8 (DW)	Lead	1.45	µg/L	0.500	05/11/2021 18:07	
BCP2-RM2-F1-D2	A 89010					
EPA-200.8 (DW)	Lead	0.500	µg/L	0.500	05/11/2021 18:09	
BCP2-RM2BA1-F1-I	A 89013					
EPA-200.8 (DW)	Lead	1.35	µg/L	0.500	05/11/2021 18:14	
BCP2-RM3-F1-D1	A 89015					
EPA-200.8 (DW)	Lead	1.19	µg/L	0.500	05/11/2021 18:23	
BCP2-RM3-F1-D2	A 89016					
EPA-200.8 (DW)	Lead	0.613	µg/L	0.500	05/11/2021 18:25	
BCP2-RM3BA1-F2-I	A 89017					
EPA-200.8 (DW)	Lead	1.41	µg/L	0.500	05/11/2021 18:27	
BCP2-RM3BA1-F2-I	A 89018					
EPA-200.8 (DW)	Lead	0.509	µg/L	0.500	05/11/2021 18:28	

Summary of Detected Analytes

Project: Lead in H2O at Belle Chase Primary Schoo

Report Number: 21-123-0031

Client Sample ID	Lab Sample ID					
Method	Parameters	Result	Units	Report Limit	Analyzed	Qualifiers
BCP2-RM4-F1-D1	A 89019					
EPA-200.8 (DW)	Lead	1.77	µg/L	0.500	05/11/2021 18:30	
BCP2-RM4-F1-D2	A 89020					
EPA-200.8 (DW)	Lead	0.676	µg/L	0.500	05/11/2021 18:32	
BCP2-RM4BA1-F2-I	A 89021					
EPA-200.8 (DW)	Lead	0.749	µg/L	0.500	05/11/2021 18:34	

5041 Taravella Road
Marrero, LA 70072

15 of 50

5041 Taravella Road
Marrero, LA 70072

16 of 50

5041 Taravella Road
Marrero, LA 70072

17 of 50

Waypoint Analytical - Louisiana, Inc.

5041 Taravella Road

Marrero, LA 70072

21-123-0031	BCP2-RM4BA1-F2-D2	Lead in H2O at Belle Chase Primary School	Waypoint ,	89022	Aqueous	5/1/2021 9:51	5/3/2021 0:00	5/11/2021 18:36	7439-92-1	Lead	<0.500	µg/L	1	0.5	EPA-200.8 (DW)
21-123-0031	BCP2-RM5-WC1-D1	Lead in H2O at Belle Chase Primary School	Waypoint ,	89023	Aqueous	5/1/2021 9:45	5/3/2021 0:00	5/11/2021 18:38	7439-92-1	Lead	<0.500	µg/L	1	0.5	EPA-200.8 (DW)
21-123-0031	BCP2-RM5-WC1-D1	Lead in H2O at Belle Chase Primary School	Waypoint ,	89024	Aqueous	5/1/2021 10:02	5/3/2021 0:00	5/11/2021 18:40	7439-92-1	Lead	<0.500	µg/L	1	0.5	EPA-200.8 (DW)

Quality Control Data

Client ID: Materials Management Group, Inc.
Project Description: Lead in H2O at Belle Chase Primary School
Report No: 21-123-0031

QC Prep: L551383 **QC Analytical Batch(es):** L551767
QC Prep Batch Method: EPA-200.8 **Analysis Method:** EPA-200.8 (DW)
Analysis Description: Metals Analyses

Lab Reagent Blank LRB-L551383 Matrix: AQU
Associated Lab Samples: 88868, 88869, 88870, 88871, 88872, 88873, 88874, 88875, 88876, 88877, 88878, 88879, 88880, 88881, 88882, 88883, 88884, 88885, 88886, 88887

Parameter	Units	Blank Result	MQL	Analyzed
Lead	µg/L	< 0.500	0.500	05/06/21 17:58

Laboratory Control Sample LCS-L551383

Parameter	Units	Spike Conc.	LCS Result	LCS %Rec	% Rec Limits
Lead	µg/L	50.0	48.0	96.0	85-115

Matrix Spike & Matrix Spike Duplicate A 88887-MS-L551383 A 88887-MSD-L551383

Parameter	Units	Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS %Rec	MSD %Rec	%Rec Limits	RPD	Max RPD
Lead	µg/L	0.755	50.3	50.3	49.4	49.5	97.0	97.0	70-130	0.2	20.0

Quality Control Data

Client ID: Materials Management Group, Inc.
Project Description: Lead in H2O at Belle Chase Primary School
Report No: 21-123-0031

QC Prep: L551386 **QC Analytical Batch(es):** L551767
QC Prep Batch Method: EPA-200.8 **Analysis Method:** EPA-200.8 (DW)
Analysis Description: Metals Analyses

Lab Reagent Blank LRB-L551386 Matrix: AQU
Associated Lab Samples: 88888, 88889, 88890, 88891, 88892, 88893, 88894, 88895, 88896, 88897, 88898, 88899, 88900, 88901, 88902, 88903, 88904, 88905, 88906, 88907

Parameter	Units	Blank Result	MQL	Analyzed
Lead	µg/L	< 0.500	0.500	05/06/21 19:00

Laboratory Control Sample LCS-L551386

Parameter	Units	Spike Conc.	LCS Result	LCS %Rec	% Rec Limits
Lead	µg/L	50.0	49.0	98.0	85-115

Matrix Spike & Matrix Spike Duplicate A 88907-MS-L551386 A 88907-MSD-L551386

Parameter	Units	Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS %Rec	MSD %Rec	%Rec Limits	RPD	Max RPD
Lead	µg/L	< 0.503	50.3	50.3	48.0	48.8	96.0	97.0	70-130	1.6	20.0

Quality Control Data

Client ID: Materials Management Group, Inc.
Project Description: Lead in H2O at Belle Chase Primary School
Report No: 21-123-0031

QC Prep: L551389 **QC Analytical Batch(es):** L551768
QC Prep Batch Method: EPA-200.8 **Analysis Method:** EPA-200.8 (DW)
Analysis Description: Metals Analyses

Lab Reagent Blank LRB-L551389 Matrix: AQU
Associated Lab Samples: 88908, 88909, 88910, 88911, 88912, 88913, 88914, 88915, 88916, 88917, 88918, 88919, 88920, 88921, 88922, 88923, 88924, 88925, 88926, 88927

Parameter	Units	Blank Result	MQL	Analyzed
Lead	µg/L	< 0.500	0.500	05/06/21 19:58

Laboratory Control Sample LCS-L551389

Parameter	Units	Spike Conc.	LCS Result	LCS %Rec	% Rec Limits
Lead	µg/L	50.0	49.2	98.0	85-115

Matrix Spike & Matrix Spike Duplicate A 88927-MS-L551389 A 88927-MSD-L551389

Parameter	Units	Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS %Rec	MSD %Rec	%Rec Limits	RPD	Max RPD
Lead	µg/L	0.863	50.3	50.3	49.4	48.5	97.0	95.0	70-130	1.8	20.0

Quality Control Data

Client ID: Materials Management Group, Inc.
Project Description: Lead in H2O at Belle Chase Primary School
Report No: 21-123-0031

QC Prep: L551392 **QC Analytical Batch(es):** L551768
QC Prep Batch Method: EPA-200.8 **Analysis Method:** EPA-200.8 (DW)
Analysis Description: Metals Analyses

Lab Reagent Blank LRB-L551392 Matrix: AQU
Associated Lab Samples: 88928, 88934, 88936, 88937, 88938, 88939, 88940, 88941, 88942, 88943, 88944, 88945, 88946, 88947, 88948, 88949, 88950, 88951, 88952, 88953

Parameter	Units	Blank Result	MQL	Analyzed
Lead	µg/L	< 0.500	0.500	05/06/21 21:00

Laboratory Control Sample LCS-L551392

Parameter	Units	Spike Conc.	LCS Result	LCS %Rec	% Rec Limits
Lead	µg/L	50.0	48.0	96.0	85-115

Matrix Spike & Matrix Spike Duplicate A 88953-MS-L551392 A 88953-MSD-L551392

Parameter	Units	Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS %Rec	MSD %Rec	%Rec Limits	RPD	Max RPD
Lead	µg/L	< 0.503	50.3	50.3	49.5	48.9	99.0	97.0	70-130	1.2	20.0

Quality Control Data

Client ID: Materials Management Group, Inc.
Project Description: Lead in H2O at Belle Chase Primary School
Report No: 21-123-0031

QC Prep: L551395 **QC Analytical Batch(es):** L551768
QC Prep Batch Method: EPA-200.8 **Analysis Method:** EPA-200.8 (DW)
Analysis Description: Metals Analyses

Lab Reagent Blank LRB-L551395 Matrix: AQU
Associated Lab Samples: 88954, 88955, 88956, 88957, 88958, 88959, 88960, 88961, 88962, 88963, 88964, 88965, 88966, 88967, 88968, 88969, 88970, 88971, 88972, 88973

Parameter	Units	Blank Result	MQL	Analyzed
Lead	µg/L	< 0.500	0.500	05/06/21 21:59

Laboratory Control Sample LCS-L551395

Parameter	Units	Spike Conc.	LCS Result	LCS %Rec	% Rec Limits
Lead	µg/L	50.0	48.6	97.0	85-115

Matrix Spike & Matrix Spike Duplicate A 88973-MS-L551395 A 88973-MSD-L551395

Parameter	Units	Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS %Rec	MSD %Rec	%Rec Limits	RPD	Max RPD
Lead	µg/L	0.628	50.3	50.3	48.4	48.8	95.0	96.0	70-130	0.8	20.0

Quality Control Data

Client ID: Materials Management Group, Inc.
Project Description: Lead in H2O at Belle Chase Primary School
Report No: 21-123-0031

QC Prep: L551452 **QC Analytical Batch(es):** L551767
QC Prep Batch Method: EPA-200.8 **Analysis Method:** EPA-200.8 (DW)
Analysis Description: Metals Analyses

Lab Reagent Blank LRB-L551452 Matrix: AQU
Associated Lab Samples: 88851, 88852, 88853, 88854, 88855, 88856, 88857, 88858, 88859, 88860, 88861, 88862, 88863, 88864, 88865, 88866, 88867

Parameter	Units	Blank Result	MQL	Analyzed
Lead	µg/L	< 0.500	0.500	05/06/21 17:06

Laboratory Control Sample LCS-L551452

Parameter	Units	Spike Conc.	LCS Result	LCS %Rec	% Rec Limits
Lead	µg/L	50.0	49.3	99.0	85-115

Matrix Spike & Matrix Spike Duplicate A 88867-MS-L551452 A 88867-MSD-L551452

Parameter	Units	Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS %Rec	MSD %Rec	%Rec Limits	RPD	Max RPD
Lead	µg/L	< 0.503	50.3	50.3	50.4	49.0	100	98.0	70-130	2.8	20.0

Quality Control Data

Client ID: Materials Management Group, Inc.
Project Description: Lead in H2O at Belle Chase Primary School
Report No: 21-123-0031

QC Prep: L551712 **QC Analytical Batch(es):** L552648,L553154
QC Prep Batch Method: EPA-200.8 **Analysis Method:** EPA-200.8 (DW)
Analysis Description: Metals Analyses

Lab Reagent Blank LRB-L551712 Matrix: AQU
Associated Lab Samples: 88849, 88850, 88929, 88930, 88931, 88932, 88933, 88935

Parameter	Units	Blank Result	MQL	Analyzed
Lead	µg/L	< 0.500	0.500	05/11/21 15:27

Laboratory Control Sample LCS-L551712

Parameter	Units	Spike Conc.	LCS Result	LCS %Rec	% Rec Limits
Lead	µg/L	50.0	50.3	101	85-115

Matrix Spike & Matrix Spike Duplicate A 88935-MS-L551712 A 88935-MSD-L551712

Parameter	Units	Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS %Rec	MSD %Rec	%Rec Limits	RPD	Max RPD
Lead	µg/L	5.35	50.0	50.0	51.3	50.8	92.0	91.0	70-130	0.9	20.0

Quality Control Data

Client ID: Materials Management Group, Inc.
Project Description: Lead in H2O at Belle Chase Primary School
Report No: 21-123-0031

QC Prep: L552110 **QC Analytical Batch(es):** L552648
QC Prep Batch Method: EPA-200.8 **Analysis Method:** EPA-200.8 (DW)
Analysis Description: Metals Analyses

Lab Reagent Blank LRB-L552110 Matrix: AQU
Associated Lab Samples: 88974, 88975, 88976, 88977, 88978, 88979, 88980, 88981, 88982, 88983, 88984, 88985, 88986, 88987, 88988

Parameter	Units	Blank Result	MQL	Analyzed
Lead	µg/L	< 0.500	0.500	05/11/21 16:04

Laboratory Control Sample LCS-L552110

Parameter	Units	Spike Conc.	LCS Result	LCS %Rec	% Rec Limits
Lead	µg/L	50.0	47.4	95.0	85-115

Matrix Spike & Matrix Spike Duplicate A 88988-MS-L552110 A 88988-MSD-L552110

Parameter	Units	Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS %Rec	MSD %Rec	%Rec Limits	RPD	Max RPD
Lead	µg/L	< 0.503	50.3	50.3	49.8	48.6	99.0	97.0	70-130	2.4	20.0

Quality Control Data

Client ID: Materials Management Group, Inc.
Project Description: Lead in H2O at Belle Chase Primary School
Report No: 21-123-0031

QC Prep: L552111 **QC Analytical Batch(es):** L552648
QC Prep Batch Method: EPA-200.8 **Analysis Method:** EPA-200.8 (DW)
Analysis Description: Metals Analyses

Lab Reagent Blank LRB-L552111 Matrix: AQU
Associated Lab Samples: 88989, 88990, 88991, 88992, 88993, 88994, 88995, 88996, 88997, 88998, 88999, 89000, 89001, 89002, 89003, 89004, 89005, 89006, 89007, 89008

Parameter	Units	Blank Result	MQL	Analyzed
Lead	µg/L	< 0.500	0.500	05/11/21 17:01

Laboratory Control Sample LCS-L552111

Parameter	Units	Spike Conc.	LCS Result	LCS %Rec	% Rec Limits
Lead	µg/L	50.0	48.3	97.0	85-115

Matrix Spike & Matrix Spike Duplicate A 89008-MS-L552111 A 89008-MSD-L552111

Parameter	Units	Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS %Rec	MSD %Rec	%Rec Limits	RPD	Max RPD
Lead	µg/L	< 0.503	50.3	50.3	49.5	49.1	99.0	98.0	70-130	0.8	20.0

Quality Control Data

Client ID: Materials Management Group, Inc.
Project Description: Lead in H2O at Belle Chase Primary School
Report No: 21-123-0031

QC Prep: L552112 **QC Analytical Batch(es):** L552648
QC Prep Batch Method: EPA-200.8 **Analysis Method:** EPA-200.8 (DW)
Analysis Description: Metals Analyses

Lab Reagent Blank LRB-L552112 Matrix: AQU
Associated Lab Samples: 89009, 89010, 89011, 89012, 89013, 89014, 89015, 89016, 89017, 89018, 89019, 89020, 89021, 89022, 89023, 89024

Parameter	Units	Blank Result	MQL	Analyzed
Lead	µg/L	< 0.500	0.500	05/11/21 18:03

Laboratory Control Sample LCS-L552112

Parameter	Units	Spike Conc.	LCS Result	LCS %Rec	% Rec Limits
Lead	µg/L	50.0	46.9	94.0	85-115

Matrix Spike & Matrix Spike Duplicate L 93908-MS-L552112 L 93908-MSD-L552112

Parameter	Units	Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS %Rec	MSD %Rec	%Rec Limits	RPD	Max RPD
Lead	µg/L	< 0.503	50.3	50.3	48.3	48.0	96.0	96.0	70-130	0.6	20.0

Shipment Receipt Form

Customer Number: **01266**

Customer Name: **Materials Management Group, Inc.**

Report Number: **21-123-0031**

Shipping Method

☐ Fed Ex	☐ US Postal	☐ Lab	☐ Other :	
☐ UPS	☒ Client	☐ Courier	Thermometer ID:	

Shipping container/cooler uncompromised?	☒ Yes	☐ No	
Number of coolers/boxes received	1		
Custody seals intact on shipping container/cooler?	☐ Yes	☐ No	☒ Not Present
Custody seals intact on sample bottles?	☐ Yes	☐ No	☒ Not Present
Chain of Custody (COC) present?	☒ Yes	☐ No	
COC agrees with sample label(s)?	☒ Yes	☐ No	
COC properly completed	☒ Yes	☐ No	
Samples in proper containers?	☒ Yes	☐ No	
Sample containers intact?	☒ Yes	☐ No	
Sufficient sample volume for indicated test(s)?	☒ Yes	☐ No	
All samples received within holding time?	☒ Yes	☐ No	
Cooler temperature in compliance?	☒ Yes	☐ No	
Cooler/Samples arrived at the laboratory on ice. Samples were considered acceptable as cooling process had begun.	☐ Yes	☒ No	
Water - Sample containers properly preserved	☒ Yes	☐ No	☐ N/A
Water - VOA vials free of headspace	☐ Yes	☐ No	☒ N/A
Trip Blanks received with VOAs	☐ Yes	☐ No	☒ N/A
Soil VOA method 5035 – compliance criteria met	☐ Yes	☐ No	☒ N/A
☐ High concentration container (48 hr)	☐ Low concentration EnCore samplers (48 hr)		
☐ High concentration pre-weighed (methanol -14 d)	☐ Low conc pre-weighed vials (Sod Bis -14 d)		
Special precautions or instructions included?	☐ Yes	☒ No	

Comments:

Signature:

Date & Time:

[illegible]

Pa: 1

Client Name/Address			Client Project Manager/Contact		Billing Information		For Laboratory Use Only			
Materials Management Group, Inc. 2401 Westbend Parkway, #3010 New Orleans, LA 70114			Erin LeCompte		miab@mmgnola.com					
Project Description Lead in H2O at Belle Chase Primary School			Project/Site Location (City/State) 601 F. Edward Hebert Blvd., Belle Chasse, LA 70037		☐ RUSH - Additional charges apply ☐ Special Detection Limit(s) Date Results Needed		Method of Shipment ☐ Fed Ex ☐ UPS ☐ USPS ☐ Courier ☐ Client Drop Off Other			
Project Number 3921LDH-38			Project Manager Phone # 504-368-0568		Project Manager Email erinl@mmgnola.com		Purchase Order Number 3921LDH-38			
 5041 Taravella Road Marrero, LA 70072 (504) 371-8560			Number of Containers Matrix (Refer to Key)		EPA 200.8 Lead		Site/Facility ID # A Cool < 10C Na2S2O3 (Micro Only) B Cool <= 6C C H2SO4 pH<2 D None Required E NaOH pH>10 F HNO3 pH<2 G HCL pH<2 H H3PO4 pH<2 I Cool <= 6C Na2S2O3			
Sample Identification			Required Analysis / Preservative		Comments/Notes					
Date	Time	BCP1-RM2-F1-D1	1	DW	1	6	1			08859
5/1/21	8:36	BCP1-RM2-F1-D2	1		1					08860
5/1/21	8:51	BCP1-RM2-F2-D1	1		1					08861
5/1/21	8:37	BCP1-RM2-F2-D2	1		1					08862
5/1/21	8:52	BCP1-RM2-F3-D1	1		1					08863
5/1/21	8:38	BCP1-RM2-F3-D2	1		1					08864
5/1/21	8:53	BCP1-H2-WC1-D1	1		1					08865
5/1/21	8:37	BCP1-H2-WC1-D2	1		1					08866
5/1/21	9:20	BCP1-H2-WC2-D1	1		1					08867
5/1/21	8:37	BCP1-H2-WC2-D2	1		1					08868
5/1/21	9:20	BCP1-H2-WC2-D2	1		1					08868
For Laboratory Use Only			Sampled by (Name - Print) Erin LeCompte		Client Remarks/Comments					
Ice	Custody	Seals	Lab Comments		Date		Time		Date	
Y/N	Y/N	Y/N			5/1/21		14:00		5-3-21 13:44	
Blank/Cooler Temp			Relinquished by: (SIGNATURE) E. LeCompte		Relinquished by: (SIGNATURE)		Date		Time	
N/A							Date		Time	
			Relinquished by: (SIGNATURE)		Relinquished by: (SIGNATURE)		Date		Time	

Client Name/Address			Client Project Manager/Contact		Billing Information		For Laboratory Use Only			
Materials Management Group, Inc. 2401 Westbend Parkway, #3010 New Orleans, LA 70114			Erin LeCompte		miab@mmgnola.com					
Project Description Lead in H2O at Belle Chase Primary School			Project/Site Location (City/State) 601 F. Edward Hebert Blvd., Belle Chasse, LA 70037		☐ RUSH - Additional charges apply ☐ Special Detection Limit(s) ☐ Date Results Needed		Method of Shipment ☐ Fed Ex ☐ UPS ☐ USPS ☐ Courier ☐ Client Drop Off Other			
Project Number 3921LDH-38			Project Manager Phone # 504-368-0568		Project Manager Email erinl@mmgnola.com		Purchase Order Number 3921LDH-38			
 5041 Taravella Road Marrero, LA 70072 (504) 371-8560			Sample Identification Unless noted, all containers per Table II of 40 CFR Part 136.		Matrix (Refer to Key)		Number of Containers		Required Analysis / Preservative EPA 200.8 Lead	
Date	Time	Sample Identification		Matrix (Refer to Key)		Number of Containers		Required Analysis / Preservative		Comments/Notes
5/1/21	8:40	BCP1-RM3-F1-D1		DW G		1				88869
5/1/21	8:50	BCP1-RM3-F1-D2		1		1				88870
5/1/21	8:40	BCP1-RM3-F2-D1		1		1				88871
5/1/21	8:51	BCP1-RM3-F2-D2		1		1				88872
5/1/21	8:39	BCP1-RM3-F3-D1		1		1				88873
5/1/21	8:52	BCP1-RM3-F3-D2		1		1				88874
5/1/21	8:39	BCP1-RM4-F1-D1		1		1				88875
5/1/21	8:55	BCP1-RM4-F1-D2		1		1				88876
5/1/21	8:39	BCP1-RM4-F2-D1		1		1				88877
5/1/21	8:55	BCP1-RM4-F2-D2		1		1				88878
Client Remarks/Comments										
For Laboratory Use Only				Sampled by (Name - Print) Erin LeCompte						
Ice Y/N		Custody Seals Y/N		Relinquished by: (SIGNATURE) E. LeCompte						
Blank/Cooler Temp		NA		Relinquished by: (SIGNATURE)						
				Date		Time		Received by: (SIGNATURE)		Date
				5/3/21		14:00		K. H. H. H. H.		5-3-21 13:45
				Date		Time		Received by: (SIGNATURE)		Date
				Date		Time		Received by: (SIGNATURE)		Date

Client Name/Address			Client Project Manager/Contact		Billing Information		For Laboratory Use Only			
Materials Management Group, Inc. 2401 Westbend Parkway, #3010 New Orleans, LA 70114			Erin LeCompte Project Manager/Contact		miab@mmgnola.com Billing Information		Method of Shipment ☐ Fed Ex ☐ UPS ☐ USPS ☐ Courier ☐ Client Drop Off Other			
Project Description Lead in H2O at Belle Chase Primary School			Project/Site Location (City/State) 601 F. Edward Hebert Blvd., Belle Chasse, LA 70037		RUSH - Additional charges apply ☐ Special Detection Limit(s) Date Results Needed		Matrix Key WW - Wastewater GW - Groundwater DW - Drinking Water S - Soil /Solid O - Oil P - Product M - Misc			
Project Number 3921LDH-38			Project Manager Phone # 504-368-0568		Project Manager Email erinl@mmgnola.com		Purchase Order Number 3921LDH-38			
 5041 Taravella Road Marrero, LA 70072 (504) 371-8560			Number of Containers 1		Matrix (Refer to Key) DW		EPA 200.8 Lead		Site/Facility ID # 3921LDH-38	
Sample Identification Unless noted, all containers per Table II of 40 CFR Part 136.			Date 5/1/21		Time 8:40		BCP1-RM4-F3-D1		Comments/Notes 88879	
			5/1/21		8:36		BCP1-RM4-F3-D2		88880	
			5/1/21		8:42		BCP1-RM5-F1-D1		88881	
			5/1/21		8:53		BCP1-RM5-F1-D2		88882	
			5/1/21		8:41		BCP1-RM5-F2-D1		88883	
			5/1/21		8:54		BCP1-RM5-F2-D2		88884	
			5/1/21		8:41		BCP1-RM5-F3-D1		88885	
			5/1/21		8:55		BCP1-RM5-F3-D2		88886	
			5/1/21		8:40		BCP1-RM6-F1-D1		88887	
			5/1/21		8:57		BCP1-RM6-F1-D2		88888	
For Laboratory Use Only Ice ☒ Custody Seals ☒ Lab Comments			Sampled by (Name - Print) Erin LeCompte		Client Remarks/Comments					
Relinquished by: (SIGNATURE) 			Date 5/3/14		Time 14:00		Received by: (SIGNATURE) 		Date 5-3-21	
Relinquished by: (SIGNATURE)			Date		Time		Received by: (SIGNATURE)		Date	
Relinquished by: (SIGNATURE)			Date		Time		Received by: (SIGNATURE)		Date	

Client Name/Address			Client Project Manager/Contact		Billing Information		For Laboratory Use Only			
Materials Management Group, Inc. 2401 Westbend Parkway, #3010 New Orleans, LA 70114			Erin LeCompte		miab@mmgnola.com					
Project Description Lead in H2O at Belle Chase Primary School			Project/Site Location (City/State) 601 F. Edward Hebert Blvd., Belle Chasse, LA 70037		☐ RUSH - Additional charges apply ☐ Special Detection Limit(s) ☐ Date Results Needed		Method of Shipment ☐ Fed Ex ☐ UPS ☐ USPS ☐ Courier ☐ Client Drop Off Other			
Project Number 3921LDH-38			Project Manager Phone # 504-368-0568		Project Manager Email erinl@mmgnola.com		Purchase Order Number 3921LDH-38			
 5041 Taravella Road Marrero, LA 70072 (504) 371-8560			Number of Containers Matrix (Refer to Key)		(Grab or Composite)		Required Analysis / Preservative			
Sample Identification Unless noted, all containers per Table II of 40 CFR Part 136.										
Date	Time	Sample Identification								
5/1/21	8:43	BCP1-RM7-F2-D1	1	DW	G	1				88895
5/1/21	8:57	BCP1-RM7-F2-D2	1			1				88896
5/1/21	8:44	BCP1-RM7-F3-D1								88897
5/1/21	8:57	BCP1-RM7-F3-D2								88898
5/1/21	8:44	BCP1-RM8-F1-D1								88899
5/1/21	9:00	BCP1-RM8-F1-D2								88900
5/1/21	8:44	BCP1-RM8-F2-D1								88901
5/1/21	8:59	BCP1-RM8-F2-D2								88902
5/1/21	8:45	BCP1-RM8-F3-D1								88903
5/1/21	8:59	BCP1-RM8-F3-D2								88904
For Laboratory Use Only			Sampled by (Name - Print) Erin LeCompte		Client Remarks/Comments					
Ice			Custody Seals		Lab Comments					
Y/N			Y/N							
Blank/Cooler Temp			N/A							
Relinquished by: (SIGNATURE) E. LeCompte			Relinquished by: (SIGNATURE) E. LeCompte		Relinquished by: (SIGNATURE) E. LeCompte		Received by: (SIGNATURE) Brandi Hidalgo			
Date			Time		Date		Time			
5/3/21			14:00		5-3-21		13:24			
Relinquished by: (SIGNATURE)			Relinquished by: (SIGNATURE)		Relinquished by: (SIGNATURE)		Received by: (SIGNATURE)			
Date			Time		Date		Time			

Client Name/Address			Client Project Manager/Contact		Billing Information		For Laboratory Use Only		
Materials Management Group, Inc. 2401 Westbend Parkway, #3010 New Orleans, LA 70114			Erin LeCompte		miab@mmgnola.com				
Project Description			Project/Site Location (City/State)		RUSH - Additional charges apply Special Detection Limit(s) Date Results Needed		Matrix Key		
Lead in H2O at Belle Chase Primary School			601 F. Edward Hebert Blvd., Belle Chasse, LA 70037		☐ RUSH ☐ Special Detection Limit(s) ☐ Date Results Needed		WW - Wastewater DW - Drinking Water S - Soil /Solid O - Oil P - Product M - Misc		
Project Number			Project Manager Phone #		Project Manager Email		Purchase Order Number		
3921LDH-38			504-368-0568		erinl@mmgnola.com		3921LDH-38		
 5041 Taravella Road Marrero, LA 70072 (504) 371-8560			Sample Identification		Matrix (Refer to Key)		Required Analysis / Preservative		
			Date	Time	Number of Containers	(Grab or Composite)	Comments/Notes		
5/1/21	8:42	BCP1-RM9-F1-D1	1	DW	1	1	1	1	88905
5/1/21	8:59	BCP1-RM9-F1-D2	1	1	1	1	1	1	88904
5/1/21	8:42	BCP1-RM9-F2-D1	1	1	1	1	1	1	88907
5/1/21	9:00	BCP1-RM9-F2-D2	1	1	1	1	1	1	88908
5/1/21	8:42	BCP1-RM9-F3-D1	1	1	1	1	1	1	88909
5/1/21	9:00	BCP1-RM9-F3-D2	1	1	1	1	1	1	88910
5/1/21	8:41	BCP1-RM10-F1-D1	1	1	1	1	1	1	88911
5/1/21	9:02	BCP1-RM10-F1-D2	1	1	1	1	1	1	88912
5/1/21	8:41	BCP1-RM10-F2-D1	1	1	1	1	1	1	88913
5/1/21	9:01	BCP1-RM10-F2-D2	1	1	1	1	1	1	88914
For Laboratory Use Only									
Ice		Custody Seals		Lab Comments					
Y/N		Y/N		Erin LeCompte					
Blank/Cooler Temp									
N/A									

Client Name/Address		Client Project Manager/Contact		Billing Information		For Laboratory Use Only	
Materials Management Group, Inc. 2401 Westbend Parkway, #3010 New Orleans, LA 70114		Erin LeCompte		miab@mmgnola.com			
Project Description Lead in H2O at Belle Chase Primary School		Project/Site Location (City/State) 601 F. Edward Hebert Blvd., Belle Chasse, LA 70037		☐ RUSH - Additional charges apply ☐ Special Detection Limit(s) Date Results Needed		Method of Shipment ☐ Fed Ex ☐ UPS ☐ USPS ☐ Courier ☐ Client Drop Off Other	
Project Number 3921LDH-38		Project Manager Phone # 504-368-0568		Project Manager Email erinl@mmgnola.com		Purchase Order Number 3921LDH-38	
 5041 Taravella Road Marrero, LA 70072 (504) 371-8560		Number of Containers Matrix (Refer to Key)		(Grab or Composite)		Required Analysis / Preservative	
Sample Identification Date Time		Unless noted, all containers per Table II of 40 CFR Part 136.		Matrix (Refer to Key)		Comments/Notes	
5/1/21	8:39	BCP1-RM12-F2-D1	1	DW	1		88925
5/1/21	9:04	BCP1-RM12-F2-D2	1		1		88926
5/1/21	8:39	BCP1-RM12-F3-D1	1		1		88927
5/1/21	9:05	BCP1-RM12-F3-D2	1		1		88928
5/1/21	8:13	BCP1-RM13-F1-D1	1		1		88929
5/1/21	8:14	BCP1-RM13-F1-D2	1		1		88930
5/1/21	8:13	BCP1-RM13-F2-D1	1		1		88931
5/1/21	8:14	BCP1-RM13-F2-D2	1		1		88932
5/1/21	8:15	BCP1-RM14-F1-D1	1		1		88933
5/1/21	8:16	BCP1-RM14-F1-D2	1		1		88934
Client Remarks/Comments							
Sampled by (Name - Print) Erin LeCompte							
Relinquished by: (SIGNATURE) 							
Relinquished by: (SIGNATURE) 							
Relinquished by: (SIGNATURE) 							
Date Time 5-3-21 13:44							
Date Time 5-3-21 13:44							
Date Time 5-3-21 13:44							

Client Name/Address		Client Project Manager/Contact		Billing Information		For Laboratory Use Only	
Materials Management Group, Inc. 2401 Westbend Parkway, #3010 New Orleans, LA 70114		Erin LeCompte		miab@mmgnola.com			
Project Description Lead in H2O at Belle Chase Primary School		Project/Site Location (City/State) 601 F. Edward Hebert Blvd., Belle Chasse, LA 70037		☐ RUSH - Additional charges apply ☐ Special Detection Limit(s) ☐ Date Results Needed		Method of Shipment ☐ Fed Ex ☐ UPS ☐ USPS ☐ Courier ☐ Client Drop Off Other	
Project Number 3921LDH-38		Project Manager Phone # 504-368-0568		Project Manager Email erinl@mmgnola.com		Site/Facility ID # 3921LDH-38	
 5041 Taravella Road Marrero, LA 70072 (504) 371-8560		Number of Containers 1		Matrix (Refer to Key) DW		Required Analysis / Preservative EPA 200.8 (G)rab or (C)omposite	
Sample Identification		Date		Time		Comments/Notes	
BCP1-RM14-F2-D1		5/1/21		8:15		88935	
BCP1-RM14-F2-D2		5/1/21		8:16		88936	
BCP1-H4-WC1-D1		5/1/21		8:50		88937	
BCP1-H4-WC1-D2		5/1/21		9:16		88938	
BCP1-H4-WC2-D1		5/1/21		8:50		88939	
BCP1-H4-WC2-D2		5/1/21		9:10		88940	
BCP1-RM15-F1-D1		5/1/21		8:18		88941	
BCP1-RM15-F1-D2		5/1/21		8:19		88942	
BCP1-RM16-F1-D1		5/1/21		8:20		88943	
BCP1-RM16-F1-D2		5/1/21		8:21		88944	
Client Remarks/Comments							
For Laboratory Use Only				Sampled by (Name - Print) Erin LeCompte			
Ice ✓		Custody Seals ✓		Lab Comments		Date 5-3-21	
Blank/Cooler Temp N/A				Relinquished by: (SIGNATURE) Erin LeCompte		Date 5-3-21	
				Relinquished by: (SIGNATURE)		Date	
				Relinquished by: (SIGNATURE)		Date	

Client Name/Address			Client Project Manager/Contact		Billing Information		For Laboratory Use Only				
Materials Management Group, Inc. 2401 Westbend Parkway, #3010 New Orleans, LA 70114			Erin LeCompte		miab@mmgnola.com						
Project Description Lead in H2O at Belle Chase Primary School			Project/Site Location (City/State) 601 F. Edward Hebert Blvd., Belle Chasse, LA 70037		☐ RUSH - Additional charges apply ☐ Special Detection Limit(s) Date Results Needed		Method of Shipment ☐ Fed Ex ☐ UPS ☐ USPS ☐ Courier ☐ Client Drop Off Other		Matrix Key WW - Wastewater GW - Groundwater DW - Drinking Water S - Soil /Solid O - Oil P - Product M - Misc		
Project Number 3921LDH-38			Project Manager Phone # 504-368-0568		Project Manager Email erinl@mmgnola.com		Purchase Order Number 3921LDH-38		Site/Facility ID #		
 5041 Taravella Road Marrero, LA 70072 (504) 371-8560			Number of Containers Matrix (Refer to Key)		EPA 200.8 LEAD				Comments/Notes A Cool < 10C Na2S2O3 (Micro Only) B Cool <= 6C C H2SO4 pH<2 D None Required E NaOH pH>10 F HNO3 pH<2 G HCL pH<2 H H3PO4 pH<2 I Cool <= 6C Na2S2O3		
Sample Identification			Required Analysis / Preservative		Required Analysis / Preservative		Required Analysis / Preservative		Required Analysis / Preservative		
Date	Time	Sample Identification	Number of Containers		Matrix (Refer to Key)		(G)rab or (C)omposite		Comments/Notes		
5/1/21	8:22	BCP1-RM17-F1-D1	1	DW							88945
5/1/21	8:23	BCP1-RM17-F1-D2									88946
5/1/21	8:24	BCP1-RM18-F1-D1									88947
5/1/21	8:25	BCP1-RM18-F1-D2									88948
5/1/21	—	BCP1-H5-WC1-D1									omit
5/1/21	—	BCP1-H5-WC1-D2									omit
5/1/21	—	BCP1-H5-WC2-D1									omit
5/1/21	—	BCP1-H5-WC2-D2									omit
5/1/21	8:26	BCP1-RM19-F1-D1									88949
5/1/21	8:27	BCP1-RM19-F1-D2									88950
For Laboratory Use Only			Lab Comments		Client Remarks/Comments						
Ice	Custody Seals	Blank/Cooler Temp		Sampled by (Name - Print) Erin LeCompte		Relinquished by: (SIGNATURE) E. LeCompte		Date		Time	
Y/N	Y/N	N/A						5/3 1400		5-3-21 13:44	
				Relinquished by: (SIGNATURE)		Relinquished by: (SIGNATURE)		Date		Time	
								Date		Time	
				Relinquished by: (SIGNATURE)		Relinquished by: (SIGNATURE)		Date		Time	

F 2 11

Client Name/Address			Client Project Manager/Contact		Billing Information		For Laboratory Use Only			
Materials Management Group, Inc. 2401 Westbend Parkway, #3010 New Orleans, LA 70114			Erin LeCompte		miab@mmgnola.com					
Project Description Lead in H2O at Belle Chase Primary School			Project/Site Location (City/State) 601 F. Edward Hebert Blvd., Belle Chasse, LA 70037		☐ RUSH - Additional charges apply ☐ Special Detection Limit(s) ☐ Date Results Needed		Method of Shipment ☐ Fed Ex ☐ UPS ☐ USPS ☐ Courier ☐ Client Drop Off Other			
Project Number 3921LDH-38			Project Manager Phone # 504-368-0568		Project Manager Email erinl@mmgnola.com		Purchase Order Number 3921LDH-38			
 5041 Taravella Road Marrero, LA 70072 (504) 371-8560			Number of Containers Matrix (Refer to Key)		(G)rab or (C)omposite EPA 200.8 LEAD		Required Analysis / Preservative Comments/Notes			
Sample Identification										
Date	Time									
5/1/21	8:27	BCP1-RM20-F1-D1	1	DW	6	1				88951
5/1/21	8:28	BCP1-RM20-F1-D2	1		1	1				88952
5/1/21	8:29	BCP1-RM21-F1-D1	1		1	1				88953
5/1/21	8:30	BCP1-RM21-F1-D2	1		1	1				88954
5/1/21	8:32	BCP1-RM22-F1-D1	1		1	1				88955
5/1/21	8:33	BCP1-RM22-F1-D2	1		1	1				88956
5/1/21	8:33	BCP1-RM23-F1-D1	1		1	1				88957
5/1/21	8:34	BCP1-RM23-F1-D2	1		1	1				88958
5/1/21	8:35	BCP1-Rm24-F1-D1	1		1	1				88959
5/1/21	8:36	BCP1-RM24-F1-D2	1		1	1				88960
For Laboratory Use Only			Sampled by (Name - Print) Erin LeCompte		Client Remarks/Comments					
Ice			Custody Seals		Lab Comments					
Y/N			Y/N							
Blank/Cooler Temp			N/A							
Relinquished by: (SIGNATURE) Erin LeCompte			Relinquished by: (SIGNATURE) Erin LeCompte		Relinquished by: (SIGNATURE) Erin LeCompte		Received by: (SIGNATURE) Erin LeCompte			
Date			Time		Date		Time			
5/3/21			14:00		5-3-21		13:44			
Date			Time		Date		Time			
Date			Time		Date		Time			

Client Name/Address		Client Project Manager/Contact		Billing Information		For Laboratory Use Only	
Materials Management Group, Inc. 2401 Westbend Parkway, #3010 New Orleans, LA 70114		Erin LeCompte		miab@mmgnola.com			
Project Description Lead in H2O at Belle Chase Primary School		Project/Site Location (City/State) 601 F. Edward Hebert Blvd., Belle Chasse, LA 70037		☐ RUSH - Additional charges apply ☐ Special Detection Limit(s) ☐ Date Results Needed		Method of Shipment ☐ Fed Ex ☐ UPS ☐ USPS ☐ Courier ☐ Client Drop Off Other	
Project Number 3921LDH-38		Project Manager Phone # 504-368-0568		Project Manager Email erinl@mmgnola.com		Site/Facility ID # 3921LDH-38	
 5041 Taravella Road Marrero, LA 70072 (504) 371-8560		Number of Containers Matrix (Refer to Key)		(Grab or Composite) EPA 200.8 LEAD		Required Analysis / Preservative Comments/Notes	
Sample Identification							
Date	Time	Sample Identification					
5/1/21	8:37	BCP1-RM25-F1-D1	1	DW G	1		88961
5/1/21	8:38	BCP1-RM25-F1-D2	1		1		88962
5/1/21	8:51	BCP1-RM26-F1-D1	1		1		not true 1st draw 88963
5/1/21	8:53	BCP1-RM26-F1-D2	1		1		88964
5/1/21	8:51	BCP1-RM26-F2-D1	1		1		88965
5/1/21	8:53	BCP1-RM26-F2-D2	1		1		88966
5/1/21	8:51	BCP1-RM26-F3-D1	1		1		not true 1st draw 88967
5/1/21	8:52	BCP1-RM26-F3-D2	1		1		88968
5/1/21	8:15	BCP1-H6-WC1-D1	1		1		88969
5/1/21	9:16	BCP1-H6-WC1-D2	1		1		88970
Ice		Custody Seals		Lab Comments		Client Remarks/Comments	
Y/N	Y/N	Y/N		Y/N		Y/N	
Blank/Cooler Temp		N/A		Y/N		Y/N	
Date		Time		Received by: (SIGNATURE)		Date	
5-3-21		13:44		Brandi Hildegar		5-3-21 13:44	
Date		Time		Received by: (SIGNATURE)		Date	
Date		Time		Received by: (SIGNATURE)		Date	

Client Name/Address		Client Project Manager/Contact		Billing Information		For Laboratory Use Only	
Materials Management Group, Inc. 2401 Westbend Parkway, #3010 New Orleans, LA 70114		Erin LeCompte		miab@mmgnola.com			
Project Description Lead in H2O at Belle Chase Primary School		Project/Site Location (City/State) 601 F. Edward Hebert Blvd., Belle Chasse, LA 70037		☐ RUSH - Additional charges apply ☐ Special Detection Limit(s) ☐ Date Results Needed		Method of Shipment ☐ Fed Ex ☐ UPS ☐ USPS ☐ Courier ☐ Client Drop Off Other	
Project Number 3921LDH-38		Project Manager Phone # 504-368-0568		Project Manager Email erinl@mmgnola.com		Site/Facility ID # 3921LDH-38	
 5041 Taravella Road Marrero, LA 70072 (504) 371-8560		Sample Identification Unless noted, all containers per Table II of 40 CFR Part 136.		Matrix (Refer to Key) Number of Containers (Grab or Composite)		Required Analysis / Preservative Comments/Notes	
Date	Time	Sample Identification					
5/1/21	8:15	BCP1-H6-WC2-D1		1	DW	1	88971
5/1/21	9:16	BCP1-H6-WC2-D2		1		1	88972
5/1/21	8:16	BCP1-RM27-F1-D1		1		1	88973
5/1/21	8:55	BCP1-RM27-F1-D2		1		1	88974
5/1/21	8:16	BCP1-RM28-F1-D1		1		1	88975
5/1/21	8:56	BCP1-RM28-F1-D2		1		1	88976
5/1/21	8:17	BCP1-RM29-F1-D1		1		1	88977
5/1/21	8:57	BCP1-RM29-F1-D2		1		1	88978
5/1/21	8:18	BCP1-RM30-F1-D1		1		1	88979
5/1/21	8:58	BCP1-RM30-F1-D2		1		1	88980
Ice		Custody Seals		Lab Comments		Client Remarks/Comments	
Y/N		Y/N					
Blank/Cooler Temp		N/A					
Relinquished by: (SIGNATURE)		Erin LeCompte		Received by: (SIGNATURE)		Date Time	
5/3/21		14:00		Brandi Hidalgo		5-3-21 13:44	
Relinquished by: (SIGNATURE)				Received by: (SIGNATURE)		Date Time	
Relinquished by: (SIGNATURE)				Received by: (SIGNATURE)		Date Time	

10c 14

Client Name/Address		Client Project Manager/Contact		Billing Information		For Laboratory Use Only	
Materials Management Group, Inc. 2401 Westbend Parkway, #3010 New Orleans, LA 70114		Erin LeCompte		miab@mmgnola.com			
Project Description Lead in H2O at Belle Chase Primary School		Project/Site Location (City/State) 601 F. Edward Hebert Blvd., Belle Chasse, LA 70037		☐ RUSH - Additional charges apply ☐ Special Detection Limit(s) Date Results Needed		Method of Shipment ☐ Fed Ex ☐ UPS ☐ USPS ☐ Courier ☐ Client Drop Off Other	
Project Number 3921LDH-38		Project Manager Phone # 504-368-0568		Project Manager Email erinl@mmgnola.com		Purchase Order Number 3921LDH-38	
 5041 Taravella Road Marrero, LA 70072 (504) 371-8560		Number of Containers Matrix (Refer to Key)		EPA 200.8 LEAD		Matrix Key WW - Wastewater GW - Groundwater DW - Drinking Water S - Soil /Solid O - Oil P - Product M - Misc	
Sample Identification		Required Analysis / Preservative		Comments/Notes			
Date	Time						
5/1/21	8:19	BCP1-H7-WC1-D1		omit			
5/1/21	8:19	BCP1-H7-WC1-D2		omit			
5/1/21	8:19	BCP1-H7-WC2-D1		omit			
5/1/21	8:19	BCP1-H7-WC2-D2		omit			
5/1/21	8:59	BCP1-RM31-F1-D1		88974-81			
5/1/21	8:59	BCP1-RM31-F1-D2		88982-2			
5/1/21	8:22	BCP1-H8BA1-F1-D1		88982-3			
5/1/21	8:59	BCP1-H8BA1-F1-D2		88982-4			
5/1/21	8:20	BCP1-RM32-F1-D1		88982-5			
5/1/21	9:00	BCP1-RM32-F1-D2		88982-6			
Ice		Custody Seals		Lab Comments		Client Remarks/Comments	
Y/N	Y/N			Erin LeCompte			
Blank/Cooler Temp		Relinquished by: (SIGNATURE)		Date		Time	
N/A		Erin LeCompte		5/3 1400		5-3-21 13:44	
		Relinquished by: (SIGNATURE)		Date		Time	
		Relinquished by: (SIGNATURE)		Date		Time	

gc 15

Client Name/Address				Client Project Manager/Contact		Billing Information		For Laboratory Use Only			
Materials Management Group, Inc. 2401 Westbend Parkway, #3010 New Orleans, LA 70114				Erin LeCompte		miab@mmgnola.com					
Project Description Lead in H2O at Belle Chase Primary School				Project/Site Location (City/State) 601 F. Edward Hebert Blvd., Belle Chasse, LA 70037		☐ RUSH - Additional charges apply ☐ Special Detection Limit(s) Date Results Needed		Method of Shipment ☐ Fed Ex ☐ USPS ☐ Client Drop Off ☐ Courier ☐ Other			
Project Number 3921LDH-38				Project Manager Phone # 504-368-0568		Project Manager Email erinl@mmgnola.com		Purchase Order Number 3921LDH-38			
 5041 Taravella Road Marrero, LA 70072 (504) 371-8560				Number of Containers Matrix (Refer to Key)		(Grab or Composite)		Required Analysis / Preservative			
Sample Identification Date Time				Unless noted, all containers per Table II of 40 CFR Part 136.				Comments/Notes			
5/1/21	8:21	BCP1-RM33-F1-D1		1	DW	1					889857
5/1/21	9:00	BCP1-RM33-F1-D2		1		1					889868
5/1/21	—	BCP1-EXT-B1-D1		—		—					omit
5/1/21	—	BCP1-EXT-B1-D2		—		—					omit
5/1/21	—	BCP1-EXT-B2-D1		—		—					omit
5/1/21	—	BCP1-EXT-B2-D2		—		—					omit
5/1/21	—	BCP1-EXT-B3-D1		—		—					omit
5/1/21	—	BCP1-EXT-B3-D2		—		—					omit
5/1/21	—	BCP1-EXT-B4-D1		—		—					omit
5/1/21	—	BCP1-EXT-B4-D2		—		—					omit
For Laboratory Use Only Ice Custody Seals Y/N Blank/Cooler Temp				Lab Comments Y/N		Sampled by (Name - Print) Erin LeCompte		Client Remarks/Comments			
Y/N		Y/N		Relinquished by: (SIGNATURE) C. S. S.		Relinquished by: (SIGNATURE) Brandi Hildegarde		Date Time 5-3-21 13:44		Date Time	
Y/N		Y/N		Relinquished by: (SIGNATURE)		Relinquished by: (SIGNATURE)		Date Time		Date Time	
Y/N		Y/N		Relinquished by: (SIGNATURE)		Relinquished by: (SIGNATURE)		Date Time		Date Time	

16

Client Name/Address		Client Project Manager/Contact		Billing Information		For Laboratory Use Only	
Materials Management Group, Inc. 2401 Westbend Parkway, #3010 New Orleans, LA 70114		Erin LeCompte		miab@mmgnola.com			
Project Description Lead in H2O at Belle Chase Primary School		Project/Site Location (City/State) 601 F. Edward Hebert Blvd., Belle Chasse, LA 70037		☐ RUSH - Additional charges apply ☐ Special Detection Limit(s) Date Results Needed		Method of Shipment ☐ Fed Ex ☐ UPS ☐ USPS ☐ Courier ☐ Client Drop Off Other	
Project Number 3921LDH-38		Project Manager Phone # 504-368-0568		Project Manager Email erinl@mmgnola.com		Purchase Order Number 3921LDH-38	
 5041 Taravella Road Marrero, LA 70072 (504) 371-8560		Number of Containers Matrix (Refer to Key)		Required Analysis / Preservative		Comments/Notes	
Sample Identification		Matrix (Refer to Key)		Required Analysis / Preservative		Comments/Notes	
Date	Time	Sample Identification	Matrix (Refer to Key)	Required Analysis / Preservative	Comments/Notes		
5/1/21	8:22	BCP1-RM34-F1-D1	DW G			08998X 9	
5/1/21	8:58	BCP1-RM34-F1-D2				88988 90	
5/1/21	8:23	BCP1-RM35-F1-D1				88989 91	
5/1/21	8:57	BCP1-RM35-F1-D2				88990 2	
5/1/21	8:23	BCP1-RM36-F1-D1				88991 3	
5/1/21	8:56	BCP1-RM36-F1-D2				88992 4	
5/1/21	8:24	BCP1-RM37-F1-D1				88993 5	
5/1/21	8:55	BCP1-RM37-F1-D2				88994 6	
5/1/21	9:43	BCP1-CAF-F1-D1				88995 7	
5/1/21	9:44	BCP1-CAF-F1-D2				88996 8	
Client Remarks/Comments							
Sampled by (Name - Print) Relinquished by: (SIGNATURE) Relinquished by: (SIGNATURE) Relinquished by: (SIGNATURE)							
Ice		Custody Seals		Date		Time	
Y/N		Y/N		5/3 1400		5-3-21 13:44	
Blank/Cooler Temp		n/a		Date		Time	
				Date		Time	

Client Name/Address		Client Project Manager/Contact		Billing Information		For Laboratory Use Only	
Materials Management Group, Inc. 2401 Westbend Parkway, #3010 New Orleans, LA 70114		Erin LeCompte		miab@mmgnola.com			
Project Description Lead in H2O at Belle Chase Primary School		Project/Site Location (City/State) 601 F. Edward Hebert Blvd., Belle Chasse, LA 70037		☐ RUSH - Additional charges apply ☐ Special Detection Limit(s) ☐ Date Results Needed		Method of Shipment ☐ Fed Ex ☐ UPS ☐ USPS ☐ Courier ☐ Client Drop Off ☐ Other	
Project Number 3921LDH-38		Project Manager Phone # 504-368-0568		Project Manager Email erinl@mmgnola.com		Purchase Order Number 3921LDH-38	
 5041 Taravella Road Marrero, LA 70072 (504) 371-8560		 Unless noted, all containers per Table II of 40 CFR Part 136.		Matrix (Refer to Key) Number of Containers (g)rab or (c)omposite		Required Analysis / Preservative Comments/Notes	
Date	Time	Sample Identification					
5/1/21	7:58	BCP1-KIT-F1-D1		1 DW G		889979	
5/1/21	8:49	BCP1-KIT-F1-D2		1		889998 89000	
5/1/21	7:58	BCP1-KIT-F2-D1		1		889999 89001	
5/1/21	8:50	BCP1-KIT-F2-D2		1		890002	
5/1/21	7:58	BCP1-KIT-F3-D1		1		890003	
5/1/21	8:50	BCP1-KIT-F3-D2		1		890004	
5/1/21	9:43	BCP2-RM1-F1-D1		1		890005	
5/1/21	9:47	BCP2-RM1-F1-D2		1		890006	
5/1/21	-	BCP2-RM1-WC1-D1		1		omit	
5/1/21	-	BCP2-RM1-WC1-D2		1		omit	
For Laboratory Use Only				Client Remarks/Comments			
Ice		Custody Seals		Sampled by (Name - Print)		Erin LeCompte	
Y/N		Y/N		Relinquished by: (SIGNATURE)		5/3 1400	
Blank/Cooler Temp		NA		Relinquished by: (SIGNATURE)		5-3-21 13:44	
				Relinquished by: (SIGNATURE)		Date Time	
				Relinquished by: (SIGNATURE)		Date Time	
				Relinquished by: (SIGNATURE)		Date Time	

Client Name/Address			Client Project Manager/Contact		Billing Information		For Laboratory Use Only			
Materials Management Group, Inc. 2401 Westbend Parkway, #3010 New Orleans, LA 70114			Erin LeCompte		miab@mmgnola.com					
Project Description Lead in H2O at Belle Chase Primary School			Project/Site Location (City/State) 601 F. Edward Hebert Blvd., Belle Chasse, LA 70037		☐ RUSH - Additional charges apply ☐ Special Detection Limit(s) ☐ Date Results Needed		Method of Shipment ☐ Fed Ex ☐ UPS ☐ USPS ☐ Courier ☐ Client Drop Off Other			
Project Number 3921LDH-38			Project Manager Phone # 504-368-0568		Project Manager Email erinl@mmgnola.com		Purchase Order Number 3921LDH-38			
 5041 Taravella Road Marrero, LA 70072 (504) 371-8560			Number of Containers Matrix (Refer to Key)		(G)rab or (C)omposite EPA 200.8 LEAD		Required Analysis / Preservative Comments/Notes			
Sample Identification										
Date	Time									
5/1/21	9:44	BCP2-RM1BA1-F1-D1	1 DW G		1		890057			
5/1/21	9:48	BCP2-RM1BA1-F1-D2	1		1		890058			
5/1/21	9:43	BCP2-RM2-F1-D1	1		1		890059			
5/1/21	9:51	BCP2-RM2-F1-D2	1		1		890060			
5/1/21	9:45	BCP2-RM2-WC1-D1	1		1		890061			
5/1/21	10:01	BCP2-RM2-WC1-D2	1		1		890062			
5/1/21	9:44	BCP2-RM2BA1-F1-D1	1		1		890063			
5/1/21	9:49	BCP2-RM2BA1-F1-D2	1		1		890064			
5/1/21	9:45	BCP2-RM3-F1-D1	1		1		890065			
5/1/21	9:48	BCP2-RM3-F1-D2	1		1		890066			
For Laboratory Use Only			Sampled by (Name - Print) Erin LeCompte		Client Remarks/Comments					
Ice			Custody Seals		Lab Comments					
Y/N			Y/N							
Blank/Cooler Temp			24							
Relinquished by: (SIGNATURE) E. LeCompte			Relinquished by: (SIGNATURE) Erin LeCompte		Received by: (SIGNATURE) Brandi Hildes		Date Time 5-3-21 13:44			
Relinquished by: (SIGNATURE)			Relinquished by: (SIGNATURE)		Received by: (SIGNATURE)		Date Time			
Relinquished by: (SIGNATURE)			Relinquished by: (SIGNATURE)		Received by: (SIGNATURE)		Date Time			

Client Name/Address		Client Project Manager/Contact		Billing Information		For Laboratory Use Only	
Materials Management Group, Inc. 2401 Westbend Parkway, #3010 New Orleans, LA 70114		Erin LeCompte		miab@mmgnola.com			
Project Description Lead in H2O at Belle Chase Primary School		Project/Site Location (City/State) 601 F. Edward Hebert Blvd., Belle Chasse, LA 70037		☐ RUSH - Additional charges apply ☐ Special Detection Limit(s) ☐ Date Results Needed		Method of Shipment ☐ Fed Ex ☐ UPS ☐ USPS ☐ Courier ☐ Client Drop Off Other	
Project Number 3921LDH-38		Project Manager Phone # 504-368-0568		Project Manager Email erinl@mmgnola.com		Site/Facility ID # 3921LDH-38	
 5041 Taravella Road Marrero, LA 70072 (504) 371-8560		Number of Containers Matrix (Refer to Key)		Required Analysis / Preservative (Grab or Composite)		Comments/Notes A Cool < 10C Na2S2O3 (Micro Only) B Cool <= 6C C H2SO4 pH<2 D None Required E NaOH pH>10 F HNO3 pH<2 G HCL pH<2 H H3PO4 pH<2 I Cool <= 6C Na2S2O3	
Sample Identification		Date		Time			
BCP2-RM3-WG1-D1		5/1/21		-		omit	
BCP2-RM3-WG1-D2		5/1/21		-		omit	
BCP2-RM3BA1-F2-D1		5/1/21		9:46		890187	
BCP2-RM3BA1-F2-D2		5/1/21		9:47		890188	
BCP2-RM4-F1-D1		5/1/21		9:45		890189	
BCP2-RM4-F1-D2		5/1/21		9:49		8901820	
BCP2-RM4-WCT-D1		5/1/21		-		omit	
BCP2-RM4-WCT-D2		5/1/21		-		omit	
BCP2-RM4BA1-F2-D1		5/1/21		9:45		8901921	
BCP2-RM4BA1-F2-D2		5/1/21		9:51		890202	
For Laboratory Use Only		Ice		Custody Seals		Lab Comments	
		Y/N		Y/N			
Blank/Cooler Temp		NA					
Sampled by (Name - Print)		Erin LeCompte		Relinquished by: (SIGNATURE)		Received by: (SIGNATURE)	
Date		5/3		Time		Date	
Time		1400		Date		Time	
Date		5-3-21		Date		Time	
Time		13:44		Date		Time	

[illegible]



6/9/2021 (REVISION DATE)

Materials Management Group, Inc.
Dr. Paul Lo
2401 Westbend Parkway
Suite 3010
New Orleans, LA, 70141

Ref: Revised Report Number: 21-141-9001 (Original Report 21-141-0001)
Project Description: Resample at Belle Chase Primary School

Dear Dr. Paul Lo:

Waypoint Analytical Louisiana, Inc. received sample(s) on 5/21/2021 for the analyses presented in the following report. The above referenced project has been analyzed per your instructions. Unless otherwise noted, the analyses were performed in our laboratory in accordance with Standard Methods, The Solid Waste Manual SW-846, EPA Methods for Chemical Analysis of Water and Wastes and /or 40 CFR part 136.

Certain parameters (chlorine, pH, dissolved oxygen, sulfite...) are required to be analyzed within 15 minutes of sampling. Usually, but not always, any field parameter analyzed at the laboratory is outside of this holding time. Refer to sample analysis time for confirmation of holding time compliance. Analyses reported which indicate "Field" for these parameters were analyzed by the client in the field. Results for solid samples are reported on an as received or "wet weight" basis unless otherwise specified.

The analytical data has been validated using standard quality control measures performed as required by the analytical method. Quality Assurance, method validations, instrumentation maintenance and calibration for all parameters (NELAP and non-NELAP) were performed in accordance with guidelines established by the USEPA (including 40 CFR 136 Method Update Rule August 2017) and NELAC unless otherwise indicated. Any parameter for which the laboratory is not officially NELAP accredited is indicated by a '~' symbol. These are not included in the scope because NELAP accreditation is either not available or has not been applied for. Additional certifications may be held/are available for parameters, where NELAP accreditation is not required or applicable. A full list of certifications is available upon request.

All quality control measures undertaken in accordance with Waypoint Analytical Louisiana, Inc. CompQAP990807A and revisions under the terms of the Louisiana Environmental Laboratory Accreditation Program (Certificate #02041) are within acceptance ranges established in that document with the exception of the items indicated and/or discussed in a Case Narrative.

The results are shown on the attached analysis sheet(s). Be aware that the time analyzed for certain samples (e.g. - BOD, CBOD, etc.) refer to the time the sample batch was begun and not necessarily to the time an individual sample was begun. Thank you for allowing Waypoint Analytical Louisiana, Inc. to serve you. Should I be of further assistance, if you have any questions or need additional information please contact me or client services.

Sincerely,

Anthony J. Albert
Laboratory Director

THIS REPORT HAS BEEN AMENDED TO SHOW THE ACTUAL VALUES OF THE RESULTS INSTEAD OF N.D. AS PER THE CLIENTS REQUEST. NO OTHER CHANGES WERE MADE.

Laboratory's liability in any claim relating to analyses performed shall be limited to, at laboratory's option, repeating the analysis in question at laboratory's expense, or the refund of the charges paid for performance of said analysis. This report may be reproduced in full only with the written permission of the laboratory and/or the entity to which it is addressed. Results contained herein relate only to the sample(s) submitted to the laboratory.



Certification Summary

Laboratory ID: WP MLA: Waypoint Analytical Louisiana, Inc., Marrero, LA

State	Program	Lab ID	Expiration Date
Georgia	State Program	02041	06/30/2021
Louisiana	State Program - NELAP	02041	06/30/2021

Laboratory ID: WP MTN: Waypoint Analytical, LLC., Memphis, TN

State	Program	Lab ID	Expiration Date
Alabama	State Program	40750	02/28/2022
Arkansas	State Program	88-0650	02/07/2022
California	State Program	2904	06/30/2021
Florida	State Program - NELAP	E871157	06/30/2021
Georgia	State Program	C044	02/18/2023
Georgia	State Program	04015	06/30/2021
Illinois	State Program - NELAP	200078	10/10/2021
Kentucky	State Program	80215	06/30/2021
Kentucky	State Program	KY90047	12/31/2021
Louisiana	State Program - NELAP	LA037	12/31/2021
Louisiana	State Program - NELAP	04015	06/30/2021
Mississippi	State Program	MS	02/11/2023
North Carolina	State Program	415	12/31/2021
Oklahoma	State Program	9311	08/31/2021
Pennsylvania	State Program - NELAP	68-03195	05/31/2022
South Carolina	State Program	84002	06/30/2021
South Carolina	State Program	84002	06/30/2021
Tennessee	State Program	02027	02/11/2023
Tennessee	A2LA ISO 17025:2017	4313.01	10/31/2021
Texas	State Program - NELAP	T104704180	09/30/2021
Virginia	State Program	00106	06/30/2021
Virginia	State Program - NELAP	460181	09/14/2021

Sample Summary Table

Report Number: 21-141-9001

Client Project Description: Resample at Belle Chase Primary School

Lab No	Client Sample ID	Matrix	Date Collected	Date Received	Method	Lab ID
89791	R-BCP1-RM13-F1-D1	Aqueous	05/21/2021 05:55	05/21/2021	EPA-200.7 (MISC)	WP MTN
89791	R-BCP1-RM13-F1-D1	Aqueous	05/21/2021 05:55	05/21/2021	EPA-200.8 (DW)	WP MTN
89792	R-BCP1-RM13-F1-D2	Aqueous	05/21/2021 05:56	05/21/2021	EPA-200.7 (MISC)	WP MTN
89792	R-BCP1-RM13-F1-D2	Aqueous	05/21/2021 05:56	05/21/2021	EPA-200.8 (DW)	WP MTN
89793	R-BCP1-RM13-F2-D1	Aqueous	05/21/2021 05:56	05/21/2021	EPA-200.8 (DW)	WP MTN
89793	R-BCP1-RM13-F2-D1	Aqueous	05/21/2021 05:56	05/21/2021	EPA-200.7 (MISC)	WP MTN
89794	R-BCP1-RM13-F2-D2	Aqueous	05/21/2021 05:57	05/21/2021	EPA-200.7 (MISC)	WP MTN
89794	R-BCP1-RM13-F2-D2	Aqueous	05/21/2021 05:57	05/21/2021	EPA-200.8 (DW)	WP MTN
89795	R-BCP1-RM14-F1-D1	Aqueous	05/21/2021 05:59	05/21/2021	EPA-200.8 (DW)	WP MTN
89796	R-BCP1-RM14-F1-D2	Aqueous	05/21/2021 06:00	05/21/2021	EPA-200.8 (DW)	WP MTN
89797	R-BCP1-RM14-F2-D1	Aqueous	05/21/2021 06:00	05/21/2021	EPA-200.8 (DW)	WP MTN
89798	R-BCP1-RM14-F2-D2	Aqueous	05/21/2021 06:01	05/21/2021	EPA-200.8 (DW)	WP MTN



Client: Materials Management Group, Inc.
Project: Resample at Belle Chase Primary School
Lab Report Number: 21-141-9001
Date: 06/09/2021 (REVISION DATE)

CASE NARRATIVE

Metals Analyses Method EPA-200.8 (DW)

Sample 89791 (R-BCP1-RM13-F1-D1)

Analyte: Lead

QC Batch No: L555217/L554819

One or more Internal Standards are outside method acceptance criteria. Re-analysis and/or sample dilutions are required.

Sample 89792 (R-BCP1-RM13-F1-D2)

Analyte: Lead

QC Batch No: L555217/L554819

One or more Internal Standards are outside method acceptance criteria. Re-analysis and/or sample dilutions are required.

Sample 89793 (R-BCP1-RM13-F2-D1)

Analyte: Lead

QC Batch No: L555217/L554819

One or more Internal Standards are outside method acceptance criteria. Re-analysis and/or sample dilutions are required.

Sample 89794 (R-BCP1-RM13-F2-D2)

Analyte: Lead

QC Batch No: L555217/L554819

One or more Internal Standards are outside method acceptance criteria. Re-analysis and/or sample dilutions are required.

Summary of Detected Analytes

Project: Resample at Belle Chase Primary School

Report Number: 21-141-9001

Client Sample ID Method	Lab Sample ID Parameters	Result	Units	Report Limit	Analyzed	Qualifiers
R-BCP1-RM13-F1-D	A 89791					
EPA-200.7 (MISC)	Bismuth	0.106	mg/L	0.010	06/01/2021 11:43	
R-BCP1-RM13-F1-D	A 89792					
EPA-200.7 (MISC)	Bismuth	0.019	mg/L	0.010	06/01/2021 11:47	
R-BCP1-RM13-F2-D	A 89793					
EPA-200.7 (MISC)	Bismuth	0.149	mg/L	0.010	06/01/2021 11:55	
R-BCP1-RM13-F2-D	A 89794					
EPA-200.7 (MISC)	Bismuth	0.011	mg/L	0.010	06/01/2021 11:51	
R-BCP1-RM14-F1-D	A 89795					
EPA-200.8 (DW)	Lead	1.87	µg/L	0.500	05/25/2021 10:46	
R-BCP1-RM14-F2-D	A 89797					
EPA-200.8 (DW)	Lead	2.95	µg/L	0.500	05/25/2021 10:54	

01266

Materials Management Group, Inc.
Dr. Paul Lo
2401 Westbend Parkway
Suite 3010
New Orleans , LA 70141

Project Resample at Belle Chase Primary School
Information :

Original Report Date : 06/02/2021
Revised Report Date: 06/09/2021
Received : 05/21/2021

Report Number : **21-141-9001**

REPORT OF ANALYSIS

Lab No : **89791**

Matrix: **Aqueous**

Sample ID : **R-BCP1-RM13-F1-D1**

Sampled: **5/21/2021 5:55**

Test	Results	Units	MQL	DF	Date / Time Analyzed	By	Analytical Method
Bismuth	0.106	mg/L	0.010	1	06/01/21 11:43	JTR	EPA-200.7 (MISC)
Lead	<25.0	µg/L	25.0	50	05/25/21 14:36	BKN	EPA-200.8 (DW)

**Qualifiers/
Definitions**

DF Dilution Factor
MQL Method Quantitation Limit

L Limit Exceeded

01266

Materials Management Group, Inc.
Dr. Paul Lo
2401 Westbend Parkway
Suite 3010
New Orleans , LA 70141

Project Resample at Belle Chase Primary School
Information :

Original Report Date : 06/02/2021
Revised Report Date: 06/09/2021
Received : 05/21/2021

Report Number : **21-141-9001**

REPORT OF ANALYSIS

Lab No : **89792**

Matrix: **Aqueous**

Sample ID : **R-BCP1-RM13-F1-D2**

Sampled: **5/21/2021 5:56**

Test	Results	Units	MQL	DF	Date / Time Analyzed	By	Analytical Method
Bismuth	0.019	mg/L	0.010	1	06/01/21 11:47	JTR	EPA-200.7 (MISC)
Lead	<2.50	µg/L	2.50	5	05/25/21 13:54	BKN	EPA-200.8 (DW)

**Qualifiers/
Definitions**

DF Dilution Factor
MQL Method Quantitation Limit

L Limit Exceeded

01266

Materials Management Group, Inc.
Dr. Paul Lo
2401 Westbend Parkway
Suite 3010
New Orleans , LA 70141

Project Resample at Belle Chase Primary School
Information :

Original Report Date : 06/02/2021
Revised Report Date: 06/09/2021
Received : 05/21/2021

Report Number : **21-141-9001**

REPORT OF ANALYSIS

Lab No : **89793**

Matrix: **Aqueous**

Sample ID : **R-BCP1-RM13-F2-D1**

Sampled: **5/21/2021 5:56**

Test	Results	Units	MQL	DF	Date / Time Analyzed	By	Analytical Method
Bismuth	0.149	mg/L	0.010	1	06/01/21 11:55	JTR	EPA-200.7 (MISC)
Lead	<25.0	µg/L	25.0	50	05/25/21 14:40	BKN	EPA-200.8 (DW)

**Qualifiers/
Definitions**

DF Dilution Factor
MQL Method Quantitation Limit

L Limit Exceeded

01266

Materials Management Group, Inc.
Dr. Paul Lo
2401 Westbend Parkway
Suite 3010
New Orleans , LA 70141

Project Resample at Belle Chase Primary School
Information :

Original Report Date : 06/02/2021
Revised Report Date: 06/09/2021
Received : 05/21/2021

Report Number : **21-141-9001**

REPORT OF ANALYSIS

Lab No : **89794**

Matrix: **Aqueous**

Sample ID : **R-BCP1-RM13-F2-D2**

Sampled: **5/21/2021 5:57**

Test	Results	Units	MQL	DF	Date / Time Analyzed	By	Analytical Method
Bismuth	0.011	mg/L	0.010	1	06/01/21 11:51	JTR	EPA-200.7 (MISC)
Lead	<2.50	µg/L	2.50	5	05/25/21 13:58	BKN	EPA-200.8 (DW)

Qualifiers/ Definitions

DF Dilution Factor
MQL Method Quantitation Limit

L Limit Exceeded

01266

Materials Management Group, Inc.
Dr. Paul Lo
2401 Westbend Parkway
Suite 3010
New Orleans , LA 70141

Project Resample at Belle Chase Primary School
Information :

Original Report Date : 06/02/2021
Revised Report Date: 06/09/2021
Received : 05/21/2021

Report Number : **21-141-9001**

REPORT OF ANALYSIS

Lab No : **89795**

Matrix: **Aqueous**

Sample ID : **R-BCP1-RM14-F1-D1**

Sampled: **5/21/2021 5:59**

Test	Results	Units	MQL	DF	Date / Time Analyzed	By	Analytical Method
Lead	1.87	µg/L	0.500	1	05/25/21 10:46	BKN	EPA-200.8 (DW)

**Qualifiers/
Definitions**

DF Dilution Factor
MQL Method Quantitation Limit

L Limit Exceeded

01266

Materials Management Group, Inc.
Dr. Paul Lo
2401 Westbend Parkway
Suite 3010
New Orleans , LA 70141

Project Resample at Belle Chase Primary School
Information :

Original Report Date : 06/02/2021
Revised Report Date: 06/09/2021
Received : 05/21/2021

Report Number : **21-141-9001**

REPORT OF ANALYSIS

Lab No : **89796**

Matrix: **Aqueous**

Sample ID : **R-BCP1-RM14-F1-D2**

Sampled: **5/21/2021 6:00**

Test	Results	Units	MQL	DF	Date / Time Analyzed	By	Analytical Method
Lead	<0.500	µg/L	0.500	1	05/25/21 10:48	BKN	EPA-200.8 (DW)

**Qualifiers/
Definitions**

DF Dilution Factor
MQL Method Quantitation Limit

L Limit Exceeded

01266

Materials Management Group, Inc.
Dr. Paul Lo
2401 Westbend Parkway
Suite 3010
New Orleans , LA 70141

Project Resample at Belle Chase Primary School
Information :

Original Report Date : 06/02/2021
Revised Report Date: 06/09/2021
Received : 05/21/2021

Report Number : **21-141-9001**

REPORT OF ANALYSIS

Lab No : **89797**

Matrix: **Aqueous**

Sample ID : **R-BCP1-RM14-F2-D1**

Sampled: **5/21/2021 6:00**

Test	Results	Units	MQL	DF	Date / Time Analyzed	By	Analytical Method
Lead	2.95	µg/L	0.500	1	05/25/21 10:54	BKN	EPA-200.8 (DW)

**Qualifiers/
Definitions**

DF Dilution Factor
MQL Method Quantitation Limit

L Limit Exceeded

01266

Materials Management Group, Inc.
Dr. Paul Lo
2401 Westbend Parkway
Suite 3010
New Orleans , LA 70141

Project Resample at Belle Chase Primary School
Information :

Original Report Date : 06/02/2021
Revised Report Date: 06/09/2021
Received : 05/21/2021

Report Number : **21-141-9001**

REPORT OF ANALYSIS

Lab No : **89798**

Matrix: **Aqueous**

Sample ID : **R-BCP1-RM14-F2-D2**

Sampled: **5/21/2021 6:01**

Test	Results	Units	MQL	DF	Date / Time Analyzed	By	Analytical Method
Lead	<0.500	µg/L	0.500	1	05/25/21 10:56	BKN	EPA-200.8 (DW)

**Qualifiers/
Definitions**

DF Dilution Factor
MQL Method Quantitation Limit

L Limit Exceeded

Quality Control Data

Client ID: Materials Management Group, Inc.
Project Description: Resample at Belle Chase Primary School
Report No: 21-141-9001

QC Prep: L555596 **QC Analytical Batch(es):** L556049
QC Prep Batch Method: EPA-200.7 (MISC PREP) **Analysis Method:** EPA-200.7 (MISC)
Analysis Description: Total Metals - Misc

Lab Reagent Blank LRB-L555596 Matrix: AQU
Associated Lab Samples: 89791, 89792, 89793, 89794

Parameter	Units	Blank Result	MQL	Analyzed
Bismuth	mg/L	< 0.010	0.010	06/01/21 11:39

Laboratory Control Sample LCS-L555596

Parameter	Units	Spike Conc.	LCS Result	LCS %Rec	% Rec Limits
Bismuth	mg/L	0.100	0.097	97.0	85-115

Matrix Spike & Matrix Spike Duplicate A 89793-MS-L555596 A 89793-MSD-L555596

Parameter	Units	Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS %Rec	MSD %Rec	%Rec Limits	RPD	Max RPD
Bismuth	mg/L	0.149	0.100	0.100	0.314	0.317	165*	168*	70-130	0.9	20.0

Quality Control Data

Client ID: Materials Management Group, Inc.
Project Description: Resample at Belle Chase Primary School
Report No: 21-141-9001

QC Prep: L554819 **QC Analytical Batch(es):** L555217
QC Prep Batch Method: EPA-200.8 **Analysis Method:** EPA-200.8 (DW)
Analysis Description: Metals Analyses

Lab Reagent Blank LRB-L554819 Matrix: AQU
Associated Lab Samples: 89791, 89792, 89793, 89794

Parameter	Units	Blank Result	MQL	Analyzed
Lead	µg/L	< 0.500	0.500	05/25/21 13:01

Laboratory Control Sample LCS-L554819

Parameter	Units	Spike Conc.	LCS Result	LCS %Rec	% Rec Limits
Lead	µg/L	50.0	50.2	100	85-115

Matrix Spike & Matrix Spike Duplicate A 89794-MS-L554819 A 89794-MSD-L554819

Parameter	Units	Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS %Rec	MSD %Rec	%Rec Limits	RPD	Max RPD
Lead	µg/L	< 2.50	50.0	50.0	44.2	43.9	88.0	88.0	70-130	0.6	20.0

Quality Control Data

Client ID: Materials Management Group, Inc.
Project Description: Resample at Belle Chase Primary School
Report No: 21-141-9001

QC Prep: L554864 **QC Analytical Batch(es):** L555217
QC Prep Batch Method: EPA-200.8 **Analysis Method:** EPA-200.8 (DW)
Analysis Description: Metals Analyses

Lab Reagent Blank LRB-L554864 Matrix: AQU
Associated Lab Samples: 89795, 89796, 89797, 89798

Parameter	Units	Blank Result	MQL	Analyzed
Lead	µg/L	< 0.500	0.500	05/25/21 10:31

Laboratory Control Sample LCS-L554864

Parameter	Units	Spike Conc.	LCS Result	LCS %Rec	% Rec Limits
Lead	µg/L	50.0	48.5	97.0	85-115

Matrix Spike & Matrix Spike Duplicate A 89798-MS-L554864 A 89798-MSD-L554864

Parameter	Units	Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS %Rec	MSD %Rec	%Rec Limits	RPD	Max RPD
Lead	µg/L	< 0.503	50.3	50.3	48.1	49.8	96.0	99.0	70-130	3.4	20.0

Shipment Receipt Form

Customer Number: **01266**

Customer Name: **Materials Management Group, Inc.**

Report Number: **21-141-9001**

Shipping Method

☐ Fed Ex ☐ US Postal ☐ Lab ☐ Other :
☐ UPS ☒ Client ☐ Courier Thermometer ID:

Shipping container/cooler uncompromised?	☒ Yes	☐ No	
Number of coolers/boxes received	1		
Custody seals intact on shipping container/cooler?	☐ Yes	☐ No	☒ Not Present
Custody seals intact on sample bottles?	☐ Yes	☐ No	☒ Not Present
Chain of Custody (COC) present?	☒ Yes	☐ No	
COC agrees with sample label(s)?	☒ Yes	☐ No	
COC properly completed	☒ Yes	☐ No	
Samples in proper containers?	☒ Yes	☐ No	
Sample containers intact?	☒ Yes	☐ No	
Sufficient sample volume for indicated test(s)?	☒ Yes	☐ No	
All samples received within holding time?	☒ Yes	☐ No	
Cooler temperature in compliance?	☒ Yes	☐ No	
Cooler/Samples arrived at the laboratory on ice. Samples were considered acceptable as cooling process had begun.	☐ Yes	☒ No	
Water - Sample containers properly preserved	☐ Yes	☐ No	☒ N/A
Water - VOA vials free of headspace	☐ Yes	☐ No	☒ N/A
Trip Blanks received with VOAs	☐ Yes	☐ No	☒ N/A
Soil VOA method 5035 – compliance criteria met	☐ Yes	☐ No	☒ N/A
☐ High concentration container (48 hr)	☐ Low concentration EnCore samplers (48 hr)		
☐ High concentration pre-weighed (methanol -14 d)	☐ Low conc pre-weighed vials (Sod Bis -14 d)		
Special precautions or instructions included?	☐ Yes	☒ No	

Comments:

Signature:

Date & Time:

Water Sampling Report (Sampling Date: 5/1/2021)

Belle Chasse Primary School

601 F. Edward Hebert Blvd., Belle Chasse, LA 70037

Report Date: 5/21/2021

MMG # 3921 LDH 38

**Appendix C: Laboratory Accreditations and
Certifications**



STATE OF LOUISIANA

DEPARTMENT OF HEALTH
OFFICE OF PUBLIC HEALTH

Waypoint Analytical, LLC

2790 Whitten Road

Memphis, TN 38133

is certified by the State of Louisiana in accordance with
Department of Health regulations
Louisiana Administrative Code 48:V.Chapter 80 and
Louisiana Administrative Code 51:XII.101 and 301

Scope of certification is limited to the
fields of testing which accompany this certificate

Continued certified status depends on successful
ongoing participation in the program

CERTIFICATE NUMBER: LA037
EFFECTIVE DATE: January 1, 2021
EXPIRATION DATE: December 31, 2021

A handwritten signature in blue ink, reading "Richard T. Tulley".

Richard T. Tulley, Ph. D.,
Public Health Laboratory Director
1209 Leesville Avenue
Baton Rouge, Louisiana 70802

A handwritten signature in blue ink, reading "Grant Aucoin".

Grant Aucoin
Laboratory Certification Program
Manager

subject to forfeiture or revocation

**Louisiana Department of Health**

Office of Public Health

1209 Leesville Avenue

Baton Rouge, LA 70802

(225) 219-5202

Louisiana Certification - 2021**Waypoint Analytical, LLC located in Memphis, TN**

meets all of the criteria necessary for CERTIFICATION by the State of Louisiana for the analysis of drinking water for the following contaminants:

Drinking Water Parameters

Analyte	Method	Primary AB	Method Revision # or date	Technology Description	TNI Method Code	TNI Analyte Code
Lead	EPA 200.8	FL	rev 5.4	ICP-MS	10014605	1075

The State of Florida is the primary TNI Accreditation Body for Waypoint Analytical, LLC. The Louisiana Department of Health is a secondary Certification Body for this laboratory. For a list of additional parameters, refer to the Florida Department of Health.