




Kathleen Babineaux Blanco
GOVERNOR

STATE OF LOUISIANA
DEPARTMENT OF HEALTH AND HOSPITALS



Frederick P. Cerise, M.D., M.P.H.
SECRETARY

June 28, 2007

Mr. Bill Chapin
Product Compliance Administrator
Cash Acme
2400 7th Avenue SW
Cullman, Alabama 35055

Re: Approval for the use of the ½" through 1" SharkBite push-fit fittings on type K and L hard drawn and annealed seamless copper water tubes (ASTM B88), CPVC water tube (ASTM D2846/2846M-99), and PEX water tube (ASTM F876, F877) using the tube liner as designed by Cash Acme.

Dear Mr. Chapin:

Receipt is acknowledged of your email dated March 29, 2007 addressed to the attention of Mr. Jake Causey, P.E., relative to requesting approval of your ½" through 1" SharkBite plumbing product for use in the State of Louisiana. This email was received on March 29, 2007. After careful review by this office Mr. Causey subsequently requested additional product data and product standard certification listing. Receipt is acknowledged of your reply email on June 18, 2007 including the additional data. Subsequent emails were received on June 20, 2007 further including additional product data.

Essentially, your email request that the ½" through 1" SharkBite push-fit fittings be approved under Section 102.7 "Alternate Materials and Methods of Construction" of the Louisiana State Plumbing Code, 2000 Edition (LSPC). This Section allows the use of any material or method of construction not specifically prescribed under the LSPC provided that any such alternate has been approved by the Plumbing Official. Section 202 of the LSPC defines the Plumbing Official as: i.) the State Health Officer (= co-State Plumbing Official), and ii.) any local Plumbing Department (= co-Local Plumbing Official) established and authorized by a political subdivision of the state. After our discussions and review of the literature, etc., provided, please be advised that this office offers no objection to the use of the ½" through 1" SharkBite push-fit fittings for type K and L hard drawn and annealed seamless copper water tubes (ASTM B88), CPVC water tube (ASTM D2846/2846M-99), and PEX water tube (ASTM F876, F877) using the tube liner as designed by Cash Acme in Louisiana.

June 28, 2007

Re: ½" through 1" SharkBite Push-Fit Fittings


Page 2 of 3

This no objection is given with the understanding that the product shall be accompanied by the manufacturer's assembly and disassembly instructions. Per Section 303.5 of the LSPC, the manufacturer's published procedures or recommendations shall be followed upon installation.

Please be advised that this action does not abrogate your responsibility to obtain similar approval from those local jurisdictions having its own local Plumbing Department (= co-Local Plumbing Official) since the local jurisdiction's requirements may be stricter than the requirements of the LSPC.

Should you have any questions, please do not hesitate to contact my staff at (225) 342-7273.

Sincerely,



Jimmy Guidry, M.D.
State Health Officer

JKC/jkc

cc: Karen Irion, Acting Chief Engineer, OPH
Sidney Becnel, Center for Environmental Health Services, OPH
Jake Causey, Engineer, Engineering Services Section, Central Office, Center for Environmental Health Services, OPH
District/Regional Engineers, Engineering Services Section, OPH
Rene' Chedraui, Director, Engineering & Consulting Services, LDHH
John Barker, Executive Director, State Plumbing Board of Louisiana
Curt McCarty, Building Codes Administrator, Louisiana State Uniform Construction
Code Council, c/o Office of Management and Finance, Department of Public Safety and Corrections
Charles G. Marceaux, Executive Director, State Licensing Board for Contractors
Local Plumbing Inspectors in LA (from S. Becnel's MSAccess list)