

Minimum Distance Requirements

	Private Water Well	Public Water Wells	Pressurized Water Lines	Property Boundaries
Septic Tank	50 feet	50 feet	10 feet	No minimum stated
Oxidation Pond	50 feet	100 feet	25 feet	20 feet
Edge of spray from spray heads	50 feet	100 feet	25 feet	10 feet
Overland Flow (discharge point & field of flow)	50 feet	100 feet	25 feet	20 feet
Absorption trenches	50 feet	100 feet	25 feet	10 feet